



Bob Holden, Governor • Stephen M. Mahfood, Director

DEPARTMENT OF NATURAL RESOURCES

www.dnr.state.mo.us

DEC 1 1 2003

Mr. Jeffrey M. Berger
Product Sales Manager
Parker Industrial Hose Division
P.O. Box 3258, 2601 Battlefield Road
Springfield, MO 65808-3258

APPROVAL LETTER

03-2

Dear Mr. Berger:

This is to inform you of the approval of the Balance Stage II Vapor Recovery (VR) hoses, formally named Dayco Petroflex series 7574BTN and 7574BTF, which your company submitted to the Air Pollution Control Program (APCP). These VR hoses were previously successfully tested and approved by the APCP, utilizing the Missouri Performance Evaluation Test Procedures (MOPETP). These VR hoses have been re-labeled Parker-Hannifin series # 7574BTN and 7574BTF. Also included on the hose assembly label is the Julian date code, which is etched onto the coupling of the hose when the assembly is manufactured. The Parker-Hannifin VR hoses have been determined by the Technical Review Committee to have no other changes that would be expected to effect VR performance.

The Parker-Hannifin VR hoses are hereby approved for use on all MOPETP approved Balance Stage II VR systems. The Parker-Hannifin series # 7574 BTF features a liquid pick-up mechanism and is marked with the words "Nozzle End." The end marked "Nozzle End" must be installed next to the nozzle (or next to the nozzle swivel). Failure to install the nozzle correctly will cause the liquid pick-up to fail, and would constitute a violation of this approval. Similarly, disassembly of the internal product hose from the vapor hose and re-assembly with the liquid pick-up mechanism out of position with the end marked "Nozzle End" would be considered in violation of this approval.

Remaining Dayco 7574 hoses, previously approved, will be allowed to be sold and used until the existing supply is exhausted.



Integrity and excellence in everything we do



Mr. Jeffrey M. Berger
Page Two

The APCP approves the equipment listed below, subject to the terms and conditions of approval listed above and on MOPETP Approval APCP-0002-001-99. The equipment below is approved for use on all Approved Balance Vapor Recovery systems.

Manufacturer	Model	Component
Parker-Hannifin Industrial Hose Division	7574BTN, 7574BTF	Vapor Recovery hose

The APCP thanks you and Parker-Hannifin Industrial Hose Division, for your cooperation and compliance. If you have any questions regarding this issue please contact Bud Pratt of the Air Pollution Control Program, P.O. Box 176, Jefferson City, MO 65102 or by phone at (573) 751-4817.

Sincerely,

AIR POLLUTION CONTROL PROGRAM



Leanne J. Tippet
Director

LJT:bpm

Attachment

c: Stage II List
Local Agencies