

CONSTRUCTION PERMIT DETERMINATIONS

Dec. 15, 1995

NOTE: Replacing "like for like" means exchanging a component from manufacturer X for manufacturer Y's component having an equivalent stock number

Construction Permit Required	Construction Permit Not Required
Replacement or updating spill buckets to - comply with UST requirements.	Replacement of hoses, breakaways, nozzles, retractors or any components thereof.
Replacing any dispenser not "like for like." <i>Example: Replacing a multi-product dispenser with a blended dispenser requires a permit.</i>	Updating from remote vapor check valves to nozzles with internal check valves. <i>Example: Exchanging Emco Wheaton 4001 nozzles which require remote vapor check valves for new Emco Wheaton 400j nozzles which have internal vapor check valves.</i>
Any modification of the vapor or UST plumbing.	Extension of the drop fill tube or replacement of float valves with no other modification.
Any addition of one or more islands, dispensers, nozzles, USTs, etc.	Replacement of UST caps, collars, seals, adapters, P/V valves with same or "like for like" components.
Any modification of the vapor recovery system which may affect the overall efficiency of that system.	Addition of pressure/vacuum valve or extending a vent pipe.
Any modification that would increase product dispensing rate above the maximum in CARB certifications.	Replacement of plumbing or components inside the dispenser with the same or "like for like" component.
Any modification to a system not specifically in the CARB certification or, if applicable, in Missouri Department of Natural Resources approval documents.	Replacement of components in manholes or access ports with same or "like for like" components.
*Any time the facility breaks concrete for any reason including UST updates. <i>Note: Agency discretion determines permit applicability. Refer to note at * below.</i>	Replacement of vapor line/fillport adapters. Examples: <ol style="list-style-type: none"> 1. Replacing OW611-AV-3" with OPW 61-AS or 633-T. 2. In vapor assist and processor systems, replacing processor or electronic control parts with "like for like."

*If the modification does not fall clearly into Column I or Column II, the Issuing Agency, (City, County or St. Louis Regional Office) must determine the permit requirement consistent with the spirit and intent of the policies outlined in columns I and II and the Air Pollution Control Program policy. When the determination is "No Permit Required," then the issuing agency is responsible for ensuring that the facility is in complete compliance with all requirements of department policy and 10 CSR 10-5.220. Verbal determinations are not acceptable. All determinations must be transmitted via written correspondence and copied to APCP.