

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES

MISSOURI CLEAN WATER COMMISSION



MISSOURI STATE OPERATING PERMIT

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92nd Congress) as amended,

Permit No. MO-0002470

Owner: Ajinomoto-Windsor Foods
Address: 5691 South Davinci Lane, Carthage, MO 64836

Continuing Authority: Ajinomoto Windsor Inc.
Address: 7124 N. Marine Drive, Portland, OR 97203

Facility Name: Windsor Foods
Facility Address: 5691 & 5695 S. Davinci Lane, Carthage, MO 64836

Legal Description: See page 2
UTM Coordinates: See page 2

Receiving Stream: See page 2
First Classified Stream and ID: See page 2
USGS Basin & Sub-watershed No.: See page 2

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

FACILITY DESCRIPTION

See page 2

This permit authorizes only wastewater and stormwater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Sections 640.013, 621.250, and 644.051.6 of the Law.

October 1, 2016
Effective Date

Sara Parker Paulley, Director, Department of Natural Resources

December 31, 2017
Expiration Date

John Madras, Director, Water Protection Program

FACILITY DESCRIPTION (CONTINUED)

Outfall #001 - Process water and domestic waste from frozen food manufacturer SIC #2038; NAICS #311412

Receives process and domestic waste waters which are initially pumped from a well and hypo-chlorinated and softened. The process water then goes through production, sanitation, and condensers in the production plant. Treatment methods are a bar screen, dissolved air flotation, pH treatment, flow equalization, and aluminum based coagulation and flocculation. The water combines with the domestic waste from the facility in an activated sludge treatment system, followed by a clarifier and ultraviolet disinfection. There is a primary sludge holding basin and secondary holding basin. Industrial and domestic sludge are removed by a contract hauler. Land application is not authorized at this facility.

Legal Description: NW¼, SE¼, Sec.33, T28N, R31W, Jasper County
UTM Coordinates: X = 382975, Y = 4107050
Receiving Stream: Tributary to Center Creek
First Classified Stream and ID: Center Creek (P) 3203, 303(d)
USGS Basin & Sub-watershed No.: Grove Creek-Center Creek (11070207-0606)
Design flow: 100,000 gallons per day
Actual flow: 70,400 gallons per day
Design Sludge Production: 226 dry tons/year.

OUTFALL # 002 – Stormwater – SIC # 2038; NAICS # 311412

Stormwater from the eastern portion of the facility.

Legal Description: NE¼, SE¼, Sec.33, T28N, R31W, Jasper County
UTM Coordinates: X = 383246, Y = 4107000
Receiving Stream: Tributary to Center Creek
First Classified Stream and ID: Center Creek (P) 3203, 303(d)
USGS Basin & Sub-watershed No.: Grove Creek-Center Creek (11070207-0606)
Est. Flow in a 10 Yr. 24 Hr. Rain Event: 0.16 MGD
Actual flow: Dependent upon precipitation

OUTFALL # 003 – Stormwater – SIC # 2038; NAICS # 311412

Stormwater from the northeast portion of the facility.

Legal Description: NE¼, SE¼, Sec.33, T28N, R31W, Jasper County
UTM Coordinates: X = 383214, Y = 4107046
Receiving Stream: Tributary to Center Creek
First Classified Stream and ID: Center Creek (P) 3203, 303(d)
USGS Basin & Sub-watershed No.: Grove Creek-Center Creek (11070207-0606)
Est. Flow in a 10 Yr. 24 Hr. Rain Event: 0.14 MGD
Actual flow: Dependent upon precipitation

OUTFALL # 004 – Stormwater – SIC # 2038; NAICS # 311412

Stormwater from the northern portion of the facility.

Legal Description: NE¼, SE¼, Sec.33, T28N, R31W, Jasper County
UTM Coordinates: X = 383178, Y = 4107060
Receiving Stream: Tributary to Center Creek
First Classified Stream and ID: Center Creek (P) 3203, 303(d)
USGS Basin & Sub-watershed No.: Grove Creek-Center Creek (11070207-0606)
Est. Flow in a 10 Yr. 24 Hr. Rain Event: 0.22 MGD
Actual flow: Dependent upon precipitation

OUTFALL # 005 – Stormwater – SIC # 2038; NAICS # 311412

Stormwater from the southern portion of the facility.

Legal Description: NE¼, SE¼, Sec.33, T28N, R31W, Jasper County
UTM Coordinates: X = 383106, Y = 4106870
Receiving Stream: Tributary to Center Creek
First Classified Stream and ID: Center Creek (P) 3203, 303(d)
USGS Basin & Sub-watershed No.: Grove Creek-Center Creek (11070207-0606)
Est. Flow in a 10 Yr. 24 Hr. Rain Event: 0.39 MGD
Actual flow: Dependent upon precipitation

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

EFFLUENT PARAMETERS	UNITS	INTERIM EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
OUTFALL #001 <i>main outfall</i>						
TABLE A-1 INTERIM EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS						
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The interim effluent limitations shall become effective on October 1, 2016 and remain in effect through September 30, 2019 . Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
PHYSICAL						
Flow	MGD	*		*	once/week	24 hr. total
CONVENTIONAL						
Biochemical Oxygen Demand ₅ (BOD ₅)	mg/L	45		30	once/month	composite §
Chlorine, Total Residual [±]	µg/L	*		*	once/month	grab
Cyanide Amenable to Chlorination [€]	µg/L	*		*	once/month	grab
<i>E. Coli</i> ^π	#/100 mL	*		*	once/month	grab
Oil & Grease	mg/L	15		10	once/month	grab
Oxygen, Dissolved (DO) ^ϕ	mg/L	*		*	once/month	grab
pH ^Ω	SU	6.5 to 9.0		6.5 to 9.0	once/month	grab
Total Suspended Solids	mg/L	45		30	once/month	composite §
METALS						
Aluminum, Total Recoverable	µg/L	*		*	once/month	grab
TMDL METAL						
Zinc, Total Recoverable	µg/L	*		*	once/month	grab
NUTRIENTS						
Ammonia as N(April 1 – Sept 30)	mg/L	6.0		1.2	once/month	grab
Ammonia as N (Oct 1 – March 31)	mg/L	*		*	once/month	grab
Nitrogen, Total (TN)	mg/L	*		*	once/month	grab
Phosphorus, Total (TP)	mg/L	*		*	once/month	grab
OTHER						
Chloride + Sulfate	mg/L	*		*	once/month	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE <u>NOVEMBER 28, 2016</u> . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						

See Notes on Page 6

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (CONTINUED)

EFFLUENT PARAMETERS	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
OUTFALL #001-main outfall						
TABLE A-2 FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS						
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective on October 1, 2019 and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
PHYSICAL						
Flow	MGD	*		*	once/week	24 hr. total
CONVENTIONAL						
Biochemical Oxygen Demand ₅	mg/L	45		30	once/month	composite §
Chlorine, Total Residual [±]	µg/L	*		*	once/month	grab
Cyanide, Amenable to Chlorination [€]	µg/L	*		*	once/month	grab
<i>E. Coli</i> ^π	#/100 mL	630		126	once/month	grab
Oil & Grease	mg/L	15		10	once/month	grab
Oxygen, Dissolved (DO) ^ϕ	mg/L	*		*	once/month	grab
pH ^Ω	SU	6.5 to 9.0		6.5 to 9.0	once/month	grab
Total Suspended Solids	mg/L	45		30	once/month	composite §
METALS						
Aluminum, Total Recoverable	µg/L	*		*	once/month	grab
TMDL METAL						
Zinc, Total Recoverable	µg/L	*		*	once/month	grab
NUTRIENTS						
Ammonia as N (April 1 – Sept 30)	mg/L	6.0		1.2	once/month	grab
Ammonia as N (Oct 1 – March 31)	mg/L	*		*	once/month	grab
Nitrogen, Total (TN)	mg/L	*		*	once/month	grab
Phosphorus, Total (TP)	mg/L	*		*	once/month	grab
OTHER						
Chloride + Sulfate	mg/L	*		*	once/month	grab
MONITORING REPORTS SHALL BE SUBMITTED MONTHLY ; THE FIRST REPORT IS DUE NOVEMBER 28, 2019 . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						

See Notes on Page 6

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (CONTINUED)

OUTFALL #002, #003, #004, #005-Stormwater Only		TABLE A-3 INTERIM EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS				
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The interim effluent limitations shall become effective on October 1, 2016 and remain in effect through September 30, 2019 . Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
EFFLUENT PARAMETERS	UNITS	INTERIM LIMITATIONS		BENCHMARK	MONITORING REQUIREMENTS	
		DAILY MAXIMUM	MONTHLY AVERAGE		MEASUREMENT FREQUENCY	SAMPLE TYPE [∞]
PHYSICAL						
Flow	MGD	*		-	once/quarter [◇]	24 hr. est.
Precipitation	inches	*		-	once/quarter [◇]	measured
CONVENTIONAL						
Chemical Oxygen Demand	mg/L	*		-	once/quarter [◇]	grab
Oil & Grease	mg/L	*		-	once/quarter [◇]	grab
pH ^Ω	SU	*		-	once/quarter [◇]	grab
Total Suspended Solids	mg/L	**		100	once/quarter [◇]	grab
TMDL Metal						
Zinc, Total Recoverable	µg/L	*		-	once/quarter [◇]	grab
OTHER						
<i>E. Coli</i> ^π	#/100 mL	*	*	-	once/month	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>QUARTERLY</u> ; THE FIRST REPORT IS DUE <u>JANUARY 28, 2017</u> . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						

OUTFALL #002, #003, #004, #005-Stormwater Only		TABLE A-4 FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS				
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective on October 1, 2019 and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
EFFLUENT PARAMETERS	UNITS	FINAL LIMITATIONS		BENCHMARK	MONITORING REQUIREMENTS	
		DAILY MAXIMUM	MONTHLY AVERAGE		MEASUREMENT FREQUENCY	SAMPLE TYPE [∞]
PHYSICAL						
Flow	MGD	*		-	once/quarter [◇]	24 hr. est.
Precipitation	inches	*		-	once/quarter [◇]	measured
CONVENTIONAL						
Chemical Oxygen Demand	mg/L	90		-	once/quarter [◇]	grab
Oil & Grease	mg/L	15		-	once/quarter [◇]	grab
pH ^Ω	SU	6.5-9.0		-	once/quarter [◇]	grab
Total Suspended Solids	mg/L	**		100	once/quarter [◇]	grab
TMDL Metal						
Zinc, Total Recoverable	µg/L	*		-	once/quarter [◇]	grab
OTHER						
<i>E. Coli</i> ^π	#/100 mL	*	*	-	once/month	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>QUARTERLY</u> ; THE FIRST REPORT IS DUE <u>JANUARY 28, 2020</u> . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						

See Notes on Page 6

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (CONTINUED)

- * Monitoring requirement only.
- ** Monitoring requirement with associated benchmark. See Special Conditions #10 through #13.
- § A 24-hour composite sample is composed of 48 aliquots (subsamples) collected at 30 minute intervals by an automatic sampling device.
- ∞ All samples shall be collected from a discharge resulting from a precipitation event greater than 0.1 inches in magnitude and that occurs at least 72 hours from the previously measurable precipitation event. If a discharge does not occur within the reporting period, report as no discharge. The total amount of precipitation should be noted from the event from which the samples were collected.
- Ω The facility will report the minimum and maximum values. pH is not to be averaged.
- € This permit contains Cyanide Amenable to Chlorination as a parameter. Cyanide amenable to chlorination is associated with a minimum quantification level (ML). The department has determined the current acceptable minimum level (ML) of cyanide amenable to chlorination to be 10 µg/L when using Method #9102A from the U.S. EPA National Exposure Research Laboratory. The permittee will conduct analyses in accordance with this method, or equivalent, and report actual analytical values.
- ± This permit contains Total Residual Chlorine (TRC) as a parameter. TRC is associated with a minimum quantification level (ML). The Department has determined the current acceptable ML for total residual chlorine to be 130 µg/L when using the DPD Colorimetric Method #4500 – CL G. from Standard Methods for the Examination of Waters and Wastewater. The permittee will conduct analyses in accordance with this method, or equivalent, and report actual analytical values. Measured values greater than or equal to the minimum quantification level of 130 µg/L will be considered exceedances of the criteria found in 10 CSR 20-7.031 Table A. Values less than the minimum quantification level of 130 µg/L will be considered to be in compliance with 10 CSR 20-7.031 Table A. The minimum quantification level does not authorize the discharge of chlorine in excess of the effluent limits stated in 10 CSR 20-7.031 Table A.
- φ Dissolved Oxygen is a minimum value. The facility will report the minimum value for the daily report.
- π Final limitations and monitoring requirements for *E. coli* are applicable only during the recreational season from April 1 through October 31. The Monthly Average Limit for *E. coli* is expressed as a seasonal geometric mean.
- ◇ Quarterly sampling

MINIMUM QUARTERLY SAMPLING REQUIREMENTS			
QUARTER	MONTHS	EFFLUENT PARAMETERS	REPORT IS DUE
First	January, February, March	Sample at least once during any month of the quarter	April 28 th
Second	April, May, June	Sample at least once during any month of the quarter	July 28 th
Third	July, August, September	Sample at least once during any month of the quarter	October 28 th
Fourth	October, November, December	Sample at least once during any month of the quarter	January 28 th

B. STANDARD CONDITIONS

In addition to specified conditions stated herein, this permit is subject to the attached Part I and Part III standard conditions dated August 1, 2014 and March 1, 2015, respectively, and hereby incorporated as though fully set forth herein.

C. SPECIAL CONDITIONS

1. This permit establishes final ammonia limitations based on Missouri’s current Water Quality Standard. On August 22, 2013, the U.S. Environmental Protection Agency (EPA) published a notice in the Federal Register announcing of the final national recommended ambient water quality criteria for protection of aquatic life from the effects of ammonia in freshwater. The EPA’s guidance, Final Aquatic Life Ambient Water Quality Criteria for Ammonia – Fresh Water 2013, is not a rule, nor automatically part of a state’s water quality standards. States must adopt new ammonia criteria consistent with EPA’s published ammonia criteria into their water quality standards that protect the designated uses of the water bodies. The Department of Natural Resources has initiated stakeholder discussions on how to best incorporate these new criteria into the State’s rules. A date for when this rule change will occur has not been determined. Also, refer to Section IV of this permit’s factsheet for further information including estimated future effluent limits for this facility. It is recommended the permittee view the Department’s 2013 EPA criteria Factsheet located at <http://dnr.mo.gov/pubs/pub2481.htm>.

C. SPECIAL CONDITIONS, CONTINUED

2. This permit may be reopened and modified, or alternatively revoked and reissued, to:
 - (a) Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a) (2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
 - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
 - (2) controls any pollutant not limited in the permit.
 - (b) Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test, or other information indicates changes are necessary to assure compliance with Missouri's Water Quality Standards.
 - (c) Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri's list of waters of the state not fully achieving the state's water quality standards, also called the 303(d) list.

The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.
3. All outfalls must be clearly marked in the field.
4. Water Quality Standards
 - (a) To the extent required by law, discharges to waters of the state shall not cause a violation of water quality standards rule under 10 CSR 20-7.031, including both specific and general criteria.
 - (b) General Criteria. The following general water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:
 - (1) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
 - (2) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
 - (3) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
 - (4) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
 - (5) There shall be no significant human health hazard from incidental contact with the water;
 - (6) There shall be no acute toxicity to livestock or wildlife watering;
 - (7) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
 - (8) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.
5. Changes in Discharges of Toxic Pollutant
In addition to the reporting requirements under §122.41(1), all existing manufacturing, commercial, mining, and silvicultural dischargers must notify the Director as soon as they know or have reason to believe:
 - (a) That an activity has occurred or will occur which would result in the discharge, on a routine or frequent basis, of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following notification levels:
 - (1) One hundred micrograms per liter (100 µg/L);
 - (2) Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile;
 - (3) Five hundred micrograms per liter (500 µg/L) for 2,4-dinitrophenol and for 2-methyl-4, 6-dinitrophenol;
 - (4) One milligram per liter (1 mg/L) for antimony;
 - (5) Five (5) times the maximum concentration value reported for the pollutant in the permit application in accordance with 40 CFR 122.21(g)(7); or
 - (6) The notification level established by the department in accordance with 40 CFR 122.44(f).
 - (b) That any activity has occurred or will occur which would result in any discharge, on a non-routine or infrequent basis, of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
 - (1) Five hundred micrograms per liter (500 µg/l);
 - (2) One milligram per liter (1 mg/l) for antimony;
 - (3) Ten (10) times the maximum concentration value reported for that pollutant in the permit application in accordance with §122.21(g)(7).
 - (4) The level established by the Director in accordance with §122.44(f).
6. Report as no-discharge when a discharge does not occur during the report period.

C. SPECIAL CONDITIONS, CONTINUED

7. Reporting of Non-Detects

- (a) An analysis conducted by the permittee or their contracted laboratory shall be conducted in such a way that the precision and accuracy of the analyzed result can be enumerated.
- (b) The permittee shall not report a sample result as “Non-Detect” without also reporting the detection limit of the test. Reporting as “Non-Detect” without also including the detection limit will be considered failure to report, which is a violation of this permit.
- (c) The permittee shall report the “Non-Detect” result using the less than sign and the minimum detection limit (e.g. <10).
- (d) Where the permit contains a Minimum Level (ML) and the permittee is granted authority in the permit to report zero in lieu of the < ML for a specified parameter (conventional, priority pollutants, metals, etc.), then zero (0) is to be reported for that parameter.
- (e) See Standard Conditions Part I, Section A, #4 regarding proper detection limits used for sample analysis.
- (f) When calculating monthly averages, one-half of the minimum detection limit (MDL) should be used instead of a zero. Where all data are below the MDL, the “<MDL” shall be reported as indicated in item (C).

8. It is a violation of the Missouri Clean Water Law to fail to pay fees associated with this permit (644.055 RSMo).

9. Any pesticide discharge from any point source shall comply with the requirements of Federal Insecticide, Fungicide and Rodenticide Act, as amended (7 U.S.C. 136 *et. seq.*) and the use of such pesticides shall be in a manner consistent with its label.

10. The purpose of the Stormwater Pollution Prevention Plan (SWPPP) and the Best Management Practices (BMPs) listed herein is the prevention of pollution of waters of the state. A deficiency of a BMP means it was not effectively preventing pollution [10 CSR 20-2.010(56)] of waters of the state, and corrective actions means the facility took steps to eliminate the deficiency.

11. Facility SIC codes found in 40 CFR 122.26(b)(14) and/or 10 CSR 20-6.200(2) shall implement a SWPPP and must be prepared and implemented upon permit issuance. The SWPPP must be kept on-site and should not be sent to the department unless specifically requested. The SWPPP must be reviewed and updated every five (5) years or as site conditions change (see Rationale and Derivation: antidegradation analysis and SWPPP in the fact sheet). The permittee shall select, install, use, operate, and maintain the Best Management Practices prescribed in the SWPPP in accordance with the concepts and methods described in: *Developing Your Stormwater Pollution Prevention Plan, A Guide for Industrial Operators*, (EPA 833-B-09-002) published by the EPA in February 2009 (www.epa.gov/npdes/pubs/industrial_swppp_guide.pdf). The SWPPP must include:

- (a) A listing of specific contaminants and their control measures (or BMPs) and a narrative explaining how BMPs are implemented to control and minimize the amount of contaminants potentially entering stormwater. The BMPs should be designed to treat the stormwater up to the 10 year, 24 hour rain event.
- (b) For new, altered, or expanded stormwater discharges, the SWPPP shall identify reasonable and effective BMPs while accounting for environmental impacts of varying control methods. The antidegradation analysis must document why no discharge or no exposure options are not feasible. The selection and documentation of appropriate control measures shall serve as an alternative analysis of technology and fulfill the requirements of antidegradation [10 CSR 20-7.031(3)]. Failure to implement and maintain the chosen BMP is a permit violation. For further guidance, consult the antidegradation implementation procedure at <http://dnr.mo.gov/env/wpp/docs/AIP050212.pdf>.
- (c) The SWPPP must include a schedule for once per month site inspections and brief written reports. The inspection report must include precipitation information for the entire period since last inspection, as well as observations and evaluations of BMP effectiveness. Throughout coverage under this permit, the facility must perform ongoing SWPPP review and revision to incorporate any site condition changes.
 - i. Operational deficiencies must be corrected within seven (7) calendar days.
 - ii. Minor structural deficiencies must be corrected within fourteen (14) calendar days.
 - iii. Major structural deficiencies must be reported to the regional office within seven (7) days of discovery. The initial report shall consist of the deficiency noted, the proposed remedies, the interim or temporary remedies (including the general timing of the placement of the interim measures), and an estimate of the timeframe needed to wholly complete the repairs or construction. The permittee will work with the regional office to determine the best course of action, including but not limited to temporary structures to control stormwater runoff. The facility shall correct the major structural deficiency as soon as reasonably achievable.
 - iv. All actions taken to correct the deficiencies shall be included with the written report, including photographs.
 - v. Inspection reports must be kept on site with the SWPPP and maintained for a period of five (5) years. These must be made available to department and EPA personnel upon request.
- (d) A provision for designating an individual to be responsible for environmental matters.
- (e) A provision for providing training to all personnel involved in material handling and storage, and housekeeping of maintenance and cleaning areas. Proof of training shall be submitted on request of the department.

C. SPECIAL CONDITIONS, CONTINUED

12. This permit stipulates pollutant benchmarks applicable to your discharge. The benchmarks do not constitute direct numeric effluent limitations; therefore, a benchmark exceedance alone is not a permit violation. Benchmark monitoring and visual inspections shall be used to determine the overall effectiveness of SWPPP and to assist you in knowing when additional corrective action may be necessary to protect water quality. If a sample exceeds a benchmark concentration you must review your SWPPP and your BMPs to determine what improvements or additional controls are needed to reduce that pollutant in your stormwater discharge(s).

Any time a benchmark exceedance occurs a Corrective Action Report (CAR) must be completed. A CAR is a document that records the efforts undertaken by the facility to improve BMPs to meet benchmarks in future samples. CARs must be retained with the SWPPP and available to the department upon request. If the efforts taken by the facility are not sufficient and subsequent exceedances of a benchmark occur, the facility must contact the department if a benchmark value cannot be achieved. Failure to take corrective action to address a benchmark exceedance and failure to make measureable progress towards achieving the benchmarks is a permit violation.

13. Permittee shall adhere to the following minimum Best Management Practices (BMPs):
- (a) Prevent the spillage or loss of fluids, oil, grease, fuel, etc. from vehicle maintenance, equipment cleaning, or warehouse activities and thereby prevent the contamination of stormwater from these substances.
 - (b) Provide collection facilities and arrange for proper disposal of waste products including but not limited to petroleum waste products, and solvents.
 - (c) Store all paint, solvents, petroleum products and petroleum waste products (except fuels), and storage containers (such as drums, cans, or cartons) so that these materials are not exposed to stormwater or provide other prescribed BMPs such as plastic lids and/or portable spill pans to prevent the commingling of stormwater with container contents. Commingled water may not be discharged under this permit. Provide spill prevention control, and/or management sufficient to prevent any spills of these pollutants from entering waters of the state. Any containment system used to implement this requirement shall be constructed of materials compatible with the substances contained and shall also prevent the contamination of groundwater.
 - (d) Provide good housekeeping practices on the site to keep trash from entry into waters of the state.
 - (e) Provide sediment and erosion control sufficient to prevent or control sediment loss off of the property to comply with general water quality criteria, effluent limits, or benchmarks. This could include the use of straw bales, silt fences, or sediment basins, if needed.
 - (f) Ensure adequate provisions are provided to prevent surface water intrusion into the storage basin, to divert stormwater runoff around the storage basin, and to protect embankments from erosion.
14. To protect the general criteria found at 10 CSR 20-7.031(4), before releasing water accumulated in secondary containment areas, it must be examined for hydrocarbon odor and presence of sheen. If the presence of odor or sheen is indicated, the water shall be treated using an appropriate method or disposed of in accordance with legally approved methods, such as being sent to a wastewater treatment facility. Following treatment, the water shall be tested for oil and grease, benzene, toluene, ethylbenzene, and xylene using 40 CFR part 136 methods. All pollutant levels must be below the most protective, applicable standards for the receiving stream, found in 10 CSR 20-7.031 Table A. Records of all testing and treatment of water accumulated in secondary containment shall be stored in the SWPPP to be available on demand to MDNR and EPA personnel.
15. Release of a hazardous substance must be reported to the department in accordance with 10 CSR 24-3.010. A record of each reportable spill shall be retained with the SWPPP and made available to the department upon request.
16. Bypasses of wastewater treatment mechanisms are not authorized at this facility unless they meet the criteria in 40 CFR 122.41(m). If a bypass occurs, the permittee shall report in accordance to 40 CFR 122.41(m)(3), and with Standard Condition Part I, Section B, subsection 2.b. Bypasses are to be reported to the SWRO Regional Office during normal business hours or the Environmental Emergency Response hotline at 573-634-2436 outside of normal business hours. Blending, which is the practice of combining a partially-treated wastewater process stream with a fully-treated wastewater process stream prior to discharge, is not considered a form of bypass. If the permittee wishes to utilize blending, the permittee shall file an application to modify this permit to facilitate the inclusion of appropriate monitoring conditions.
17. Permittee will cease discharge by connection to a facility with an area-wide management plan per 10 CSR 20-6.010(3)(B) within 90 days of notice of its availability.
18. The wastewater treatment facility must be sufficiently secured to restrict entry by children, livestock, and unauthorized persons as well as to protect the facility from vandalism.

C. SPECIAL CONDITIONS, CONTINUED

19. At least one gate must be provided to access the wastewater treatment facility and provide for maintenance and mowing. The gate shall remain locked except when opened by the permittee to perform operational monitoring, sampling, maintenance, mowing, or for inspections by the Department.
20. At least one (1) warning sign shall be placed on each side of the facility enclosure in such positions as to be clearly visible from all directions of approach. There shall also be one (1) sign placed for every five hundred feet (500') (150 m) of the perimeter fence. A sign shall also be placed on each gate. Minimum wording shall be SEWAGE TREATMENT FACILITY—KEEP OUT. Signs shall be made of durable materials with characters at least two inches (2") high and shall be securely fastened to the fence, equipment or other suitable locations.
21. A minimum of two (2) feet freeboard must be maintained in each lagoon cell. A lagoon level gauge, which clearly marks the minimum freeboard level, shall be provided in each lagoon cell.
22. An all-weather access road shall be provided to the treatment facility.
23. The discharge from the wastewater treatment facility shall be conveyed to the receiving stream via a closed pipe or a paved or rip-rapped open channel. Sheet or meandering drainage is not acceptable. The outfall sewer shall be protected against the effects of floodwater, ice or other hazards as to reasonably insure its structural stability and freedom from stoppage. The outfall shall be maintained so that a sample of the effluent can be obtained at a point after the final treatment process and before the discharge mixes with the receiving waters.
24. The berms of the lagoons and storage basins shall be mowed and kept free of any deep-rooted vegetation, animal dens, or other potential sources of damage to the berms.
25. The facility shall ensure that adequate provisions are provided to prevent surface water intrusion into the lagoons and storage basins and to divert stormwater runoff around the lagoon and protect embankments from erosion.
26. An Operation and Maintenance (O & M) manual shall be maintained by the permittee and made available to the operator. The O & M manual shall include key operating procedures and a brief summary of the operation of the facility.

D. SCHEDULE OF COMPLIANCE

Schedules of compliance are allowed under 40 CFR 122.47. The facility shall attain compliance with final effluent limitations for E. coli at outfall #001 and Oil and Grease and pH at outfall #002 as soon as reasonably achievable:

1. Within six months of the effective date of this permit, the permittee shall report progress made in attaining compliance with the final effluent limits.
2. The permittee shall submit interim progress reports detailing progress made in attaining compliance with the final effluent limits every 12 months from issuance date.
3. With 3 years of the effective date of this permit, the permittee shall attain compliance with the final effluent limits for E. coli at outfall #001, as well as final effluent limits for COD, pH, and Oil and grease at outfall #002-#005.

Please submit progress reports to:

Southwest Regional Office
2040 West Woodland
Springfield, MO 65807-5912

MISSOURI DEPARTMENT OF NATURAL RESOURCES
FACT SHEET
FOR THE PURPOSE OF RENEWAL
OF
MO-0002470
AJINOMOTO-WINDSOR FOODS

The Federal Water Pollution Control Act ("Clean Water Act" Section 402 Public Law 92-500 as amended) established the National Pollution Discharge Elimination System (NPDES) permit program. This program regulates the discharge of pollutants from point sources into the waters of the United States, and the release of stormwater from certain point sources. All such discharges are unlawful without a permit (Section 301 of the "Clean Water Act"). After a permit is obtained, a discharge not in compliance with all permit terms and conditions is unlawful. Missouri State Operating Permits (MSOPs) are issued by the Director of the Missouri Department of Natural Resources (Department) under an approved program, operating in accordance with federal and state laws (Federal "Clean Water Act" and "Missouri Clean Water Law" Section 644 as amended). MSOPs are issued for a period of five (5) years unless otherwise specified for less.

As per [40 CFR Part 124.8(a)] and [10 CSR 20-6.020(1)2.] a factsheet shall be prepared to give pertinent information regarding the applicable regulations, rationale for the development of effluent limitations and conditions, and the public participation process for the Missouri State Operating Permit (MSOP or operating permit) listed below. A factsheet is not an enforceable part of an operating permit.

Part I. FACILITY INFORMATION

Facility Type: Categorical Industrial
 Facility SIC Code(s): 2038
 Facility NAICS Code: 311412
 Application Date: 05/29/2013
 Expiration Date: 09/14/2013
 Last Inspection: 04/08/2013 Found to be Not in Compliance at time of inspection

FACILITY DESCRIPTION:

Ajinomoto-Windsor foods is a frozen food manufacturer. They primarily process prepared meat products, frozen vegetables, and cheese appetizer products. There is one process water outfall supplied by groundwater from onsite wells, and four stormwater outfalls. Outfall #001 receives process and domestic waste waters which are initially pumped from onsite wells and hypo-chlorinated and softened. The water is used for drinking water, domestic water, and industrial process water. After softening and hypo-chlorination, the process water then goes through production, sanitation, and condensers in the production plant. Treatment methods are a bar screen, dissolved air flotation, pH treatment, flow equalization, and aluminum based coagulation and flocculation. The water combines with the domestic waste from the facility in an activated sludge treatment system, followed by a clarifier and ultraviolet disinfection. There is a primary sludge holding basin and secondary holding basin. Industrial and domestic sludge are removed by a contract hauler. Land application is not authorized at this facility

PERMITTED FEATURES TABLE:

OUTFALL	AVERAGE FLOW (MGD)	DESIGN FLOW (MGD)	TREATMENT LEVEL	EFFLUENT TYPE
#001	0.074	0.1	Tertiary/Advanced	domestic waste, industrial process water
#002	dependent on precipitation	0.16*	BMPs	stormwater
#003	dependent on precipitation	0.14*	BMPs	stormwater
#004	dependent on precipitation	0.22*	BMPs	stormwater
#005	dependent on precipitation	0.39*	BMPs	stormwater

* Estimated flow in a 10 year, 24 hour rain event, determined using the "rational method". 0.8 was used as the rational co-efficient, rainfall amount was 5.7 inches/24 hours, with area that each outfall drain being interpolated from a map.

FACILITY PERFORMANCE HISTORY & COMMENTS:


The discharge monitoring reports were reviewed for the last five years. There were no DMR violations in the past five years. This facility was last inspected on 4/08/2013. The inspection showed the following unsatisfactory features: Failure to submit a timely renewal application, stormwater outfall locations were not correctly identified (discharge from unpermitted outfalls), outfalls were not clearly marked, allowing process water (wash water) to blend with stormwater and be discharged from a stormwater outfall, the DAF unit was discharging grease which was entering the stormwater stream, and sludge reports were not submitted to the regional office for all years. The facility has since returned to compliance. The outfalls identified by the inspector as unpermitted were marked on a map submitted with the renewal application.

While wastewater operator certification is not required at this site, they currently have a Class B operator operating the water treatment facility. At the time of permit issuance, operator on site was John Burns, Jr., operator certificate number 10330. The well they draw process water from is also used for drinking water at the facility.


MAJOR WATER USER:

Ajinomoto-Windsor foods is a major water user according to the 2014 list. Their Major Water User ID is 66931747. According to the information provided by this list, 61,320,000 gallons of groundwater are used annually by this facility. The water is used for domestic water, drinking water, and industrial process water.

FACILITY MAP:



WATER BALANCE DIAGRAM:



Part II. RECEIVING STREAM INFORMATION

OUTFALL	WATERBODY NAME	CLASS	WBID	DESIGNATED USES*	DISTANCE TO SEGMENT (MILES)	12-DIGIT HUC
#001	Tributary to Center Creek	n/a	n/a	GEN	0.14	11070207-0606 Grove Creek-Center Creek
	Center Creek	P	3203	AQL, GEN, IND, IRR, LWV, SCR, WBC-A, HHP		
#002	Tributary to Center Creek	n/a	n/a	GEN	0.17	
	Center Creek	P	3203	AQL, GEN, IND, IRR, LWV, SCR, WBC-A, HHP		
#003	Tributary to Center Creek	n/a	n/a	GEN	0.13	
	Center Creek	P	3203	AQL, GEN, IND, IRR, LWV, SCR, WBC-A, HHP		
#004	Tributary to Center Creek	n/a	n/a	GEN	0.08	
	Center Creek	P	3203	AQL, GEN, IND, IRR, LWV, SCR, WBC-A, HHP		
#005	Tributary to Center Creek	n/a	n/a	GEN	0.28	
	Center Creek	P	3203	AQL, GEN, IND, IRR, LWV, SCR, WBC-A, HHP		

n/a not applicable

WBID = Waterbody IDentification: Missouri Use Designation Dataset 8-20-13 MUDD V1.0 data can be found as an ArcGIS shapefile on MSDIS at http://msdis.missouri.edu/pub/Inland_Water_Resources/MO_2014_WQS_Stream_Classifications_and_Use_shp.zip

* As per 10 CSR 20-7.031 Missouri Water Quality Standards, the department defines the Clean Water Commission's water quality objectives in terms of "water uses to be maintained and the criteria to protect those uses." The receiving stream and 1st classified receiving stream's beneficial water uses to be maintained are in the receiving stream table in accordance with [10 CSR 20-7.031(1)(C)].

Uses which may be found in the receiving streams table, above:

10 CSR 20-7.031(1)(C)1.:

AQL = Protection of aquatic life (Current narrative use(s) are defined to ensure the protection and propagation of fish shellfish and wildlife, which is further subcategorized as: WWH = Warm Water Habitat; CLH = Cool Water Habitat; CDH = Cold Water Habitat; EAH = Ephemeral Aquatic Habitat; MAH = Modified Aquatic Habitat; LAH = Limited Aquatic Habitat. This permit uses AQL effluent limitations in 10 CSR 20-7.031 Table A for all habitat designations unless otherwise specified.)

10 CSR 20-7.031(1)(C)2.:

Recreation in and on the water
WBC = Whole Body Contact recreation where the entire body is capable of being submerged;
WBC-A = Whole body contact recreation supporting swimming uses and has public access;
WBC-B = Whole body contact recreation supporting swimming;
SCR = Secondary Contact Recreation (like fishing, wading, and boating).

10 CSR 20-7.031(1)(C)3. to 7.:

HHP (formerly HHP) = Human Health Protection as it relates to the consumption of fish;
IRR = Irrigation for use on crops utilized for human or livestock consumption;
LWW = Livestock and wildlife watering (Current narrative use is defined as LWP = Livestock and Wildlife Protection);
DWS = Drinking Water Supply; **IND** = Industrial water supply

10 CSR 20-7.031(1)(C)8-11.:

Wetlands (10 CSR 20-7.031 Table A currently does not have corresponding habitat use criteria for these defined uses)
WSA = Storm- and flood-water storage and attenuation; **WHP** = Habitat for resident and migratory wildlife species;
WRC = Recreational, cultural, educational, scientific, and natural aesthetic values and uses; **WHC** = Hydrologic cycle maintenance.

10 CSR 20-7.031(6): **GRW** = Groundwater

MIXING CONSIDERATIONS:

Mixing zone: not allowed [10 CSR 20-7.031(5)(A)4.B.(I)(a)].

Zone of initial dilution: not allowed [10 CSR 20-7.031(5)(A)4.B.(I)(b)].

RECEIVING STREAM MONITORING REQUIREMENTS:

No receiving water monitoring requirements are recommended at this time.

RECEIVING WATER BODY'S WATER QUALITY:

The receiving stream Tributary to Center Creek has no concurrent water quality data available. Center Creek (3203) is about 60 miles long and has a watershed of about 302 miles. Center Creek is one of two main receiving waters for the Oronogo-Duenweg mining belt. Aquatic life in Center Creek is known to be negatively affected by the mining point source pollution. Center Creek is found on the 2006 303(d) list for Cadmium in both the sediment and water, as well as for lead in the sediment. Ajinomoto-Windsor foods is not expected contribute these pollutants to the watershed. Center Creek (3202) is also associated with a 2006 TMDL for zinc. This facility is specifically mentioned in the TMDL document, and is assigned a wasteload allocation (WLA) for zinc; however, after concurrence from the MDNR TMDL unit, it is in the professional judgment of the permit writer to require monitoring only to evaluate Ajinomoto-Windsor's contribution to the zinc loading in the watershed.

303(D) LIST:

Section 303(d) of the federal Clean Water Act requires each state identify waters not meeting water quality standards and for which adequate water pollution controls have not been required. Water quality standards protect such beneficial uses of water as whole body contact (such as swimming), maintaining fish and other aquatic life, and providing drinking water for people, livestock, and wildlife. The 303(d) list helps state and federal agencies keep track of impaired waters not addressed by normal water pollution control programs. <http://dnr.mo.gov/env/wpp/waterquality/303d/303d.htm>

- ✓ Applicable; Center Creek is listed on the 2006 Missouri 303(d) list for Cadmium in the sediment and water, and lead in the sediment. This facility is not considered a source of the above listed pollutants or considered to contribute to the impairment.

TOTAL MAXIMUM DAILY LOAD (TMDL):

A TMDL is a calculation of the maximum amount of a given pollutant that a body of water can absorb before its water quality is affected; hence, the purpose of a TMDL is to determine the pollutant loading a specific waterbody can assimilate without exceeding water quality standards. If a water body is determined to be impaired as listed on the 303(d) list, then a watershed management plan or TMDL may be developed. The TMDL shall include the WLA calculation. <http://dnr.mo.gov/env/wpp/tmdl/>

- ✓ Applicable; Center Creek is associated with the 2006 EPA approved TMDL for zinc. This facility is considered to be a source of or has the potential to contribute to the above listed pollutant(s). A wasteload allocation of 0.12 lbs/day dissolved zinc, and 0.13 lbs/day total recoverable zinc was assigned to this facility in the TMDL Document; however, after concurrence from the MDNR TMDL unit, it is in the professional judgment of the permit writer to require monitoring only to evaluate Ajinomoto-Windsor's contribution to the zinc loading in the watershed.

APPLICABLE DESIGNATIONS OF WATERS OF THE STATE:

- ✓ As per Missouri's Effluent Regulations [10 CSR 20-7.015(1)(B)], the waters of the state are divided into the following seven categories. Each category lists effluent limitations for specific parameters, which are presented in each outfall's effluent limitation table and further discussed in the derivation & discussion of limits section.

- Missouri or Mississippi River:
- Lake or Reservoir:
- Losing:
- Metropolitan No-Discharge:
- Special Stream:
- Subsurface Water:
- All Other Waters:

Part III. RATIONALE AND DERIVATION OF EFFLUENT LIMITATIONS & PERMIT CONDITIONS

ALTERNATIVE EVALUATIONS FOR NEW FACILITIES:

As per [10 CSR 20-7.015(4)(A)], discharges to losing streams shall be permitted only after other alternatives including land application, discharges to a gaining stream and connection to a regional wastewater treatment facility have been evaluated and determined to be unacceptable for environmental and/or economic reasons.

- ✓ Not applicable; the facility does not discharge to a losing stream as defined by [10 CSR 20-2.010(36)] & [10 CSR 20-7.031(1)(N)].

ANTI-BACKSLIDING:

Federal Regulations [CWA §303(d)(4); CWA §402(c); 40 CFR Part 122.44(I)] require a reissued permit to be as stringent as the previous permit with some exceptions. Backsliding (a less stringent permit limitation) is only allowed under certain conditions.

- ✓ Limitations in this operating permit for the reissuance conform to the anti-backsliding provisions of Section 402(o) of the Clean Water Act, and 40 CFR Part 122.44.
 - ✓ Information is available which was not available at the time of permit issuance which would have justified the application of a less stringent effluent limitation.
 - Five years of DMR data were provided to the permit writer which justified requiring monthly sampling rather than weekly sampling for BOD and TSS on outfall #001.
 - ✓ The Department determined technical mistakes or mistaken interpretations of law were made in issuing the permit under section 402(a)(1)(b).
 - The ammonia values used in the previous permit were split into four seasons. It is the current practice of the Department to split ammonia into two seasons, summer and winter. An RPA was performed on ammonia that justified monitoring only during the winter season.

ANTIDegradation REVIEW:

For process water discharge with new, altered, or expanding discharges, the department is to document, by means of antidegradation review, if the use of a water body's available assimilative capacity is justified. In accordance with Missouri's water quality regulations for antidegradation [10 CSR 20-7.031(3)], degradation may be justified by documenting the socio-economic importance of a discharge after determining the necessity of the discharge. Facilities must submit the antidegradation review request to the department prior to establishing, altering, or expanding discharges. See <http://dnr.mo.gov/env/wpp/permits/antideg-implementation.htm>

✓ Not applicable; the facility has not submitted information proposing expanded or altered process water discharge; no further degradation proposed therefore no further review necessary.

For stormwater discharges with new, altered, or expanding discharges, the stormwater BMP chosen for the facility, through the antidegradation analysis performed by the facility, must be implemented and maintained at the facility. Failure to implement and maintain the chosen BMP alternative is a permit violation; see SWPPP.

✓ Applicable; the facility must review and maintain stormwater BMPs as appropriate.

BENCHMARKS:

When a permitted feature or outfall consists of only stormwater, a benchmark may be implemented at the discretion of the permit writer. Benchmarks require the facility to monitor, and if necessary, replace and update stormwater control measures. Benchmark concentrations are not effluent limitations. A benchmark exceedance, therefore, is not a permit violation; however, failure to take corrective action is a violation of the permit. Benchmark monitoring data is used to determine the overall effectiveness of control measures and to assist the permittee in knowing when additional corrective actions may be necessary to comply with the limitations of the permit.

Because of the fleeting nature of stormwater discharges, the department, under the direction of EPA guidance, has determined monthly averages are capricious measures of stormwater discharges. The *Technical Support Document for Water Quality Based Toxics Control* (EPA/505/2-90-001; 1991) Section 3.1 indicates most procedures within the document apply only to water quality based approaches, not end-of-pipe technology-based controls. Hence, stormwater only outfalls will generally only contain a maximum daily limit (MDL), benchmark, or monitoring requirement determined by the site specific conditions including the receiving water's current quality. While inspections of the stormwater BMPs occur monthly, facilities with no compliance issues are usually expected to sample stormwater quarterly.

Numeric benchmark values are based on water quality standards or other stormwater permits including guidance forming the basis of Environmental Protection Agency's (EPA's) *Multi-Sector General Permit for Stormwater Discharges Associated with Industrial Activity* (MSGP). Because precipitation events are sudden and momentary, benchmarks based on state or federal standards or recommendations use the Criteria Maximum Concentration (CMC) value, or acute standard. The CMC is the estimate of the highest concentration of a material in surface water to which an aquatic community can be exposed briefly without resulting in an unacceptable effect. The CMC for aquatic life is intended to be protective of the vast majority of the aquatic communities in the United States.

✓ Not applicable; this facility does have stormwater outfalls, but all parameters are monitoring only.

BIOSOLIDS & SEWAGE SLUDGE:

Biosolids are solid materials resulting from domestic wastewater treatment meeting federal and state criteria for beneficial use (i.e. fertilizer). Sewage sludge is solid, semi-solid, or liquid residue generated during the treatment of domestic sewage in a treatment works; including but not limited to, domestic septage; scum or solids removed in primary, secondary, or advanced wastewater treatment process; and material derived from sewage sludge. Sewage sludge does not include ash generated during the firing of sewage sludge in a sewage sludge incinerator or grit and screening generated during preliminary treatment of domestic sewage in a treatment works. Additional information: <http://extension.missouri.edu/main/DisplayCategory.aspx?C=74> (WQ422 through WQ449).

✓ Permittee is not authorized to land apply biosolids. Sludge/biosolids are removed by contract hauler.

COMPLIANCE AND ENFORCEMENT:

Enforcement is the action taken by the Water Protection Program (WPP) to bring an entity into compliance with the Missouri Clean Water Law, its implementing regulations, and/or any terms and conditions of an operating permit. The primary purpose of the enforcement activity in the WPP is to resolve violations and return the entity to compliance.

✓ Not applicable; the permittee/facility is not currently under Water Protection Program enforcement action.

GROUNDWATER MONITORING:

Groundwater is a water of the state according to 10 CSR 20-7.015(7) and 10 CSR 20-7.031(6) and must be protected accordingly.

✓ This facility is not required to monitor groundwater for the water protection program.

SANITARY SEWER OVERFLOWS (SSO) AND INFLOW AND INFILTRATION (I&I):

Sanitary Sewer Overflows (SSOs) are defined as untreated sewage releases and are considered bypassing under state regulation [10 CSR 20-2.010(11)] and should not be confused with the federal definition of bypass. SSOs result from a variety of causes including blockages, line breaks, and sewer defects that can either allow wastewater to backup within the collection system during dry weather conditions or allow excess stormwater and groundwater to enter and overload the collection system during wet weather conditions. SSOs can also result from lapses in sewer system operation and maintenance, inadequate sewer design and construction, power failures, and vandalism. SSOs include overflows out of manholes, cleanouts, broken pipes, and other into waters of the state and onto city streets, sidewalks, and other terrestrial locations.

Inflow and Infiltration (I&I) is defined as unwanted intrusion of stormwater or groundwater into a collection system. This can occur from points of direct connection such as sump pumps, roof drain downspouts, foundation drains, and storm drain cross-connections or through cracks, holes, joint failures, faulty line connections, damaged manholes, and other openings in the collection system itself. I&I results from a variety of causes including line breaks, improperly sealed connections, cracks caused by soil erosion/settling, penetration of vegetative roots, and other sewer defects. In addition, excess stormwater and groundwater entering the collection system from line breaks and sewer defects have the potential to negatively impact the treatment facility.

Missouri RSMo §644.026.1.(13) mandates that the Department issue permits for discharges of water contaminants into the waters of this state, and also for the operation of sewer systems. Such permit conditions shall ensure compliance with all requirements as established by sections 644.006 to 644.141. Standard Conditions Part I, referenced in the permit, contains provisions requiring proper operation and maintenance of all facilities and systems of treatment and control. Missouri RSMo §644.026.1.(15) instructs the Department to require proper maintenance and operation of treatment facilities and sewer systems and proper disposal of residual waste from all such facilities. To ensure that public health and the environment are protected, any noncompliance which may endanger public health or the environment must be reported to the Department within 24 hours of the time the permittee becomes aware of the noncompliance. Standard Conditions Part I, referenced in the permit, contains the reporting requirements for the permittee when bypasses and upsets occur.

- ✓ This facility is not required to develop or implement a program for maintenance and repair of the collection system; however, it is a violation of Missouri State Environmental Laws and Regulations to allow untreated wastewater to discharge to waters of the state.

INDUSTRIAL SLUDGE:

Industrial sludge is solid, semi-solid, or liquid residue generated during the treatment of industrial process wastewater in a treatment works; including but not limited to, scum or solids removed in primary, secondary, or advanced wastewater treatment process; scum and solids filtered from water supplies and backwashed; and a material derived from industrial sludge.

- ✓ Permittee is not authorized to land apply industrial sludge. Permittee currently has industrial sludge collected by a permitted contract hauler and land applied off site. Permittee should notify MDNR if contract hauler changes, or if alternate treatment methods being evaluated for utilization.

REASONABLE POTENTIAL ANALYSIS (RPA):

Federal regulation [40 CFR Part 122.44(d)(1)(i)] requires effluent limitations for all pollutants that are (or may be) discharged at a level causing or have the reasonable potential to cause (or contribute to) an in-stream excursion above narrative or numeric water quality standards. If the permit writer determines any give pollutant has the reasonable potential to cause or contribute to an in-stream excursion above the WQS, the permit must contain effluent limits for that pollutant [40 CFR Part 122.44(d)(1)(iii)].

- ✓ Applicable; an RPA was conducted on appropriate parameters and was conducted as per (TSD, EPA/505/2-90-001, Section 3.3.2). A more detailed version including calculations of this RPA is available upon request. Please see **PART V. EFFLUENT LIMITS DERIVATION** for more information.

SCHEDULE OF COMPLIANCE (SOC):

A schedule of remedial measures included in a permit, including an enforceable sequence of interim requirements (actions, effluent limits, operations, or milestone events) leading to compliance with the Missouri Clean Water Law, its implementing regulations, and/or the terms and conditions of an operating permit. SOC's are allowed under 40 CFR 122.47 providing certain conditions are met.

- ✓ Applicable; the time given for effluent limitations of this permit listed under Interim Effluent Limitation and Final Effluent Limitations were established in accordance with [10 CSR 20-7.031(12)]. The facility has been given a three year schedule of compliance to meet final effluent limits for E. coli at outfall #001; and COD, Oil and Grease, and pH at outfall #002-#005. Three years will allow the permittee to assess the impact of new limits on their facility. In addition, sampling was not previously done on stormwater outfalls #002-#005. Three years will allow the facility to adjust BMPs as necessary to achieve the limits in this permit.

SPILL REPORTING:

Per 10 CSR 24-3.010, any emergency involving a hazardous substance must be reported to the department's 24 hour Environmental Emergency Response hotline at (573) 634-2436 at the earliest practicable moment after discovery. The department may require the submittal of a written report detailing measures taken to clean up a spill. These reporting requirements apply whether or not the spill results in chemicals or materials leaving the permitted property or reaching waters of the state. This requirement is in addition to the noncompliance reporting requirement found in Standard Conditions Part I. <http://dnr.mo.gov/env/esp/spillbill.htm>

STORMWATER PERMITTING:

A standard mass-balance equation cannot be calculated for stormwater from this facility because the stormwater flow and flow in the receiving stream cannot be determined for conditions on any given day. The amount of stormwater discharged from the facility will vary based on previous rainfall, soil saturation, humidity, detention time, BMPs, surface permeability, etc. Flow in the receiving stream will vary based on climatic conditions, size of watershed, amount of surfaces with reduced permeability (houses, parking lots, and the like) in the watershed, hydrogeology, topography, etc. Decreased permeability increases the flash of the stream.

It is likely sufficient rainfall to cause a discharge for four continuous days from a facility will also cause some significant amount of flow in the receiving stream. Chronic WQSs are based on a four-day exposure (except ammonia, which is based on a thirty day exposure). In the event a discharge does occur from this facility for four continuous days, some amount of flow will occur in the receiving stream. This flow will dilute stormwater discharges from a facility. For these reasons, most industrial stormwater facilities have limited potential to cause a violation of chronic water quality standards in the receiving stream.

Sufficient rainfall to cause a discharge for one hour or more from a facility would not necessarily cause significant flow in a receiving stream. Acute WQSs are based on a one hour of exposure, and must be protected at all times in unclassified streams, and within mixing zones of class P streams [10 CSR 20-7.031(4) and (5)(4)4.B.]. Therefore, industrial stormwater facilities with toxic contaminants do have the potential to cause a violation of acute WQSs if those toxic contaminants occur in sufficient amounts.

It is due to the items stated above staff drafting this fact sheet are unable to perform statistical Reasonable Potential Analysis (RPA) and calculate Wasteload Allocations (WLA) via a site-specific mass-balance equation for effluent limit determination on stormwater outfalls. However, staff will use their best professional judgment in determining if a facility has a potential to violate Missouri's Water Quality Standards.

STORMWATER POLLUTION PREVENTION PLAN (SWPPP):

In accordance with 40 CFR 122.44(k), Best Management Practices (BMPs) must be used to control or abate the discharge of pollutants when: 1) Authorized under section 304(e) of the Clean Water Act (CWA) for the control of toxic pollutants and hazardous substances from ancillary industrial activities; 2) Authorized under section 402(p) of the CWA for the control of stormwater discharges; 3) Numeric effluent limitations are infeasible; or 4) the practices are reasonably necessary to achieve effluent limitations and standards or to carry out the purposes and intent of the CWA. In accordance with the EPA's *Developing Your Stormwater Pollution Prevention Plan, A Guide for Industrial Operators*, (Document number EPA 833-B-09-002) [published by the United States Environmental Protection Agency (USEPA) in February 2009], BMPs are measures or practices used to reduce the amount of pollution entering waters of the state from a permitted facility. BMPs may take the form of a process, activity, or physical structure. Additionally in accordance with the Stormwater Management, a SWPPP is a series of steps and activities to 1) identify sources of pollution or contamination, and 2) select and carry out actions which prevent or control the pollution of storm water discharges.

A SWPPP must be prepared by the permittee if the SIC code is found in 40 CFR 122.26(b)(14) and/or 10 CSR 20-6.200(2). A SWPPP may be required of other facilities where stormwater has been identified as necessitating better management. The purpose of a SWPPP is to comply with all applicable stormwater regulations by creating an adaptive management plan to control and mitigate stream pollution from stormwater runoff. Developing a SWPPP provides opportunities to employ appropriate BMPs to minimize the risk of pollutants being discharged during storm events. The following paragraph outlines the general steps the permittee should take to determine which BMPs will work to achieve the benchmark values or limits in the permit. This section is not intended to be all encompassing or restrict the use of any physical BMP or operational and maintenance procedure assisting in pollution control. Additional steps or revisions to the SWPPP may be required to meet the requirements of the permit.

Areas which should be included in the SWPPP are identified in 40 CFR 122.26(b)(14). Once the potential sources of stormwater pollution have been identified, a plan should be formulated to best control the amount of pollutant being released and discharged by each activity or source. This should include, but is not limited to, minimizing exposure to stormwater, good housekeeping measures, proper facility and equipment maintenance, spill prevention and response, vehicle traffic control, and proper materials handling. Once a plan has been developed the facility will employ the control measures determined to be adequate to achieve the benchmark values discussed above. The facility will conduct monitoring and inspections of the BMPs to ensure they are working properly and re-evaluate any BMP not achieving compliance with permitting requirements. For example, if sample results from an outfall show values of TSS above the benchmark value, the BMP being employed is deficient in controlling stormwater pollution. Corrective action should be taken to repair, improve, or replace the failing BMP. This internal evaluation is required at least once per month but should

be continued more frequently if BMPs continue to fail. If failures do occur, continue this trial and error process until appropriate BMPs have been established.

For new, altered, or expanded stormwater discharges, the SWPPP shall identify reasonable and effective BMPs while accounting for environmental impacts of varying control methods. The antidegradation analysis must document why no discharge or no exposure options are not feasible. The selection and documentation of appropriate control measures shall serve as an alternative analysis of technology and fulfill the requirements of antidegradation [10 CSR 20-7.031(3)]. Failure to implement and maintain the chosen BMP is a permit violation. For further guidance, consult the antidegradation implementation procedure (<http://dnr.mo.gov/env/wpp/docs/AIP050212.pdf>).

Alternative Analysis (AA) evaluation of the BMPs is a structured evaluation of BMPs that are reasonable and cost effective. The AA evaluation should include practices that are designed to be: 1) non-degrading; 2) less degrading; or 3) degrading water quality. The glossary of AIP defines these three terms. The chosen BMP will be the most reasonable and effective management strategy while ensuring the highest statutory and regulatory requirements are achieved and the highest quality water attainable for the facility is discharged. The AA evaluation must demonstrate why “no discharge” or “no exposure” is not a feasible alternative at the facility. This structured analysis of BMPs serves as the antidegradation review, fulfilling the requirements of 10 CSR 20-7.031(3) Water Quality Standards and *Antidegradation Implementation Procedure* (AIP), Section II.B.

If parameter-specific numeric exceedances continue to occur and the permittee feels there are no practicable or cost-effective BMPs which will sufficiently reduce a pollutant concentration in the discharge to the benchmark values established in the permit, the permittee can submit a request to re-evaluate the benchmark values. This request needs to include 1) a detailed explanation of why the facility is unable to comply with the permit conditions and unable to establish BMPs to achieve the benchmark values; 2) financial data of the company and documentation of cost associated with BMPs for review and 3) the SWPPP, which should contain adequate documentation of BMPs employed, failed BMPs, corrective actions, and all other required information. This will allow the department to conduct a cost analysis on control measures and actions taken by the facility to determine cost-effectiveness of BMPs. The request shall be submitted in the form of an operating permit modification; the application is found at: <http://dnr.mo.gov/forms/index.html>.
 ✓ Applicable; a SWPPP shall be developed and implemented for this facility.

VARIANCE:

As per the Missouri Clean Water Law § 644.061.4, variances shall be granted for such period of time and under such terms and conditions as shall be specified by the commission in its order. The variance may be extended by affirmative action of the commission. In no event shall the variance be granted for a period of time greater than is reasonably necessary for complying with the Missouri Clean Water Law §§644.006 to 644.141 or any standard, rule or regulation promulgated pursuant to Missouri Clean Water Law §§644.006 to 644.141.

✓ Not applicable; the operating permit is not drafted under premise of a petition for variance.

WASTELOAD ALLOCATIONS (WLA) FOR LIMITS:

As per [10 CSR 20-2.010(78)], the WLA is the amount of pollutant each discharger is allowed to discharge into the receiving stream without endangering water quality. Two general types of effluent limitations, technology-based effluent limits (TBELs) and water quality based effluent limits (WQBELs) are reviewed. If one limit does provide adequate protection for the receiving waters, then the other must be used.

✓ Applicable; wasteload allocations were calculated where relevant using water quality criteria or water quality model results and by applying the dilution equation below:

$$C = \frac{(C_s \times Q_s) + (C_e \times Q_e)}{(Q_e + Q_s)} \quad \text{(EPA/505/2-90-001, Section 4.5.5)}$$

Where C = downstream concentration C_s = upstream concentration
 Q_s = upstream flow C_e = effluent concentration
 Q_e = effluent flow

- Acute wasteload allocations (daily maximum limits; MDL) were determined using applicable water quality criteria (CMC: criteria maximum concentration) and stream volume of flow at the edge of the zone of initial dilution (ZID).
- Chronic wasteload allocations (monthly average limits; AML) were determined using applicable chronic water quality criteria (CCC: criteria continuous concentration) and stream volume of flow at the edge of the mixing zone (MZ).
- Water quality based maximum daily and average monthly effluent limitations were calculated using methods and procedures outlined in USEPA’s *Technical Support Document For Water Quality-based Toxics Control* or TSD EPA/505/2-90-001; March 1991.

- Number of Samples “n”: In accordance with the TSD for water quality-based permitting, effluent quality is determined by the underlying distribution of daily values, which is determined by the Long Term Average (LTA) associated with a particular Wasteload Allocation (WLA) and by the Coefficient of Variation (CV) of the effluent concentrations. Increasing or decreasing the monitoring frequency does not affect this underlying distribution or treatment performance which should be, at a minimum, targeted to comply with the values dictated by the WLA. Therefore, it is recommended the actual planned frequency of monitoring normally be used to determine the value of “n” for calculating the AML. However, in situations where monitoring frequency is once per month or less, a higher value for “n” must be assumed for AML derivation purposes. Thus, the statistical procedure being employed using an assumed number of samples is “n = 4” at a minimum. For total ammonia as nitrogen, “n = 30” is used.

WLA MODELING:

Permittees may submit site specific studies to better determine the site specific wasteload allocations applied in permits.

- ✓ Not applicable; a WLA study was either not submitted or determined not applicable by department staff.

WATER QUALITY STANDARDS:

Per 10 CSR 20-7.031(4), general criteria shall be applicable to all waters of the state at all times including mixing zones. Additionally, 40 CFR 122.44(d)(1) directs the department to establish in each NPDES permit to include conditions to achieve water quality established under Section 303 of the Clean Water Act, including state narrative criteria for water quality.

WHOLE EFFLUENT TOXICITY (WET) TEST:

A WET test is a quantifiable method of determining if a discharge from a facility may be causing toxicity to aquatic life by itself, in combination with, or through synergistic responses when mixed with receiving stream water. Under the federal Clean Water Act (CWA) §101(a)(3), requiring WET testing is reasonably appropriate for site-specific Missouri State Operating Permits for discharges to waters of the state issued under the National Pollutant Discharge Elimination System (NPDES). WET testing is also required by 40 CFR 122.44(d)(1). WET testing ensures the provisions in 10 CSR 20-6 and the Water Quality Standards in 10 CSR 20-7 are being met. Under 10 CSR 20-6.010(8)(A)4, the department may require other terms and conditions it deems necessary to assure compliance with the CWA and related regulations of the Missouri Clean Water Commission. The following Missouri Clean Water Laws (MCWL) apply: §644.051.3. requires the department to set permit conditions complying with the MCWL and CWA; §644.051.4 specifically references toxicity as an item we must consider in writing permits (along with water quality-based effluent limits); and §644.051.5. is the basic authority to require testing conditions.

- ✓ Not applicable; at this time, the permittee is not required to conduct WET testing for this facility. WET tests are tools to determine if waste streams that could potentially contain unidentified toxic pollutants are actually toxic to aquatic life. These tests are typically associated with Publically Owned Treatment Works (POTWs) or municipal wastewater treatment facilities. The public wastewater treatment systems collect wastewater from many different sources, including private residences and industries that can generate a wide variety of pollutants. In these cases, WET test can help identify toxicity in the final wastewater discharge stream. If toxicity occurs, then the facility will conduct further investigations to identify the specific pollutant or pollutants contributing to the toxicity and eventually identify the source. Then the facility could potentially require pretreatment from the industry or add additional treatment to reduce the level of pollutants in the waste stream. In the case of Ajinomoto-Windsor Foods, the pollutants of concern have already been identified as being domestic waste and process water from frozen food production. The industrial process is consistent throughout the year. The facility passed the required WET test during the previous permit cycle. Based on this information, the permit writer feels that WET testing is not necessary at this time.

Part IV. 2013 WATER QUALITY CRITERIA FOR AMMONIA

Upcoming changes to the Water Quality Standard for ammonia may require significant upgrades to wastewater treatment facilities.

On August 22, 2013, the U.S. Environmental Protection Agency (EPA) finalized new water quality criteria for ammonia, based on toxicity studies of mussels and gill breathing snails. Missouri’s current ammonia criteria are based on toxicity testing of several species, but did not include data from mussels or gill breathing snails. Missouri is home to 69 of North America’s mussel species, which are spread across the state. According to the Missouri Department of Conservation nearly two-thirds of the mussel species in Missouri are considered to be “of conservation concern”. Nine species are listed as federally endangered, with an additional species currently proposed as endangered and another species proposed as threatened.

The adult forms of mussels that are seen in rivers, lakes, and streams are sensitive to pollutants because they are sedentary filter feeders. They vacuum up many pollutants with the food they bring in and cannot escape to new habitats, so they can accumulate toxins in their bodies and die. But very young mussels, called glochidia, are exceptionally sensitive to ammonia in water. As a result of a citizen suit, the EPA was compelled to conduct toxicity testing and develop ammonia water quality criteria that would be protective if young mussels may be present in a waterbody. These new criteria will apply to any discharge with ammonia levels that may pose a reasonable potential to violate the standards. Nearly all discharging domestic wastewater treatment facilities (cities, subdivisions, mobile home parks, etc.), as well as certain industrial and stormwater dischargers with ammonia in their effluent, will be affected by this change in the regulations.

When new water quality criteria are established by the EPA, states must adopt them into their regulations in order to keep their authorization to issue permits under the National Pollutant Discharge Elimination System (NPDES). States are required to review their water quality standards every three years, and if new criteria have been developed they must be adopted. States may be more protective than the Federal requirements, but not less protective. Missouri does not have the resources to conduct the studies necessary for developing new water quality standards, and therefore our standards mirror those developed by the EPA; however, we will utilize any available flexibility based on actual species of mussels that are native to Missouri and their sensitivity to ammonia. Many treatment facilities in Missouri are currently scheduled to be upgraded to comply with the current water quality standards. But these new ammonia standards may require a different treatment technology than the one being considered by the permittee. It is important that permittees discuss any new and upcoming requirements with their consulting engineers to ensure that their treatment systems are capable of complying with the new requirements. The Department encourages permittees to construct treatment technologies that can attain effluent quality that supports the EPA ammonia criteria.

Ammonia toxicity varies by temperature and by pH of the water. Assuming a stable pH value, but taking into account winter and summer temperatures, Missouri includes two seasons of ammonia effluent limitations. Current effluent limitations in this permit are:

Summer – 6.0 mg/L daily maximum, 1.2 mg/L monthly average.

Winter – Monitoring only

Under the new EPA criteria, where mussels of the family Unionidae are present or expected to be present, the estimated effluent limitations for a facility in a location such as this that discharges to a receiving stream with no mixing will be:

Summer – 1.7 mg/L daily maximum, 0.6 mg/L monthly average.

Winter – 5.6 mg/L daily maximum, 2.1 mg/L monthly average.

Actual effluent limits will depend in part on the actual performance of the facility.

Operating permits for facilities in Missouri must be written based on current statutes and regulations. Therefore permits will be written with the existing effluent limitations until the new standards are adopted. To aid permittees in decision making, an advisory will be added to permit Fact Sheets notifying permittees of the expected effluent limitations for ammonia. When setting schedules of compliance for ammonia effluent limitations, consideration will be given to facilities that have recently constructed upgraded facilities to meet the current ammonia limitations. For more information on this topic feel free to contact the Missouri Department of Natural Resources, Water Protection Program, Water Pollution Control Branch, Operating Permits Section at (573) 751-1300.

Part V. EFFLUENT LIMITS DETERMINATION

OUTFALL #001 – PROCESS WASTEWATER/DOMESTIC WASTEWATER OUTFALL

Effluent limitations derived and established in the below effluent limitations table are based on current operations of the facility. Effluent means both process water and stormwater. Any flow through the outfall is considered a discharge and must be sampled and reported as provided below. Future permit action due to facility modification may contain new operating permit terms and conditions that supersede the terms and conditions, including effluent limitations, of this operating permit. Daily maximums and monthly averages are required under 40 CFR 122.45(d)(1) for continuous discharges not from a POTW.

EFFLUENT LIMITATIONS TABLE:

PARAMETERS OUTFALL #001	UNIT	BASIS FOR LIMITS	DAILY MAX	MONTHLY AVG	PREVIOUS PERMIT LIMITS	MINIMUM SAMPLING FREQUENCY	MINIMUM REPORTING FREQUENCY	SAMPLE TYPE
PHYSICAL								
FLOW	MGD	1	*	*	SAME	ONCE/MONTH	ONCE/MONTH	24 Hr. TOT
TEMPERATURE	REMOVED FROM THIS PERMIT							
CONVENTIONAL								
BOD ₅	MG/L	6	45	30	45 WKLY	ONCE/MONTH	ONCE/MONTH	COMPOSITE
CHLORINE, TOTAL RESIDUAL	µg/L	1	*	*	NEW	ONCE/MONTH	ONCE/MONTH	GRAB
CYANIDE, AMENABLE TO CHLORINATION	µg/L	1	*	*	NEW	ONCE/MONTH	ONCE/MONTH	GRAB
E. COLI***	#/100 mL	1,6	630	126	NEW	ONCE/MONTH	ONCE/MONTH	GRAB
FECAL COLIFORM	REMOVED FROM PERMIT							
OIL & GREASE	MG/L	1, 3	15	10	SAME	ONCE/MONTH	ONCE/MONTH	GRAB
OXYGEN, DISSOLVED (DO) **	MG/L	6	*	*	SAME	ONCE/MONTH	ONCE/MONTH	GRAB
pH †	SU	1, 3	6.5 TO 9.0	6.5 TO 9.0	SAME	ONCE/MONTH	ONCE/MONTH	GRAB
TSS	MG/L	6	45	30	45 WKLY	ONCE/MONTH	ONCE/MONTH	COMPOSITE
METALS								
ALUMINUM, TOTAL RECOV.	µg/L	6	*	*	NEW	ONCE/MONTH	ONCE/MONTH	GRAB
TMDL METAL								
ZINC, TOTAL RECOVERABLE	µg/L	7	*	*	NEW	ONCE/MONTH	ONCE/MONTH	GRAB
NUTRIENTS								
AMMONIA AS N (APR 1 – SEPT 30)	MG/L	2, 3, 5	6.0	1.2	MULTIPLE	ONCE/MONTH	ONCE/MONTH	GRAB
AMMONIA AS N (OCT 1 – MARCH 31)	MG/L	2, 3, 5	*	*	MULTIPLE	ONCE/MONTH	ONCE/MONTH	GRAB
NITROGEN, TOTAL N (TN)	MG/L	1	*	*	NEW	ONCE/MONTH	ONCE/MONTH	GRAB
PHOSPHORUS, TOTAL P (TP)	MG/L	1	*	*	NEW	ONCE/MONTH	ONCE/MONTH	GRAB
OTHER								
CHLORIDE + SULFATE	mg/L	6	*	*	NEW	ONCE/MONTH	ONCE/MONTH	GRAB

* - Monitoring requirement only

** - For DO the Daily Maximum is a Daily Minimum and the Monthly Average is a Monthly Average Minimum

***- Final limitations and monitoring requirements for *E. coli* are applicable only during the recreational season from April 1 through October 31. The Monthly Average Limit for *E. coli* is expressed as a geometric mean.

† The facility will report the minimum and maximum pH values; pH is not to be averaged.

NEW - Parameter not previously established in previous state operating permit.

Basis for Limitations Codes:

- | | |
|--|-----------------------------------|
| 1. State or Federal Regulation/Law | 5. Water Quality Model |
| 2. Water Quality Standard (includes RPA) | 6. Best Professional Judgment |
| 3. Water Quality Based Effluent Limits | 7. TMDL or Permit in lieu of TMDL |
| 4. Antidegradation Review/Policy | 8. WET Test Policy |

DERIVATION AND DISCUSSION OF LIMITS:

PHYSICAL:

Flow

In accordance with [40 CFR Part 122.44(i)(1)(ii)] the volume of effluent discharged from each outfall is needed to assure compliance with permitted effluent limitations. If the permittee is unable to obtain effluent flow, then it is the responsibility of the permittee to inform the department, which may require the submittal of an operating permit modification. The facility will report the total flow in millions of gallons per day (MGD).

Temperature

Removed from this permit. It is not necessary to monitor temperature from lagoon structures, which are affected by outdoor ambient temperature.

CONVENTIONAL:

Biochemical Oxygen Demand (BOD₅)

45 mg/L daily maximum limit, 30 mg/L average monthly limit. The previous permit required a weekly average limit of 45 mg/L and a monthly average limit of 30 mg/L. The facility met those limits in the previous permit cycle. There are no water quality criteria for BOD₅. BOD₅ measures the amount of oxygen consumed by microbial oxidation, and is a pollutant of concern for facilities that discharge domestic waste. The previous permit required weekly sampling of this parameter due to the domestic waste component of the discharge; however, it is in the professional judgment of the permit writer that weekly sampling is unnecessary due to the consistent nature of the discharge after blending with wastewater from the industrial process and treatment at the onsite wastewater treatment facility.

Chlorine, Total Residual (TRC)

Monitoring only. This is a new parameter for this permit. This facility chlorinates groundwater for use in their industrial process and domestic water system. Chlorine is extremely toxic to aquatic organisms; therefore, it is important to monitor chlorine discharge from this outfall. TRC is associated with a minimum quantification level (ML). The Department has determined the current acceptable ML for total residual chlorine to be 130 µg/L when using the DPD Colorimetric Method #4500 – CL G. from Standard Methods for the Examination of Waters and Wastewater. The permittee will conduct analyses in accordance with this method, or equivalent, and report actual analytical values. Measured values greater than or equal to the minimum quantification level of 130 µg/L will be considered exceedances of the criteria found in 10 CSR 20-7.031 Table A. Values less than the minimum quantification level of 130 µg/L will be considered to be in compliance with 10 CSR 20-7.031 Table A. The minimum quantification level does not authorize the discharge of chlorine in excess of the effluent limits stated in 10 CSR 20-7.031 Table A.

Cyanide Amenable to Chlorination (CATC)

Monitoring only. This is a new parameter for this permit. Cyanide is a byproduct of chlorination, and can be toxic to aquatic life and human health. The department has determined the current acceptable minimum level (ML) of cyanide amenable to chlorination to be 10 µg/L when using Method #9102A from the U.S. EPA National Exposure Research Laboratory. This method is used to determine the concentration of inorganic cyanide that is present as either soluble salts or complexes in wastes or leachate. The permittee will conduct analyses in accordance with this method, or equivalent, and report actual analytical values. The minimum quantification level does not authorize the discharge of cyanide in excess of the effluent limits stated in 10 CSR 20-7.031 Table A.

Escherichia coli (E. coli)

A daily maximum of 630 bacteria per 100 mL and a monthly geometric mean of 126 bacteria per 100 mL –only during the recreational season (April 1 through October 31), to protect the Whole Body Contact (A) designated use of the first classified receiving stream, as per 10 CSR 20-7.031(5)(C). An effluent limit for both monthly average and daily maximum is required by 40 CFR 122.45(d). The geometric mean is calculated by multiplying all of the data points and then taking the nth root of this product, where n = # of samples collected. For example: Five *E. coli* samples were collected with results of 1, 4, 5, 6, and 10 (#/100 mL). Geometric mean = 5th root of (1)(4)(5)(6)(10) = 5th root of 1,200 = 4.1 #/100 mL. Additionally, Center Creek is on the 2014 303(d) list for *E. coli*, meaning protections are necessary to restore the impaired use designations.

Fecal Coliform

This parameter will be removed from this permit. The limits for this parameter will be replaced with *E. coli* limits.

Oil & Grease

Daily maximum of 15 mg/L, with a monthly average limit of 10 mg/L, continued from the previous permit. Five years of DMR data showed consistently low levels for this parameter when compared to the 10 mg/L standard. Oil and grease is considered a conventional pollutant. Oil and grease is a comprehensive test which measures for gasoline, diesel, crude oil, creosote, kerosene, heating oils, heavy fuel oils, lubricating oils, waxes, and some asphalt and pitch. The test can also detect some volatile organics such as benzene, toluene, ethylbenzene, or toluene, but these constituents are often lost during testing due to their boiling points. It is recommended to perform separate testing for these constituents if they are a known pollutant of concern at the site, i.e. aquatic life toxicity or human health is a concern. Results do not allow for separation of specific pollutants within the test, they are reported, totaled, as “Oil and grease”. Per 10 CSR 20-7.031 Table A: *Criteria for Designated Uses*; 10 mg/L is the monthly value for protection of aquatic life for this parameter. This is multiplied by 1.5 to get the daily maximum of 15 mg/L. 10 mg/L is the level at which sheen is expected to form on receiving waters. Oils and greases of different densities will possibly form sheen or unsightly bottom deposits at levels which vary from 10 mg/L. To protect the general criteria found at 10 CSR 20: 7.031 (4), it is the responsibility of the permittee to visually observe the discharge and receiving waters for sheen or bottom deposits.

Oxygen, Dissolved (DO)

Monitoring requirement only. This is continued from the previous permit. Monitoring for dissolved oxygen is continued to determine whether reasonable potential exists to exceed water quality standards. Lowered DO can be a consequence of chlorination. There were no levels below 5 mg/L in the previous permit cycle.

pH

6.5 to 9.0 SU. The Water Quality Standard at 10 CSR 20-7.031(5)(E) states water contaminants shall not cause pH to be outside the range of 6.5 to 9.0 standard pH units. This is continued from the previous permit.

Total Suspended Solids (TSS)

45 mg/L daily maximum, 30 mg/L monthly average. Previous permit required a weekly average of 45 mg/L and a monthly average if 30 mg/L. The values reported in the past five years of DMR data are consistently below these limits. There are no water quality standards for TSS; however, sediment discharges can negatively impact aquatic life habitat. TSS is also a valuable indicator parameter. TSS monitoring allows the permittee to identify increases in TSS that may indicate uncontrolled materials leaving the site. The previous permit required weekly sampling of this parameter due to the domestic waste component of the discharge; however, it is in the professional judgment of the permit writer that weekly sampling is unnecessary due to the consistent nature of the discharge after blending with wastewater from the industrial process and treatment at the onsite wastewater treatment facility.

METALS AND TMDL RELATED METALS:

Aluminum, Total Recoverable

Monitoring requirement only; this facility uses chemicals for flocculation that contain aluminum. Monitoring is required to determine if reasonable potential exists for this facility’s discharge to exceed water quality standards for Aluminum (Total Recoverable). Water quality standards are used, in this case, to judge toxicity to aquatic life in the receiving tributary. The general criteria found at 10 CSR 20-7.031 (4)(D) state, “Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal, or aquatic life.” General criteria are applicable to all waters of the state at all times.

Zinc, Total Recoverable

Monitoring only. This facility is subject to the wasteload allocation found in the 2006 TMDL for zinc applicable to the Center Creek watershed. The TMDL refers to this facility by its previous name, Specialty Brands; however, the permit number for this facility is the same. A wasteload allocation of 0.12 lbs/day dissolved zinc, and 0.13 lbs/day total recoverable zinc was assigned to this facility in the TMDL Document; however, after concurrence from the MDNR TMDL unit, it is in the professional judgment of the permit writer to require monitoring only to evaluate Ajinomoto-Windsor’s contribution to the zinc loading in the watershed.

NUTRIENTS:

Ammonia, Total as Nitrogen

Early Life Stages Present Total Ammonia Nitrogen criteria apply [10 CSR 20-7.031(4)(B)7.C. & Table B3] default pH 7.8 SU No mixing considerations allowed; therefore, WLA = appropriate criterion. A schedule of compliance will not be needed for this parameter as it is in the professional judgment of the permit writer the facility is capable of meeting these limits as stated.

Season	Temp (°C)	pH (SU)	Ammonia Nitrogen Chronic WLA(mg/L)	Ammonia Nitrogen Acute WLA (mg/L)	Daily Maximum limits (mg/L)	Monthly Average limits (mg/L)
Summer	26	7.8	1.5	12.1	6.0	1.2
Winter	6	7.8	3.1	12.1	*	*

Summer: April 1 – September 30

Acute WLA: $C_e = ((0.155 + 0.0)12.1 - (0.0 * 0.01))/0.155$

$C_e = 12.1 \text{ mg/L}$

Chronic WLA: $C_e = ((0.155 + 0.0)1.5 - (0.0 * 0.01))/0.155$

$C_e = 1.5 \text{ mg/L}$

$LTA_a = 12.1 \text{ mg/L} (0.122) = 1.4762 \text{ mg/L} = 1.48 \text{ mg/L}$

[CV = 1.873551, 99th Percentile]

$LTA_c = 1.5 \text{ mg/L} (0.488) = \mathbf{0.732 \text{ mg/L}}$

[CV = 1.873551, 99th Percentile, 30 day avg.]

Use most protective number of LTA_a or LTA_c .

$MDL = 0.732 \text{ mg/L} (8.18) = 5.988 = \mathbf{6.0 \text{ mg/L}}$

[CV = 1.873551, 99th Percentile]

$AML = 0.732 \text{ mg/L} (1.64) = 1.20 = \mathbf{1.2 \text{ mg/L}}$

[CV = 1.873551, 95th Percentile, n = 30]

Winter: October 1 – March 31

Monitoring only. The RPA for this parameter showed no reasonable potential to exceed current water quality standards during the winter months; therefore, monitoring only will be required in the next permit cycle.

Ammonia RPA results

SEASON	CMC	RWC ACUTE	CCC	RWC CHRONIC	N	RANGE MAX/MIN	CV	MF	RP	RP ACUTE	RP CHRONIC
Summer	12.1	6.77	1.5	6.77	30	1.449/0.03	1.87	4.67	YES	NO	YES
Winter	12.1	2.12	3.1	2.12	31	0.695/0.03	1.12	3.04	NO	NO	NO

Nitrogen, Total N (TN)

Per 10 CSR 20-7.015(9)(D)7, nutrient monitoring shall be instituted on a quarterly basis for facilities with a design flow greater than 0.1 MGD.

Phosphorous, Total P (TN)

Per 10 CSR 20-7.015(9)(D)7, nutrient monitoring shall be instituted on a quarterly basis for facilities with a design flow greater than 0.1 MGD.

OTHER:

Chloride + Sulfate

Monitoring only. This is a new parameter for this permit. This facility softens water, which involves the addition of salts. This facility also utilizes chemical coagulation/flocculation, which involves the addition of sulfates to the water. Chloride + Sulfate has a state water quality standard of 1000 mg/L. This parameter is included per the permit writer’s professional judgment, to ascertain the facility’s potential to exceed water quality standards.

OUTFALL #002-005 –STORMWATER OUTFALLS

Outfalls #002-#005 did not have monitoring included in the previous permit cycle. All parameters on these outfalls are new. Effluent limitations derived and established in the below effluent limitations table are based on current operations of the facility. Effluent means both process water and stormwater. Any flow through the outfall is considered a discharge and must be sampled and reported as provided below. Future permit action due to facility modification may contain new operating permit terms and conditions that supersede the terms and conditions, including effluent limitations, of this operating permit.

EFFLUENT LIMITATIONS TABLE:

PARAMETERS OUTFALLS #002-#005	UNIT	BASIS	DAILY MAXIMUM LIMIT	BENCH-MARK	PREVIOUS PERMIT LIMITS	MINIMUM SAMPLING FREQUENCY	MINIMUM REPORTING FREQUENCY	SAMPLE TYPE
PHYSICAL								
FLOW	MGD	1	*	-	NEW	ONCE/QUARTER	ONCE/QUARTER	24 HR. ESTIMATE
PRECIPITATION	INCHES	6	*	-	NEW	ONCE/QUARTER	ONCE/QUARTER	24 HR. TOT
CONVENTIONAL								
COD	MG/L	6	90	-	NEW	ONCE/QUARTER	ONCE/QUARTER	GRAB
OIL & GREASE	MG/L	1, 3	15	-	NEW	ONCE/QUARTER	ONCE/QUARTER	GRAB
pH †	SU	1, 3	6.5 TO 9.0	-	NEW	ONCE/QUARTER	ONCE/QUARTER	GRAB
TSS	MG/L	6	**	100	NEW	ONCE/QUARTER	ONCE/QUARTER	GRAB
TMDL METAL								
ZINC, TOTAL RECOVERABLE	µg/L	6, 7	*	-	NEW	ONCE/QUARTER	ONCE/QUARTER	GRAB
OTHER								
<i>E. COLI</i> ***	#/100 mL	6	*	-	NEW	ONCE/MONTH	ONCE/MONTH	GRAB

* - Monitoring requirement only

** - Monitoring with associated benchmark

*** - Final limitations and monitoring requirements for *E. coli* are applicable only during the recreational season from April 1 through October 31. The Monthly Average Limit for *E. coli* is expressed as a seasonal geometric mean.

† The facility will report the minimum and maximum pH values; pH is not to be averaged

NEW = Parameter not established in previous operating permit

Basis for Limitations Codes:

- | | | |
|--|-----------------------------------|--|
| 1. State or Federal Regulation/Law | 5. Water Quality Model | 9. Benchmark based on Missouri Water Quality Standards |
| 2. Water Quality Standard (includes RPA) | 6. Best Professional Judgment | |
| 3. Water Quality Based Effluent Limits | 7. TMDL or Permit in lieu of TMDL | |
| 4. Antidegradation Review/Policy | 8. Benchmark based on MSGP | |

PHYSICAL:

Flow

In accordance with [40 CFR Part 122.44(i)(1)(ii)] the volume of effluent discharged from each outfall is needed to assure compliance with permitted effluent limitations. If the permittee is unable to obtain effluent flow, then it is the responsibility of the permittee to inform the department, which may require the submittal of an operating permit modification. The facility will report the total flow in millions of gallons per day (MGD).

Precipitation

Monitoring only requirement; measuring the amount of precipitation [(10 CSR 20-6.200(2)(C)1.E(VI)] during an event is necessary to ensure adequate stormwater management exists at the site. Knowing the amount of potential stormwater runoff can provide the permittee a better understanding of specific control measure that should be employed to ensure protection of water quality. The facility will provide the 24 hour accumulation value of precipitation from the day of sampling the other parameters. It is not necessary to report all days of precipitation during the quarter because of the readily available on-line data.

CONVENTIONAL:

Chemical Oxygen Demand (COD)

Daily maximum limit of 90 mg/L is included using the permit writer's best professional judgment. There is no water quality standard for COD; however, increased oxygen demand may impact instream water quality. COD is also a valuable indicator parameter. COD monitoring allows the permittee to identify increases in COD that may indicate materials/chemicals coming into contact with stormwater that cause an increase in oxygen demand. Increases in COD may indicate a need for maintenance or improvement of BMPs. COD was reported on the application materials received 7/20/2016 for these outfalls. For outfalls #002-#004, values exceeding 90 mg/L were reported. In order to protect the general criteria in the receiving stream, a daily maximum limit of 90 mg/L will be placed. This value falls within the range of values implemented in other permits that have similar industrial activities. A three year schedule of compliance will be allowed to the permittee to meet this new limit.

Escherichia coli (E. coli)

Monitoring only for daily maximum during the recreational season (April 1 through October 31). This parameter is included per the permit writer's professional judgment. Previous inspections of this facility pointed out several industrial practices that could contribute E. coli to the water shed, including allowing seepage of grease from the treatment works, and an employee spraying wash water contaminated food waste into the storm drain system in error. While the facility has returned to compliance for these infractions, it is still possible that other such activities could occur during daily operation. This parameter will allow the facility to monitor non-structural BMPs such as sweeping, cleaning, equipment maintenance, and employee training. Additionally, Center Creek is on the 2014 303(d) list for E. coli, meaning protections are necessary to restore the impaired use designations, and monitoring for this parameter will help determine this facility's total contribution of E. coli to the Center Creek watershed.

Oil and Grease

Daily maximum of 15 mg/L, continued from the previous permit. Oil and grease is considered a conventional pollutant. Oil and grease is a comprehensive test which measures for gasoline, diesel, crude oil, creosote, kerosene, heating oils, heavy fuel oils, lubricating oils, waxes, and some asphalt and pitch. The test can also detect some volatile organics such as benzene, toluene, ethylbenzene, or toluene, but these constituents are often lost during testing due to their boiling points. It is recommended to perform separate testing for these constituents if they are a known pollutant of concern at the site, i.e. aquatic life toxicity or human health is a concern. Results do not allow for separation of specific pollutants within the test, they are reported, totaled, as "Oil and grease". Per 10 CSR 20-7.031 Table A: *Criteria for Designated Uses*; 10 mg/L is the value for protection of aquatic life for this parameter. This is multiplied by 1.5 to get the daily maximum of 15 mg/L. 10 mg/L is the level at which sheen is expected to form on receiving waters. Oils and greases of different densities will possibly form sheen or unsightly bottom deposits at levels which vary from 10 mg/L. To protect the general criteria found at 10 CSR 20: 7.031 (4), it is the responsibility of the permittee to visually observe the discharge and receiving waters for sheen or bottom deposits. A schedule of compliance is offered to the facility for compliance with this new limit.

pH

6.5 to 9.0 SU. The Water Quality Standard at 10 CSR 20-7.031(5)(E) states water contaminants shall not cause pH to be outside the range of 6.5 to 9.0 standard pH units.

Total Suspended Solids (TSS)

Monitoring with a technology based benchmark of 100 mg/L. There are no water quality standards for TSS; however, sediment discharges can negatively impact aquatic life habitat. Increased TSS can lead to violations of the general criteria found at 10 CSR 20-7.031 (4) through causing changes in color, increases in temperature, or direct negative effects on aquatic life. Additionally, TSS is also a valuable indicator parameter. TSS monitoring allows the permittee to identify increases in TSS that may indicate uncontrolled materials leaving the site. A benchmark value will be implemented for this parameter. The benchmark value will be set at 100 mg/L. This value is achievable and falls within the range of values implemented in other permits with industrial activities. Application materials received 07/20/2016 show TSS values lower than 100 mg/L at all outfalls except outfall #004. A benchmark value will allow the permittee to evaluate the effectiveness of BMP measures at these stormwater outfalls.

TMDL RELATED METALS:

Zinc, Total Recoverable

Monitoring only. This facility is subject to the wasteload allocation found in the 2006 TMDL for zinc applicable to the Center Creek watershed. The TMDL refers to this facility by its previous name, Specialty Brands; however, the permit number for this facility is the same. Center Creek is impaired for zinc largely due to historical mining activities in the area. A wasteload allocation of 0.12 lbs/day dissolved zinc, and 0.13 lbs/day total recoverable zinc was assigned to this facility in the TMDL Document; however, after concurrence from the MDNR TMDL unit, it is in the professional judgment of the permit writer to require monitoring only to evaluate Ajinomoto-Windsor's contribution to the zinc loading in the watershed.

Part VI. SAMPLING AND REPORTING REQUIREMENTS:

Refer to each outfall's derivation and discussion of limits section to review individual sampling and reporting frequencies and sampling type.

ELECTRONIC DISCHARGE MONITORING REPORTING:

Due to recently enacted federal regulations, all facilities must begin submitting their discharge monitoring reports electronically, called the eDMR system. To begin the process, please visit <http://dnr.mo.gov/env/wpp/edmr.htm>. This process is expected to save time, lessen paperwork, and reduce operating costs for both the facilities and the water protection program. Additional information may also be found at <http://dnr.mo.gov/pubs/pub2474.pdf>.

SAMPLING FREQUENCY JUSTIFICATION:

Sampling and reporting frequency was generally retained from previous permit. Sampling was initiated on all stormwater outfalls at a quarterly frequency. Sampling frequency for stormwater-only outfalls is typically quarterly even though BMP inspection occurs monthly. The facility may sample more frequently if they need additional data to determine if their best management technology is performing as expected. 40 CFR 122.45(d)(1) indicates all continuous discharges shall be permitted with daily maximum and monthly average limits.

For flows less than or equal to 100,000 gpd use:

The Clean Water Commission has directed the Department to proceed with amending 10 CSR 20-7.015 to reduce the sampling frequency required for *E. coli* to a lesser frequency, still protective of water quality standards, for smaller facilities, including those with discharges of 100,000 gallons per day or less. The frequency used in this permit is monthly sampling.

SAMPLING TYPE JUSTIFICATION:

Sampling type was continued from the previous permit. The sampling types are representative of the discharges, and are protective of water quality. Grab samples are usually appropriate for stormwater. Parameters which must have grab sampling are: pH, ammonia, *E. coli*, total residual chlorine, free available chlorine, hexavalent chromium, dissolved oxygen, total phosphorus, and volatile organic samples.

Part VII. ADMINISTRATIVE REQUIREMENTS

On the basis of preliminary staff review and the application of applicable standards and regulations, the Department, as administrative agent for the Missouri Clean Water Commission, proposes to issue a permit(s) subject to certain effluent limitations, schedules, and special conditions contained herein and within the operating permit. The proposed determinations are tentative pending public comment.

PERMIT SYNCHRONIZATION:

The Department of Natural Resources is currently undergoing a synchronization process for operating permits. Permits are normally issued on a five-year term, but to achieve synchronization many permits will need to be issued for less than the full five years allowed by regulation. The intent is that all permits within a watershed will move through the Watershed Based Management (WBM) cycle together will all expire in the same fiscal year. <http://dnr.mo.gov/env/wpp/cpp/docs/watershed-based-management.pdf>. This will allow further streamlining by placing multiple permits within a smaller geographic area on public notice simultaneously, thereby reducing repeated administrative efforts. This will also allow the department to explore a watershed based permitting effort at some point in the future. Renewal applications must continue to be submitted within 180 days of expiration, however, in instances where effluent data from the previous renewal is less than three years old, that data may be re-submitted to meet the requirements of the renewal application. If the permit provides a schedule of compliance for meeting new water quality based effluent limits beyond the expiration date of the permit, the time remaining in the schedule of compliance will be allotted in the renewed permit. *This permit will become synchronized by expiring the end of the 4th quarter, 2017.*

PUBLIC NOTICE:

The Department shall give public notice that a draft permit has been prepared and its issuance is pending. <http://dnr.mo.gov/env/wpp/permits/pn/index.html> Additionally, public notice will be issued if a public hearing is to be held because of a significant degree of interest in and water quality concerns related to a draft permit. No public notice is required when a request for a permit modification or termination is denied; however, the requester and permittee must be notified of the denial in writing.

The Department must issue public notice of a pending operating permit or of a new or reissued statewide general permit. The public comment period is the length of time not less than 30 days following the date of the public notice which interested persons may submit written comments about the proposed permit.

For persons wanting to submit comments regarding this proposed operating permit, then please refer to the Public Notice page located at the front of this draft operating permit. The Public Notice page gives direction on how and where to submit appropriate comments.

- The Public Notice period for this operating permit was from 08/19/2016 to 09/19/2016. No responses were received.

The fact sheet of this permit was altered after public notice for typographical errors. No changes to the permit were made.

DATE OF FACT SHEET: 05/03/2016, UPDATED 08/02/2016

COMPLETED BY:

AMBERLY SCHULZ, ENVIRONMENTAL SPECIALIST
MISSOURI DEPARTMENT OF NATURAL RESOURCES
WATER PROTECTION PROGRAM
OPERATING PERMITS SECTION - INDUSTRIAL UNIT
(573) 751-8049
Amberly.schulz@dnr.mo.gov



STANDARD CONDITIONS FOR NPDES PERMITS
ISSUED BY
THE MISSOURI DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION
REVISED
AUGUST 1, 2014

These Standard Conditions incorporate permit conditions as required by 40 CFR 122.41 or other applicable state statutes or regulations. These minimum conditions apply unless superseded by requirements specified in the permit.

Part I – General Conditions

Section A – Sampling, Monitoring, and Recording

1. **Sampling Requirements.**
 - a. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
 - b. All samples shall be taken at the outfall(s) or Missouri Department of Natural Resources (Department) approved sampling location(s), and unless specified, before the effluent joins or is diluted by any other body of water or substance.
2. **Monitoring Requirements.**
 - a. Records of monitoring information shall include:
 - i. The date, exact place, and time of sampling or measurements;
 - ii. The individual(s) who performed the sampling or measurements;
 - iii. The date(s) analyses were performed;
 - iv. The individual(s) who performed the analyses;
 - v. The analytical techniques or methods used; and
 - vi. The results of such analyses.
 - b. If the permittee monitors any pollutant more frequently than required by the permit at the location specified in the permit using test procedures approved under 40 CFR Part 136, or another method required for an industry-specific waste stream under 40 CFR subchapters N or O, the results of such monitoring shall be included in the calculation and reported to the Department with the discharge monitoring report data (DMR) submitted to the Department pursuant to Section B, paragraph 7.
3. **Sample and Monitoring Calculations.** Calculations for all sample and monitoring results which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified in the permit.
4. **Test Procedures.** The analytical and sampling methods used shall conform to the reference methods listed in 10 CSR 20-7.015 unless alternates are approved by the Department. The facility shall use sufficiently sensitive analytical methods for detecting, identifying, and measuring the concentrations of pollutants. The facility shall ensure that the selected methods are able to quantify the presence of pollutants in a given discharge at concentrations that are low enough to determine compliance with Water Quality Standards in 10 CSR 20-7.031 or effluent limitations unless provisions in the permit allow for other alternatives. A method is “sufficiently sensitive” when; 1) the method minimum level is at or below the level of the applicable water quality criterion for the pollutant or, 2) the method minimum level is above the applicable water quality criterion, but the amount of pollutant in a facility’s discharge is high enough that the method detects and quantifies the level of pollutant in the discharge, or 3) the method has the lowest minimum level of the analytical methods approved under 10 CSR 20-7.015. These methods are also required for parameters that are listed as monitoring only, as the data collected may be used to determine if limitations need to be established. A permittee is responsible for working with their contractors to ensure that the analysis performed is sufficiently sensitive.
5. **Record Retention.** Except for records of monitoring information required by the permit related to the permittee’s sewage sludge use and disposal activities, which shall be retained for a period of at least five (5) years (or longer as required by 40 CFR part 503), the permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by the permit, and records of all data used to complete the application for the permit, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Department at any time.

6. **Illegal Activities.**
 - a. The Federal Clean Water Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under the permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than two (2) years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than four (4) years, or both.
 - b. The Missouri Clean Water Law provides that any person or who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained pursuant to sections 644.006 to 644.141 shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than six (6) months, or by both. Second and successive convictions for violation under this paragraph by any person shall be punished by a fine of not more than \$50,000 per day of violation, or by imprisonment for not more than two (2) years, or both.

Section B – Reporting Requirements

1. **Planned Changes.**
 - a. The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility when:
 - i. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR 122.29(b); or
 - ii. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in the permit, nor to notification requirements under 40 CFR 122.42;
 - iii. The alteration or addition results in a significant change in the permittee’s sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan;
 - iv. Any facility expansions, production increases, or process modifications which will result in a new or substantially different discharge or sludge characteristics must be reported to the Department 60 days before the facility or process modification begins. Notification may be accomplished by application for a new permit. If the discharge does not violate effluent limitations specified in the permit, the facility is to submit a notice to the Department of the changed discharge at least 30 days before such changes. The Department may require a construction permit and/or permit modification as a result of the proposed changes at the facility.
2. **Non-compliance Reporting.**
 - a. The permittee shall report any noncompliance which may endanger health or the environment. Relevant information shall be provided orally or via the current electronic method approved by the Department, within 24 hours from the time the permittee becomes aware of the circumstances, and shall be reported to the appropriate Regional Office during normal business hours or the Environmental Emergency Response hotline at 573-634-2436 outside of normal business hours. A written submission shall also be provided within five (5) business days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.



STANDARD CONDITIONS FOR NPDES PERMITS
ISSUED BY
THE MISSOURI DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION
REVISED
AUGUST 1, 2014

- b. The following shall be included as information which must be reported within 24 hours under this paragraph.
 - i. Any unanticipated bypass which exceeds any effluent limitation in the permit.
 - ii. Any upset which exceeds any effluent limitation in the permit.
 - iii. Violation of a maximum daily discharge limitation for any of the pollutants listed by the Department in the permit required to be reported within 24 hours.
 - c. The Department may waive the written report on a case-by-case basis for reports under paragraph 2. b. of this section if the oral report has been received within 24 hours.
3. **Anticipated Noncompliance.** The permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements. The notice shall be submitted to the Department 60 days prior to such changes or activity.
 4. **Compliance Schedules.** Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of the permit shall be submitted no later than 14 days following each schedule date. The report shall provide an explanation for the instance of noncompliance and a proposed schedule or anticipated date, for achieving compliance with the compliance schedule requirement.
 5. **Other Noncompliance.** The permittee shall report all instances of noncompliance not reported under paragraphs 2, 3, and 6 of this section, at the time monitoring reports are submitted. The reports shall contain the information listed in paragraph 2. a. of this section.
 6. **Other Information.** Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or information.
 7. **Discharge Monitoring Reports.**
 - a. Monitoring results shall be reported at the intervals specified in the permit.
 - b. Monitoring results must be reported to the Department via the current method approved by the Department, unless the permittee has been granted a waiver from using the method. If the permittee has been granted a waiver, the permittee must use forms provided by the Department.
 - c. Monitoring results shall be reported to the Department no later than the 28th day of the month following the end of the reporting period.
- b. Notice.
 - i. Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least 10 days before the date of the bypass.
 - ii. Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in Section B – Reporting Requirements, paragraph 5 (24-hour notice).
 - c. Prohibition of bypass.
 - i. Bypass is prohibited, and the Department may take enforcement action against a permittee for bypass, unless:
 1. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 2. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 3. The permittee submitted notices as required under paragraph 2. b. of this section.
 - ii. The Department may approve an anticipated bypass, after considering its adverse effects, if the Department determines that it will meet the three (3) conditions listed above in paragraph 2. c. i. of this section.
3. **Upset Requirements.**
 - a. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of paragraph 3. b. of this section are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
 - b. Conditions necessary for a demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - i. An upset occurred and that the permittee can identify the cause(s) of the upset;
 - ii. The permitted facility was at the time being properly operated; and
 - iii. The permittee submitted notice of the upset as required in Section B – Reporting Requirements, paragraph 2. b. ii. (24-hour notice).
 - iv. The permittee complied with any remedial measures required under Section D – Administrative Requirements, paragraph 4.
 - c. Burden of proof. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

Section C – Bypass/Upset Requirements

1. **Definitions.**
 - a. *Bypass*: the intentional diversion of waste streams from any portion of a treatment facility, except in the case of blending.
 - b. *Severe Property Damage*: substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
 - c. *Upset*: an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
2. **Bypass Requirements.**
 - a. Bypass not exceeding limitations. The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs 2. b. and 2. c. of this section.

Section D – Administrative Requirements

1. **Duty to Comply.** The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Missouri Clean Water Law and Federal Clean Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application.
 - a. The permittee shall comply with effluent standards or prohibitions established under section 307(a) of the Federal Clean Water Act for toxic pollutants and with standards for sewage sludge use or disposal established under section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions or standards for sewage sludge use or disposal, even if the permit has not yet been modified to incorporate the requirement.
 - b. The Federal Clean Water Act provides that any person who violates section 301, 302, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any such sections in a permit issued under section 402, or any requirement imposed in a pretreatment program approved under sections 402(a)(3) or 402(b)(8) of the Act, is subject to a civil penalty not to exceed \$25,000 per day for each violation. The Federal Clean Water Act provides that any person who negligently violates sections 301, 302, 306, 307, 308, 318, or 405 of the Act, or any condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, or any requirement



STANDARD CONDITIONS FOR NPDES PERMITS
ISSUED BY
THE MISSOURI DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION
REVISED
AUGUST 1, 2014

- imposed in a pretreatment program approved under section 402(a)(3) or 402(b)(8) of the Act, is subject to criminal penalties of \$2,500 to \$25,000 per day of violation, or imprisonment of not more than one (1) year, or both. In the case of a second or subsequent conviction for a negligent violation, a person shall be subject to criminal penalties of not more than \$50,000 per day of violation, or by imprisonment of not more than two (2) years, or both. Any person who knowingly violates such sections, or such conditions or limitations is subject to criminal penalties of \$5,000 to \$50,000 per day of violation, or imprisonment for not more than three (3) years, or both. In the case of a second or subsequent conviction for a knowing violation, a person shall be subject to criminal penalties of not more than \$100,000 per day of violation, or imprisonment of not more than six (6) years, or both. Any person who knowingly violates section 301, 302, 303, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, and who knows at that time that he thereby places another person in imminent danger of death or serious bodily injury, shall, upon conviction, be subject to a fine of not more than \$250,000 or imprisonment of not more than 15 years, or both. In the case of a second or subsequent conviction for a knowing endangerment violation, a person shall be subject to a fine of not more than \$500,000 or by imprisonment of not more than 30 years, or both. An organization, as defined in section 309(c)(3)(B)(iii) of the CWA, shall, upon conviction of violating the imminent danger provision, be subject to a fine of not more than \$1,000,000 and can be fined up to \$2,000,000 for second or subsequent convictions.
- c. Any person may be assessed an administrative penalty by the EPA Director for violating section 301, 302, 306, 307, 308, 318 or 405 of this Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of this Act. Administrative penalties for Class I violations are not to exceed \$10,000 per violation, with the maximum amount of any Class I penalty assessed not to exceed \$25,000. Penalties for Class II violations are not to exceed \$10,000 per day for each day during which the violation continues, with the maximum amount of any Class II penalty not to exceed \$125,000.
- d. It is unlawful for any person to cause or permit any discharge of water contaminants from any water contaminant or point source located in Missouri in violation of sections 644.006 to 644.141 of the Missouri Clean Water Law, or any standard, rule or regulation promulgated by the commission. In the event the commission or the director determines that any provision of sections 644.006 to 644.141 of the Missouri Clean Water Law or standard, rules, limitations or regulations promulgated pursuant thereto, or permits issued by, or any final abatement order, other order, or determination made by the commission or the director, or any filing requirement pursuant to sections 644.006 to 644.141 of the Missouri Clean Water Law or any other provision which this state is required to enforce pursuant to any federal water pollution control act, is being, was, or is in imminent danger of being violated, the commission or director may cause to have instituted a civil action in any court of competent jurisdiction for the injunctive relief to prevent any such violation or further violation or for the assessment of a penalty not to exceed \$10,000 per day for each day, or part thereof, the violation occurred and continues to occur, or both, as the court deems proper. Any person who willfully or negligently commits any violation in this paragraph shall, upon conviction, be punished by a fine of not less than \$2,500 nor more than \$25,000 per day of violation, or by imprisonment for not more than one year, or both. Second and successive convictions for violation of the same provision of this paragraph by any person shall be punished by a fine of not more than \$50,000 per day of violation, or by imprisonment for not more than two (2) years, or both.
2. **Duty to Reapply.**
- a. If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit.
- b. A permittee with a currently effective site-specific permit shall submit an application for renewal at least 180 days before the expiration date of the existing permit, unless permission for a later date has been granted by the Department. (The Department shall not grant permission for applications to be submitted later than the expiration date of the existing permit.)
- c. A permittees with currently effective general permit shall submit an application for renewal at least 30 days before the existing permit expires, unless the permittee has been notified by the Department that an earlier application must be made. The Department may grant permission for a later submission date. (The Department shall not grant permission for applications to be submitted later than the expiration date of the existing permit.)
3. **Need to Halt or Reduce Activity Not a Defense.** It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.
4. **Duty to Mitigate.** The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.
5. **Proper Operation and Maintenance.** The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit.
6. **Permit Actions.**
- a. Subject to compliance with statutory requirements of the Law and Regulations and applicable Court Order, this permit may be modified, suspended, or revoked in whole or in part during its term for cause including, but not limited to, the following:
- i. Violations of any terms or conditions of this permit or the law;
- ii. Having obtained this permit by misrepresentation or failure to disclose fully any relevant facts;
- iii. A change in any circumstances or conditions that requires either a temporary or permanent reduction or elimination of the authorized discharge; or
- iv. Any reason set forth in the Law or Regulations.
- b. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.
7. **Permit Transfer.**
- a. Subject to 10 CSR 20-6.010, an operating permit may be transferred upon submission to the Department of an application to transfer signed by the existing owner and the new owner, unless prohibited by the terms of the permit. Until such time the permit is officially transferred, the original permittee remains responsible for complying with the terms and conditions of the existing permit.
- b. The Department may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under the Missouri Clean Water Law or the Federal Clean Water Act.
- c. The Department, within 30 days of receipt of the application, shall notify the new permittee of its intent to revoke or reissue or transfer the permit.
8. **Toxic Pollutants.** The permittee shall comply with effluent standards or prohibitions established under section 307(a) of the Federal Clean Water Act for toxic pollutants and with standards for sewage sludge use or disposal established under section 405(d) of the Federal Clean Water Act within the time provided in the regulations that establish these standards or prohibitions or standards for sewage sludge use or disposal, even if the permit has not yet been modified to incorporate the requirement.
9. **Property Rights.** This permit does not convey any property rights of any sort, or any exclusive privilege.



STANDARD CONDITIONS FOR NPDES PERMITS
ISSUED BY
THE MISSOURI DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION
REVISED
AUGUST 1, 2014

10. **Duty to Provide Information.** The permittee shall furnish to the Department, within a reasonable time, any information which the Department may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. The permittee shall also furnish to the Department upon request, copies of records required to be kept by this permit.
11. **Inspection and Entry.** The permittee shall allow the Department, or an authorized representative (including an authorized contractor acting as a representative of the Department), upon presentation of credentials and other documents as may be required by law, to:
 - a. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of the permit;
 - b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
 - c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
 - d. Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Federal Clean Water Act or Missouri Clean Water Law, any substances or parameters at any location.
12. **Closure of Treatment Facilities.**
 - a. Persons who cease operation or plan to cease operation of waste, wastewater, and sludge handling and treatment facilities shall close the facilities in accordance with a closure plan approved by the Department.
 - b. Operating Permits under 10 CSR 20-6.010 or under 10 CSR 20-6.015 are required until all waste, wastewater, and sludges have been disposed of in accordance with the closure plan approved by the Department and any disturbed areas have been properly stabilized. Disturbed areas will be considered stabilized when perennial vegetation, pavement, or structures using permanent materials cover all areas that have been disturbed. Vegetative cover, if used, shall be at least 70% plant density over 100% of the disturbed area.
13. **Signatory Requirement.**
 - a. All permit applications, reports required by the permit, or information requested by the Department shall be signed and certified. (See 40 CFR 122.22 and 10 CSR 20-6.010)
 - b. The Federal Clean Water Act provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or non-compliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than six (6) months per violation, or by both.
 - c. The Missouri Clean Water Law provides that any person who knowingly makes any false statement, representation or certification in any application, record, report, plan, or other document filed or required to be maintained pursuant to sections 644.006 to 644.141 shall, upon conviction, be punished by a fine of not more than ten thousand dollars, or by imprisonment for not more than six months, or by both.
14. **Severability.** The provisions of the permit are severable, and if any provision of the permit, or the application of any provision of the permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of the permit, shall not be affected thereby.

STANDARD CONDITIONS FOR NPDES PERMITS
ISSUED BY
THE MISSOURI DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION
March 1, 2015

**PART III – SLUDGE AND BIOSOLIDS FROM DOMESTIC AND INDUSTRIAL WASTEWATER
TREATMENT FACILITIES**

SECTION A – GENERAL REQUIREMENTS

1. This permit pertains to sludge requirements under the Missouri Clean Water Law and regulation for domestic wastewater and industrial process wastewater. This permit also incorporates applicable federal sludge disposal requirements under 40 CFR 503 for domestic wastewater. The Environmental Protection Agency (EPA) has principal authority for permitting and enforcement of the federal sludge regulations under 40 CFR 503 for domestic wastewater. EPA has reviewed and accepted these standard sludge conditions. EPA may choose to issue a separate sludge addendum to this permit or a separate federal sludge permit at their discretion to further address the federal requirements.
2. These PART III Standard Conditions apply only to sludge and biosolids generated at domestic wastewater treatment facilities, including public owned treatment works (POTW), privately owned facilities and sludge or biosolids generated at industrial facilities.
3. Sludge and Biosolids Use and Disposal Practices:
 - a. The permittee is authorized to operate the sludge and biosolids treatment, storage, use, and disposal facilities listed in the facility description of this permit.
 - b. The permittee shall not exceed the design sludge volume listed in the facility description and shall not use sludge disposal methods that are not listed in the facility description, without prior approval of the permitting authority.
 - c. The permittee is authorized to operate the storage, treatment or generating sites listed in the Facility Description section of this permit.
4. Sludge Received from other Facilities:
 - a. Permittees may accept domestic wastewater sludge from other facilities including septic tank pumpings from residential sources as long as the design sludge volume is not exceeded and the treatment facility performance is not impaired.
 - b. The permittee shall obtain a signed statement from the sludge generator or hauler that certifies the type and source of the sludge
5. These permit requirements do not supersede nor remove liability for compliance with county and other local ordinances.
6. These permit requirements do not supersede nor remove liability for compliance with other environmental regulations such as odor emissions under the Missouri Air Pollution Control Law and regulations.
7. This permit may (after due process) be modified, or alternatively revoked and reissued, to comply with any applicable sludge disposal standard or limitation issued or approved under Section 405(d) of the Clean Water Act or under Chapter 644 RSMo.
8. In addition to STANDARD CONDITIONS, the Department may include sludge limitations in the special conditions portion or other sections of a site specific permit.
9. Alternate Limits in the Site Specific Permit.

Where deemed appropriate, the Department may require an individual site specific permit in order to authorize alternate limitations:

 - a. A site specific permit must be obtained for each operating location, including application sites.
 - b. To request a site specific permit, an individual permit application, permit fee, and supporting documents shall be submitted for each operating location. This shall include a detailed sludge/biosolids management plan or engineering report.
10. Exceptions to these Standard Conditions may be authorized on a case-by-case basis by the Department, as follows:
 - a. The Department will prepare a permit modification and follow permit notice provisions as applicable under 10 CSR 20-6.020, 40 CFR 124.10, and 40 CFR 501.15(a)(2)(ix)(E). This includes notification of the owner of the property located adjacent to each land application site, where appropriate.
 - b. Exceptions cannot be granted where prohibited by the federal sludge regulations under 40 CFR 503.

SECTION B – DEFINITIONS

1. Best Management Practices include agronomic loading rates, soil conservation practices and other site restrictions.
2. Biosolids means organic fertilizer or soil amendment produced by the treatment of domestic wastewater sludge.
3. Biosolids land application facility is a facility where biosolids are spread onto the land at agronomic rates for production of food or fiber. The facility includes any structures necessary to store the biosolids until soil, weather, and crop conditions are favorable for land application.
4. Class A biosolids means a material that has met the Class A pathogen reduction requirements or equivalent treatment by a Process to Further Reduce Pathogens (PFRP) in accordance with 40 CFR 503.
5. Class B biosolids means a material that has met the Class B pathogen reduction requirements or equivalent treatment by a Process to Significantly Reduce Pathogens (PFRP) in accordance with 40 CFR 503.
6. Domestic wastewater means wastewater originating from the sanitary conveniences of residences, commercial buildings, factories and institutions; or co-mingled sanitary and industrial wastewater processed by a (POTW) or a privately owned facility.
7. Industrial wastewater means any wastewater, also known as process water, not defined as domestic wastewater. Per 40 CFR Part 122, process water means any water which, during manufacturing or processing, comes into direct contact with or results from the production or use of any raw material, intermediate product, finished product, byproduct, or waste product.
8. Mechanical treatment plants are wastewater treatment facilities that use mechanical devices to treat wastewater, including septic tanks, sand filters, extended aeration, activated sludge, contact stabilization, trickling filters, rotating biological discs, and other similar facilities. It does not include wastewater treatment lagoons and constructed wetlands for wastewater treatment.
9. Operating location as defined in 10 CSR 20-2.010 is all contiguous lands owned, operated or controlled by one (1) person or by two (2) or more persons jointly or as tenants in common.
10. Plant Available Nitrogen (PAN) is the nitrogen that will be available to plants during the growing seasons after biosolids application.
11. Public contact site is land with a high potential for contact by the public. This includes, but is not limited to, public parks, ball fields, cemeteries, plant nurseries, turf farms, and golf courses.
12. Sludge is the solid, semisolid, or liquid residue removed during the treatment of wastewater. Sludge includes septage removed from septic tanks or equivalent facilities. Sludge does not include carbon coal byproducts (CCBs)
13. Sludge lagoon is part of a mechanical wastewater treatment facility. A sludge lagoon is an earthen basin that receives sludge that has been removed from a wastewater treatment facility. It does not include a wastewater treatment lagoon or sludge treatment units that are not a part of a mechanical wastewater treatment facility.
14. Septage is the material pumped from residential septic tanks and similar treatment works (with a design population of less than 150 people). The standard for biosolids from septage is different from other sludges.

SECTION C – MECHANICAL WASTEWATER TREATMENT FACILITIES

1. Sludge shall be routinely removed from wastewater treatment facilities and handled according to the permit facility description and sludge conditions of this permit.
2. The permittee shall operate the facility so that there is no sludge discharged to waters of the state.
3. Mechanical treatment plants shall have separate sludge storage compartments in accordance with 10 CSR 20, Chapter 8. Failure to remove sludge from these storage compartments on the required design schedule is a violation of this permit.

SECTION D – SLUDGE DISPOSED AT OTHER TREATMENT FACILITY OR CONTRACT HAULER

1. This section applies to permittees that haul sludge to another treatment facility for disposal or use contract haulers to remove and dispose of sludge.
2. Permittees that use contract haulers are responsible for compliance with all the terms of this permit including final disposal, unless the hauler has a separate permit for sludge or biosolids disposal issued by the Department; or the hauler transports the sludge to another permitted treatment facility.
3. Haulers who land apply septage must obtain a state permit.
4. Testing of sludge, other than total solids content, is not required if sludge is hauled to a municipal wastewater treatment facility or other permitted wastewater treatment facility, unless it is required by the accepting facility.

SECTION E – INCINERATION OF SLUDGE

1. Sludge incineration facilities shall comply with the requirements of 40 CFR 503 Subpart E; air pollution control regulations under 10 CSR 10; and solid waste management regulations under 10 CSR 80.
2. Permittee may be authorized under the facility description of this permit to store incineration ash in lagoons or ash ponds. This permit does not authorize the disposal of incineration ash. Incineration ash shall be disposed in accordance with 10 CSR 80; or if the ash is determined to be hazardous with 10 CSR 25.
3. In addition to normal sludge monitoring, incineration facilities shall report the following as part of the annual report, quantity of sludge incinerated, quantity of ash generated, quantity of ash stored, and ash used or disposal method, quantity, and location. Permittee shall also provide the name of the disposal facility and the applicable permit number.

SECTION F – SURFACE DISPOSAL SITES AND SLUDGE LAGOONS

1. Surface disposal sites of domestic facilities shall comply with the requirements in 40 CFR 503 Subpart C; air pollution control regulations under 10 CSR 10; and solid waste management regulations under 10 CSR 80.
2. Sludge storage lagoons are temporary facilities and are not required to obtain a permit as a solid waste management facility under 10 CSR 80. In order to maintain sludge storage lagoons as storage facilities, accumulated sludge must be removed routinely, but not less than once every two years unless an alternate schedule is approved in the permit. The amount of sludge removed will be dependent on sludge generation and accumulation in the facility. Enough sludge must be removed to maintain adequate storage capacity in the facility.
 - a. In order to avoid damage to the lagoon seal during cleaning, the permittee may leave a layer of sludge on the bottom of the lagoon, upon prior approval of the Department; or
 - b. Permittee shall close the lagoon in accordance with Section H.

SECTION G – LAND APPLICATION

1. The permittee shall not land apply sludge or biosolids unless land application is authorized in the facility description or the special conditions of the issued NPDES permit.
2. Land application sites within a 20 miles radius of the wastewater treatment facility are authorized under this permit when biosolids are applied for beneficial use in accordance with these standard conditions unless otherwise specified in a site specific permit. If the permittee's land application site is greater than a 20 mile radius of the wastewater treatment facility, approval must be granted from the Department.
3. Land application shall not adversely affect a threatened or endangered species or its designated critical habitat.
4. Biosolids shall not be applied unless authorized in this permit or exempted under 10 CSR 20, Chapter 6.
 - a. This permit does not authorize the land application of domestic sludge except for when sludge meets the definition of biosolids.
 - b. This permit authorizes "Class A or B" biosolids derived from domestic wastewater and/or process water sludge to be land applied onto grass land, crop land, timber or other similar agricultural or silviculture lands at rates suitable for beneficial use as organic fertilizer and soil conditioner.
5. Public Contact Sites:

Permittees who wish to apply Class A biosolids to public contact sites must obtain approval from the Department after two years of proper operation with acceptable testing documentation that shows the biosolids meet Class A criteria. A shorter length of testing will be allowed with prior approval from the Department. Authorization for land applications must be provided in the special conditions section of this permit or in a separate site specific permit.

 - a. After Class B biosolids have been land applied, public access must be restricted for 12 months.
 - b. Class B biosolids are only land applied to root crops, home gardens or vegetable crops whose edible parts will not be for human consumption.
6. Agricultural and Silvicultural Sites:

Septage – Based on Water Quality guide 422 (WQ422) published by the University of Missouri

 - a. Haulers that land apply septage must obtain a state permit
 - b. Do not apply more than 30,000 gallons of septage per acre per year.
 - c. Septage tanks are designed to retain sludge for one to three years which will allow for a larger reduction in pathogens and vectors, as compared to other mechanical type treatment facilities.
 - d. To meet Class B sludge requirements, maintain septage at 12 pH for at least thirty (30) minutes before land application. 50 pounds of hydrated lime shall be added to each 1,000 gallons of septage in order to meet pathogen and vector stabilization for septage biosolids applied to crops, pastures or timberland.
 - e. Lime is to be added to the pump truck and not directly to the septic tanks, as lime would harm the beneficial bacteria of the septic tank.

Biosolids - Based on Water Quality guide 423, 424, and 425 (WQ423, WQ424, WQ425) published by the University of Missouri;

- a. Biosolids shall be monitored to determine the quality for regulated pollutants
- b. The number of samples taken is directly related to the amount of sludge produced by the facility (See Section I of these Standard Conditions). Report as dry weight unless otherwise specified in the site specific permit. Samples should be taken only during land application periods. When necessary, it is permissible to mix biosolids with lower concentrations of biosolids as well as other suitable Department approved material to reach the maximum concentration of pollutants allowed.
- c. Table 1 gives the maximum concentration allowable to protect water quality standards

TABLE 1

Biosolids ceiling concentration ¹	
Pollutant	Milligrams per kilogram dry weight
Arsenic	75
Cadmium	85
Copper	4,300
Lead	840
Mercury	57
Molybdenum	75
Nickel	420
Selenium	100
Zinc	7,500

¹ Land application is not allowed if the sludge concentration exceeds the maximum limits for any of these pollutants

- d. The low metal concentration biosolids has reduced requirements because of its higher quality and can safely be applied for 100 years or longer at typical agronomic loading rates. (See Table 2)

TABLE 2

Biosolids Low Metal Concentration ¹	
Pollutant	Milligrams per kilogram dry weight
Arsenic	41
Cadmium	39
Copper	1,500
Lead	300
Mercury	17
Nickel	420
Selenium	36
Zinc	2,800

¹ You may apply low metal biosolids without tracking cumulative metal limits, provided the cumulative application of biosolids does not exceed 500 dry tons per acre.

- e. Each pollutant in Table 3 has an annual and a total cumulative loading limit, based on the allowable pounds per acre for various soil categories.

TABLE 3

Pollutant	CEC 15+		CEC 5 to 15		CEC 0 to 5	
	Annual	Total ¹	Annual	Total ¹	Annual	Total ¹
Arsenic	1.8	36.0	1.8	36.0	1.8	36.0
Cadmium	1.7	35.0	0.9	9.0	0.4	4.5
Copper	66.0	1,335.0	25.0	250.0	12.0	125.0
Lead	13.0	267.0	13.0	267.0	13.0	133.0
Mercury	0.7	15.0	0.7	15.0	0.7	15.0
Nickel	19.0	347.0	19.0	250.0	12.0	125.0
Selenium	4.5	89.0	4.5	44.0	1.6	16.0
Zinc	124.0	2,492.0	50.0	500.0	25.0	250.0

¹ Total cumulative loading limits for soils with equal or greater than 6.0 pH (salt based test) or 6.5 pH (water based test)

TABLE 4 - Guidelines for land application of other trace substances ¹

Cumulative Loading	
Pollutant	Pounds per acre
Aluminum	4,000 ²
Beryllium	100
Cobalt	50
Fluoride	800
Manganese	500
Silver	200
Tin	1,000
Dioxin	(10 ppt in soil) ³
Other	⁴

¹ Design of land treatment systems for Industrial Waste, 1979. Michael Ray Overcash, North Carolina State University and Land Treatment of Municipal Wastewater, EPA 1981.)

² This applies for a soil with a pH between 6.0 and 7.0 (salt based test) or a pH between 6.5 to 7.5 (water based test). Case-by-case review is required for higher pH soils.

³ Total Dioxin Toxicity Equivalents (TEQ) in soils, based on a risk assessment under 40 CFR 744, May 1998.

⁴ Case by case review. Concentrations in sludge should not exceed the 95th percentile of the National Sewage Sludge Survey, EPA, January 2009.

Best Management Practices – Based on Water Quality guide 426 (WQ426) published by the University of Missouri

- a. Use best management practices when applying biosolids.
- b. Biosolids cannot discharge from the land application site
- c. Biosolid application is subject to the Missouri Department of Agriculture State Milk Board concerning grazing restrictions of lactating dairy cattle.
- d. Biosolid application must be in accordance with section 4 of the Endangered Species Act.
- e. Do not apply more than the agronomic rate of nitrogen needed.
- f. The applicator must document the Plant Available Nitrogen (PAN) loadings, available nitrogen in the soil, and crop removal when either of the following occurs: 1) When biosolids are greater than 50,000 mg/kg TN; or 2) When biosolids are land applied at an application rate greater than two dry tons per acre per year.
 - i. PAN can be determined as follows and is in accordance with WQ426
(Nitrate + nitrite nitrogen) + (organic nitrogen x 0.2) + (ammonia nitrogen x volatilization factor¹).
¹Volatilization factor is 0.7 for surface application and 1 for subsurface application.
- g. Buffer zones are as follows:
 - i. 300 feet of a water supply well, sinkhole, lake, pond, water supply reservoir or water supply intake in a stream;
 - ii. 300 feet of a losing stream, no discharge stream, stream stretches designated for whole body contact recreation, wild and scenic rivers, Ozark National Scenic Riverways or outstanding state resource waters as listed in the Water Quality Standards, 10 CSR 20-7.031;
 - iii. 150 feet if dwellings;
 - iv. 100 feet of wetlands or permanent flowing streams;
 - v. 50 feet of a property line or other waters of the state, including intermittent flowing streams.
- h. Slope limitation for application sites are as follows;
 - i. A slope 0 to 6 percent has no rate limitation
 - ii. Applied to a slope 7 to 12 percent, the applicator may apply biosolids when soil conservation practices are used to meet the minimum erosion levels
 - iii. Slopes > 12 percent, apply biosolids only when grass is vegetated and maintained with at least 80 percent ground cover at a rate of two dry tons per acre per year or less.
- i. No biosolids may be land applied in an area that it is reasonably certain that pollutants will be transported into waters of the state.
- j. Do not apply biosolids to sites with soil that is snow covered, frozen or saturated with liquid without prior approval by the Department.
- k. Biosolids / sludge applicators must keep detailed records up to five years.

SECTION H – CLOSURE REQUIREMENTS

1. This section applies to all wastewater facilities (mechanical, industrial, and lagoons) and sludge or biosolids storage and treatment facilities and incineration ash ponds. It does not apply to land application sites.
2. Permittees of a domestic wastewater facility who plan to cease operation must obtain Department approval of a closure plan which addresses proper removal and disposal of all residues, including sludge, biosolids. Mechanical plants, sludge lagoons, ash ponds and other storage structures must obtain approval of a closure plan from the Department. Permittee must maintain this permit until the facility is closed in accordance with the approved closure plan per 10 CSR 20 – 6. 010 and 10 CSR 20 – 6.015.
3. Residuals that are left in place during closure of a lagoon or earthen structure or ash pond shall not exceed the agricultural loading rates as follows:
 - a. Residuals shall meet the monitoring and land application limits for agricultural rates as referenced in Section H of these standard conditions.
 - b. If a wastewater treatment lagoon has been in operation for 15 years or more without sludge removal, the sludge in the lagoon qualifies as a Class B biosolids with respect to pathogens due to anaerobic digestion, and testing for fecal coliform is not required. For other lagoons, testing for fecal coliform is required to show compliance with Class B biosolids limitations. In order to reach Class B biosolids requirements, fecal coliform must be less than 2,000,000 colony forming units or 2,000,000 most probable number. All fecal samples must be presented as geometric mean per gram.
 - c. The allowable nitrogen loading that may be left in the lagoon shall be based on the plant available nitrogen (PAN) loading. For a grass cover crop, the allowable PAN is 300 pounds/acre.
 - i. PAN can be determined as follows:
$$(\text{Nitrate} + \text{nitrite nitrogen}) + (\text{organic nitrogen} \times 0.2) + (\text{ammonia nitrogen} \times \text{volatilization factor}^1).$$

¹ Volatilization factor is 0.7 for surface application and 1 for subsurface application.
4. When closing a domestic wastewater treatment lagoon with a design treatment capacity equal or less than 150 persons, the residuals are considered “septage” under the similar treatment works definition. See Section B of these standard conditions. Under the septage category, residuals may be left in place as follows:
 - a. Testing for metals or fecal coliform is not required
 - b. If the wastewater treatment lagoon has been in use for less than 15 years, mix lime with the sludge at a rate of 50 pounds of hydrated lime per 1000 gallons (134 cubic feet) of sludge.
 - c. The amount of sludge that may be left in the lagoon shall be based on the plant available nitrogen (PAN) loading. 100 dry tons/acre of sludge may be left in the basin without testing for nitrogen. If 100 dry tons/acre or more will be left in the lagoon, test for nitrogen and determine the PAN using the calculation above. Allowable PAN loading is 300 pounds/acre.
5. Residuals left within the domestic lagoon shall be mixed with soil on at least a 1 to 1 ratio, the lagoon berm shall be demolished, and the site shall be graded and contain $\geq 70\%$ vegetative density over 100% of the site so as to avoid ponding of storm water and provide adequate surface water drainage without creating erosion.
6. Lagoons and/or earthen structure and/or ash pond closure activities shall obtain a storm water permit for land disturbance activities that equal or exceed one acre in accordance with 10 CSR 20-6.200
7. When closing a mechanical wastewater and/or industrial process wastewater plant; all sludge must be cleaned out and disposed of in accordance with the Department approved closure plan before the permit for the facility can be terminated.
 - a. Land must be stabilized which includes any grading, alternate use or fate upon approval by the Department, remediation, or other work that exposes sediment to stormwater per 10 CSR 20-6.200. The site shall be graded and contain $\geq 70\%$ vegetative density over 100% of the site, so as to avoid ponding of storm water and provide adequate surface water drainage without creating erosion.
 - b. Per 10 CSR 20-6.015(4)(B)6, Hazardous Waste shall not be land applied or disposed during industrial and mechanical plant closures unless in accordance with Missouri Hazardous Waste Management Law and Regulations under 10 CSR 25.
 - c. After demolition of the mechanical plant / industrial plant, the site must only contain clean fill defined in RSMo 260.200 (5) as uncontaminated soil, rock, sand, gravel, concrete, asphaltic concrete, cinderblocks, brick, minimal amounts of wood and metal, and inert solids as approved by rule or policy of the Department for fill or other beneficial use. Other solid wastes must be removed.
8. If sludge from the domestic lagoon or mechanical treatment plant exceeds agricultural rates under Section G and/or H, a landfill permit or solid waste disposal permit must be obtained if the permittee chooses to seek authorization for on-site sludge disposal under the Missouri Solid Waste Management Law and regulations per 10 CSR 80, and the permittee must comply with the surface disposal requirements under 40 CFR 503, Subpart C.

SECTION I – MONITORING FREQUENCY

- At a minimum, sludge or biosolids shall be tested for volume and percent total solids on a frequency that will accurately represent sludge quantities produced and disposed. Please see the table below.

TABLE 5

Design Sludge Production (dry tons per year)	Monitoring Frequency (See Notes 1, 2, and 3)			
	Metals, Pathogens and Vectors	Nitrogen TKN ¹	Nitrogen PAN ²	Priority Pollutants and TCLP ³
0 to 100	1 per year	1 per year	1 per month	1 per year
101 to 200	biannual	biannual	1 per month	1 per year
201 to 1,000	quarterly	quarterly	1 per month	1 per year
1,001 to 10,000	1 per month	1 per month	1 per week	-- ⁴
10,001 +	1 per week	1 per week	1 per day	-- ⁴

¹ Test total Kjeldahl nitrogen, if biosolids application is 2 dry tons per acre per year or less.

² Calculate plant available nitrogen (PAN) when either of the following occurs: 1) when biosolids are greater than 50,000 mg/kg TN; or 2) when biosolids are land applied at an application rate greater than two dry tons per acre per year.

³ Priority pollutants (40 CFR 122.21, Appendix D, Tables II and III) and toxicity characteristic leaching procedure (40 CFR 261.24) is required only for permit holders that must have a pre-treatment program.

⁴ One sample for each 1,000 dry tons of sludge.

Note 1: Total solids: A grab sample of sludge shall be tested one per day during land application periods for percent total solids.

This data shall be used to calculate the dry tons of sludge applied per acre.

Note 2: Total Phosphorus: Total phosphorus and total potassium shall be tested at the same monitoring frequency as metals.

Note 3: Table 5 is not applicable for incineration and permit holders that landfill their sludge.

- If you own a wastewater treatment lagoon or sludge lagoon that is cleaned out once a year or less, you may choose to sample only when the sludge is removed or the lagoon is closed. Test one composite sample for each 100 dry tons of sludge or biosolids removed from the lagoon during the year within the lagoon at closing. Composite sample must represent various areas at one-foot depth.
- Additional testing may be required in the special conditions or other sections of the permit. Permittees receiving industrial wastewater may be required to conduct additional testing upon request from the Department.
- At this time, the Department recommends monitoring requirements shall be performed in accordance with, "POTW Sludge Sampling and Analysis Guidance Document," United States Environmental Protection Agency, August 1989, and the subsequent revisions.

SECTION J – RECORD KEEPING AND REPORTING REQUIREMENTS

- The permittee shall maintain records on file at the facility for at least five years for the items listed in these standard conditions and any additional items in the Special Conditions section of this permit. This shall include dates when the sludge facility is checked for proper operation, records of maintenance and repairs and other relevant information.
- Reporting period
 - By January 28th of each year, an annual report shall be submitted for the previous calendar year period for all mechanical wastewater treatment facilities, sludge lagoons, and sludge or biosolids disposal facilities.
 - Permittees with wastewater treatment lagoons shall submit the above annual report only when sludge or biosolids are removed from the lagoon during the report period or when the lagoon is closed.
- Report Forms. The annual report shall be submitted on report forms provided by the Department or equivalent forms approved by the Department.
- Reports shall be submitted as follows:


Major facilities (those serving 10,000 persons or 1 million gallons per day) shall report to both the Department and EPA. Other facilities need to report only to the Department. Reports shall be submitted to the addresses listed as follows:

DNR regional office listed in your permit
(see cover letter of permit)
ATTN: Sludge Coordinator

EPA Region VII
Water Compliance Branch (WACM)
Sludge Coordinator
11201 Renner Blvd.
Lenexa, KS 66219

5. Annual report contents. The annual report shall include the following:
- a. Sludge and biosolids testing performed. Include a copy or summary of all test results, even if not required by the permit.
 - b. Sludge or biosolids quantity shall be reported as dry tons for quantity generated by the wastewater treatment facility, the quantity stored on site at the end of the year, and the quantity used or disposed.
 - c. Gallons and % solids data used to calculate the dry ton amounts.
 - d. Description of any unusual operating conditions.
 - e. Final disposal method, dates, and location, and person responsible for hauling and disposal.
 - i. This must include the name, address for the hauler and sludge facility. If hauled to a municipal wastewater treatment facility, sanitary landfill, or other approved treatment facility, give the name of that facility.
 - ii. Include a description of the type of hauling equipment used and the capacity in tons, gallons, or cubic feet.
 - f. Contract Hauler Activities:

If contract hauler, provide a copy of a signed contract from the contractor. Permittee shall require the contractor to supply information required under this permit for which the contractor is responsible. The permittee shall submit a signed statement from the contractor that he has complied with the standards contained in this permit, unless the contract hauler has a separate sludge or biosolids use permit.
 - g. Land Application Sites:
 - i. Report the location of each application site, the annual and cumulative dry tons/acre for each site, and the landowners name and address. The location for each spreading site shall be given as a legal description for nearest ¼, ¼, Section, Township, Range, and county, or UTM coordinates. The facility shall report PAN when either of the following occurs: 1) When biosolids are greater than 50,000 mg/kg TN; or 2) when biosolids are land applied at an application rate greater than two dry tons per acre per year.
 - ii. If the “Low Metals” criteria are exceeded, report the annual and cumulative pollutant loading rates in pounds per acre for each applicable pollutant, and report the percent of cumulative pollutant loading which has been reached at each site.
 - iii. Report the method used for compliance with pathogen and vector attraction requirements.
 - iv. Report soil test results for pH, CEC, and phosphorus. If none was tested during the year, report the last date when tested and results.



MISSOURI DEPARTMENT OF NATURAL RESOURCES
 WATER PROTECTION PROGRAM, WATER POLLUTION CONTROL BRANCH
**FORM A - APPLICATION FOR CONSTRUCTION OR OPERATING PERMIT
 UNDER MISSOURI CLEAN WATER LAW**

AP 15591
FOR AGENCY USE ONLY
 RECEIVED
 MAY 2013
 CHECK NUMBER
 DEC/SWRO
 DATE RECEIVED 5-29-13
 FEE SUBMITTED 0-0-08
 12345678

Note PLEASE READ THE ACCOMPANYING INSTRUCTIONS BEFORE COMPLETING THIS FORM

1. This application is for:

An operating permit and antidegradation review public notice

A construction permit following an appropriate operating permit and antidegradation review public notice

A construction permit and concurrent operating permit and antidegradation review public notice

A construction permit (submitted before Aug. 30, 2008 or antidegradation review is not required)

An operating permit for a new or unpermitted facility Construction Permit # _____

An operating permit renewal: permit # MO- 0002470 Expiration Date 09/14/13

An operating permit modification: permit # MO- _____ Reason: _____

1.1 Is the appropriate fee included with the application? (See instructions for appropriate fee) YES NO

2. FACILITY

NAME Windsor Foods		TELEPHONE WITH AREA CODE (417) 358-8104	
ADDRESS (PHYSICAL) 5691 & 5695 S. Davinci Lane		FAX (417) 359-9389	
CITY Carthage	STATE Mo.	ZIP CODE 64836	

3. OWNER

NAME Windsor Foods		E-MAIL ADDRESS	TELEPHONE WITH AREA CODE (417) 358-8104	
ADDRESS (MAILING) 5691 South Davinci Lane		FAX (417) 359-9389		
CITY Carthage	STATE Mo.	ZIP CODE 64836		

3.1 Request review of draft permit prior to public notice? YES NO

4. CONTINUING AUTHORITY

NAME Windsor Foods		TELEPHONE WITH AREA CODE (713) 843-5200	
ADDRESS (MAILING) 3355 W. Alabama		FAX (713) 960-9709	
CITY Houston	STATE TX.	ZIP CODE 77098	

5. OPERATOR

NAME John Burns		CERTIFICATE NUMBER 6998	TELEPHONE WITH AREA CODE (417) 358-8104	
ADDRESS (MAILING) 5691 S. Davinci Lane		FAX (417) 358-4069		
CITY Carthage	STATE Mo.	ZIP CODE 64836		

6. FACILITY CONTACT

NAME David Loyd		TITLE Plant Engineer & Environmental Mgr.	TELEPHONE WITH AREA CODE (417) 358-8104	
		FAX (417) 359-9389		

7. ADDITIONAL FACILITY INFORMATION

7.1 Legal Description of Outfalls. (Attach additional sheets if necessary.)

001 NW 1/4 SE 1/4 Sec 33 T 28N R 31 JAS. County
 UTM Coordinates Easting (X): 382975 Northing (Y): 4107050
For Universal Transverse Mercator (UTM), Zone 15 North referenced to North American Datum 1983 (NAD83)

002 NW 1/4 SE 1/4 Sec 33 T 28N R 31 JAS. County
 UTM Coordinates Easting (X): 383246 Northing (Y): N410700009

003 NW 1/4 SE 1/4 Sec 33 T 28N R 31 JAS. County
 UTM Coordinates Easting (X): 383214 Northing (Y): 4107046

004 NW 1/4 SE 1/4 Sec 33 T 28N R 31 JAS. County
 UTM Coordinates Easting (X): 383178 Northing (Y): 4107060

7.2 Primary Standard Industrial Classification (SIC) and Facility North American Industrial Classification System (NAICS) Codes.

001 - SIC 2038 and NAICS 311412 002 - SIC 2038 and NAICS 311412
 003 - SIC 2038 and NAICS 311412 004 - SIC 2038 and NAICS 311412



MISSOURI DEPARTMENT OF NATURAL RESOURCES
 WATER PROTECTION PROGRAM, WATER POLLUTION CONTROL BRANCH
**FORM A – APPLICATION FOR CONSTRUCTION OR OPERATING PERMIT
 UNDER MISSOURI CLEAN WATER LAW**

FOR AGENCY USE ONLY	
CHECK NUMBER	MAY 2013
DATE RECEIVED	5-29-13
FEE SUBMITTED	0-00

Note PLEASE READ THE ACCOMPANYING INSTRUCTIONS BEFORE COMPLETING THIS FORM

1. This application is for:

An operating permit and antidegradation review public notice

A construction permit following an appropriate operating permit and antidegradation review public notice

A construction permit and concurrent operating permit and antidegradation review public notice

A construction permit (submitted before Aug. 30, 2008 or antidegradation review is not required)

An operating permit for a new or unpermitted facility Construction Permit # _____

An operating permit renewal: permit # MO- _____ Expiration Date _____

An operating permit modification: permit # MO- _____ Reason: _____

1.1 Is the appropriate fee included with the application? (See instructions for appropriate fee) YES NO

2. FACILITY

NAME		TELEPHONE WITH AREA CODE	
ADDRESS (PHYSICAL)		CITY	STATE ZIP CODE
		FAX	

3. OWNER

NAME		E-MAIL ADDRESS	TELEPHONE WITH AREA CODE	
ADDRESS (MAILING)		CITY	STATE	ZIP CODE
		FAX		

3.1 Request review of draft permit prior to public notice? YES NO

4. CONTINUING AUTHORITY

NAME		TELEPHONE WITH AREA CODE	
ADDRESS (MAILING)		CITY	STATE ZIP CODE
		FAX	

5. OPERATOR

NAME		CERTIFICATE NUMBER	TELEPHONE WITH AREA CODE	
ADDRESS (MAILING)		CITY	STATE	ZIP CODE
		FAX		

6. FACILITY CONTACT

NAME		TITLE	TELEPHONE WITH AREA CODE	
		FAX		

7. ADDITIONAL FACILITY INFORMATION

7.1 Legal Description of Outfalls. (Attach additional sheets if necessary.)

005 NW 1/4 SE 1/4 Sec 33 T 28N R 31 JAS County
 UTM Coordinates Easting (X): 383106 Northing (Y): 4106870
 For Universal Transverse Mercator (UTM), Zone 15 North referenced to North American Datum 1983 (NAD83)

002 1/4 1/4 Sec T R County
 UTM Coordinates Easting (X): Northing (Y):

003 1/4 1/4 Sec T R County
 UTM Coordinates Easting (X): Northing (Y):

004 1/4 1/4 Sec T R County
 UTM Coordinates Easting (X): Northing (Y):

7.2 Primary Standard Industrial Classification (SIC) and Facility North American Industrial Classification System (NAICS) Codes.

005- SIC 2038 and NAICS 311412 002 - SIC and NAICS
 003 - SIC and NAICS 004 - SIC and NAICS

8. ADDITIONAL FORMS AND MAPS NECESSARY TO COMPLETE THIS APPLICATION
 (Complete all forms that are applicable.)

A.	Is your facility a manufacturing, commercial, mining or silviculture waste treatment facility? If yes, complete Form C (unless storm water only, then complete U.S. Environmental Protection Agency Form 2F per Item C below).	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
B.	Is your facility considered a "Primary Industry" under EPA guidelines: If yes, complete Forms C and D.	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
C.	Is application for storm water discharges only? If yes, complete EPA Form 2F.	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
D.	Attach a map showing all outfalls and the receiving stream at 1" = 2,000' scale.	
E.	Is wastewater land applied? If yes, complete Form I.	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
F.	Is sludge, biosolids, ash or residuals generated, treated, stored or land applied? If yes, complete Form R.	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>

9. DOWNSTREAM LANDOWNER(S) Attach additional sheets as necessary. See Instructions.
 (PLEASE SHOW LOCATION ON MAP. SEE 8.D ABOVE).

NAME Robert W. Richart			
ADDRESS 630 NW Murphy Blvd.	CITY Joplin	STATE Mo.	ZIP CODE 64801

10. I certify that I am familiar with the information contained in the application, that to the best of my knowledge and belief such information is true, complete and accurate, and if granted this permit, I agree to abide by the Missouri Clean Water Law and all rules, regulations, orders and decisions, subject to any legitimate appeal available to applicant under the Missouri Clean Water Law to the Missouri Clean Water Commission.

NAME AND OFFICIAL TITLE (TYPE OR PRINT) CHARLES SMITH V.P. MIDWEST OPERATIONS	TELEPHONE WITH AREA CODE 417 358-8104
SIGNATURE <i>Charles Smith</i>	DATE SIGNED 05-10-2013

MO 780-1479 (01-09)

BEFORE MAILING, PLEASE ENSURE ALL SECTIONS ARE COMPLETED AND ADDITIONAL FORMS, IF APPLICABLE, ARE INCLUDED.

Submittal of an incomplete application may result in the application being returned.

HAVE YOU INCLUDED:

- Appropriate Fees?
- Map at 1" = 2000' scale?
- Signature?
- Form C, if applicable?
- Form D, if applicable?
- Form 2F, if applicable?
- Form I (Irrigation), if applicable?
- Form R (Sludge), if applicable?





001



004

003

002


005

DAVINCI

200 ft

2843091.85 340924.44

I-49
COUNTY Rd.
OUTFALL
LOCATION
RECEIVING
STREAM
I-44




RECEIVED
MAY 2013
JFQ/SWRD



ALLGEIER, MARTIN & ASSOCIATES, INC.
CONSULTING ENGINEERS & SURVEYORS
JOPLIN, MISSOURI

NPDES
MULTIFC

DRAFT



SOURCE: DeLone, Street Atlas USA

LEGAL DESCRIPTION

Scale

1 inch = 0.49 mile

SITE LOCATION

ENSR

ENSR Consulting and Engineering


FIGURE 1-1

Site Location Map

Windsor Foods
5691 & 5695 Davinci Lane
Carthage, Missouri 64836

DRAWN: TMS	DATE: June 4, 1999	PROJECT NO.: REV
FILE 6994 104	CHECKED:	6994-109





MISSOURI DEPARTMENT OF NATURAL RESOURCES
 WATER PROTECTION PROGRAM, WATER POLLUTION BRANCH
 (SEE MAP FOR APPROPRIATE REGIONAL OFFICE)
FORM H - REQUEST FOR TERMINATION OF A GENERAL PERMIT



UNDER MI **AP ID 15502**
 1.00 TYPE OF GENERAL PERMIT REQUESTED TO BE TERMINATED
 Stormwater Permit

1.10 PERMIT NUMBER
MO - 130150

2.00 FACILITY

NAME Windsor Foods COUNTY Jasper

ADDRESS 5691 S. Davinci Lane CITY Carthage STATE Mo. ZIP CODE 64836

3.00 OWNER

NAME Windsor Foods E-MAIL David.Loyd@Windsorfoods.com PHONE (417) 358-8104
 FAX (417) 359-9389

ADDRESS 5691 S. Davinci Lane CITY Carthage STATE Mo. ZIP CODE 64836

4.00 CONTINUING AUTHORITY

NAME Windsor Foods PHONE (713) 843-5200
 FAX (713) 960-9709

ADDRESS 3355 W. Alabama CITY Houston STATE TX. ZIP CODE 77098

5.00 REASON FOR TERMINATION REQUEST: (CHECK ONE)

For land disturbance sites, area is stabilized by seeding, mulching, sodding, paving, or other means, no further land disturbance activities are planned, all building construction (commercial or residential) is completed, and construction equipment removed.

For industrial facilities, site activities have ceased and site closed and no significant materials remain exposed to storm water.


For any type of site, a site specific permit was obtained.

Other reason (specify) **Site specific permit MO-0002470 includes the conditions AND requirements of the facility's general stormwater permit # MO-R130150.**

6.00 I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THE TERMINATION REQUEST, THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE, COMPLETE AND ACCURATE.

NAME AND OFFICIAL TITLE (TYPE OR PRINT) **CHARLES SMITH** TELEPHONE NO. **417 358-8104**
V. P. MIDWEST OPERATIONS (AREA CODE)

SIGNATURE **Charles Smith** DATE SIGNED **05-10-2013**



MISSOURI DEPARTMENT OF NATURAL RESOURCES
 WATER PROTECTION PROGRAM, WATER POLLUTION BRANCH
FORM C – APPLICATION FOR DISCHARGE PERMIT –
MANUFACTURING, COMMERCIAL, MINING,
SILVICULTURE OPERATIONS, PROCESS & STORM WATER

FOR AGENCY USE ONLY	
CHECK NO.	
DATE RECEIVED	FEE SUBMITTED

NOTE: DO NOT ATTEMPT TO COMPLETE THIS FORM BEFORE READING THE ACCOMPANYING INSTRUCTIONS

1.00 NAME OF FACILITY
 Windsor Foods

1.10 THIS FACILITY IS NOW IN OPERATION UNDER MISSOURI OPERATING PERMIT NUMBER
 MO-0002470

1.20 THIS IS A NEW FACILITY AND WAS CONSTRUCTED UNDER MISSOURI CONSTRUCTION PERMIT NUMBER (COMPLETE ONLY IF THIS FACILITY DOES NOT HAVE AN OPERATING PERMIT).

2.00 LIST THE STANDARD INDUSTRIAL CLASSIFICATION (SIC) CODES APPLICABLE TO YOUR FACILITY (FOUR DIGIT CODE)

A. FIRST 2038 Frozen Specialty Food Manufacturing B. SECOND _____

C. THIRD _____ D. FOURTH _____

2.10 FOR EACH OUTFALL GIVE THE LEGAL DESCRIPTION.

OUTFALL NUMBER (LIST) NW 1/4 SE 1/4 SEC 33 T 28N R 31 Jasper COUNTY

001, 002, 003, 004, 005

ALLOW 7.1

2.20 FOR EACH OUTFALL LIST THE NAME OF THE RECEIVING WATER

OUTFALL NUMBER (LIST)	RECEIVING WATER
# 001, 002, 003, 004, 005	All to Tributary to Center Creek

2.30 BRIEFLY DESCRIBE THE NATURE OF YOUR BUSINESS
 Processing of prepared meat products , & frozen vegetable & cheese appetizer products.



2.40 CONTINUED

C. EXCEPT FOR STORM RUNOFF, LEAKS OR SPILLS, ARE ANY OF THE DISCHARGES DESCRIBED IN ITEMS A OR B INTERMITTENT OR SEASONAL?

YES (COMPLETE THE FOLLOWING TABLE) NO (GO TO SECTION 2.50)

1. OUTFALL NUMBER (list)	2. OPERATION(S) CONTRIBUTING FLOW (list)	3. FREQUENCY		4. FLOW				C. DURATION (in days)
		A. DAYS PER WEEK (specify average)	B. MONTHS PER YEAR (specify average)	A. FLOW RATE (in mgd)		B. TOTAL VOLUME (specify with units)		
				1. LONG TERM AVERAGE	2. MAXIMUM DAILY	4. LONG TERM DAILY	3. MAXIMUM AVERAGE	

2.50 MAXIMUM PRODUCTION

A. DOES AN EFFLUENT GUIDELINE LIMITATION PROMULGATED BY EPA UNDER SECTION 304 OF THE CLEAN WATER ACT APPLY TO YOUR FACILITY?

YES (COMPLETE B.) NO (GO TO SECTION 2.60)

B. ARE THE LIMITATIONS IN THE APPLICABLE EFFLUENT GUIDELINES EXPRESSED IN TERMS OF PRODUCTION (OF OTHER MEASURE OF OPERATION)?

YES (COMPLETE c.) NO (GO TO SECTION 2.60)

C. IF YOU ANSWERED "YES" TO B. LIST THE QUANTITY THAT REPRESENTS AN ACTUAL MEASUREMENT OF YOUR MAXIMUM LEVEL OF PRODUCTION, EXPRESSED IN THE TERMS AND UNITS USED IN THE APPLICABLE EFFLUENT GUIDELINE AND INDICATE THE AFFECTED OUTFALLS.

1. MAXIMUM QUANTITY			2. AFFECTED OUTFALLS (list outfall numbers)
A. QUANTITY PER DAY	B. UNITS OF MEASURE	C. OPERATION, PRODUCT, MATERIAL, ETC. (specify)	



2.60 IMPROVEMENTS

A. ARE YOU NOW REQUIRED BY ANY FEDERAL, STATE OR LOCAL AUTHORITY TO MEET, ANY IMPLEMENTATION SCHEDULE FOR THE CONSTRUCTION, UPGRADING OR OPERATION OF WASTEWATER TREATMENT EQUIPMENT OR PRACTICES OR ANY OTHER ENVIRONMENTAL PROGRAMS THAT MAY AFFECT THE DISCHARGES DESCRIBED IN THIS APPLICATION? THIS INCLUDES, BUT IS NOT LIMITED TO, PERMIT CONDITIONS, ADMINISTRATIVE OR ENFORCEMENT ORDERS, ENFORCEMENT COMPLIANCE SCHEDULE LETTERS, STIPULATIONS, COURT ORDERS AND GRANT OR LOAN CONDITIONS.

YES (COMPLETE THE FOLLOWING TABLE) NO (GO TO 3.00)

1. IDENTIFICATION OF CONDITION AGREEMENT, ETC.	2. AFFECTED OUTFALLS		3. BRIEF DESCRIPTION OF PROJECT	4. FINAL COMPLIANCE DATE	
				A. REQUIRED	B. PROJECTED

B. OPTIONAL: YOU MAY ATTACH ADDITIONAL SHEETS DESCRIBING ANY ADDITIONAL WATER POLLUTION CONTROL PROGRAMS (OR OTHER ENVIRONMENTAL PROJECTS THAT MAY AFFECT YOUR DISCHARGES) YOU NOW HAVE UNDER WAY OR ARE YOU PLANNING. INDICATE WHETHER EACH PROGRAM IS NOW UNDER WAY OR PLANNED, AND INDICATE YOUR ACTUAL OR PLANNED SCHEDULES FOR CONSTRUCTION.

MARK "X" IF DESCRIPTION OF ADDITIONAL CONTROL PROGRAMS IS ATTACHED.

3.10 BIOLOGICAL TOXICITY TESTING DATA

DO YOU HAVE ANY KNOWLEDGE OR REASON TO BELIEVE THAT ANY BIOLOGICAL TEST FOR ACUTE OR CHRONIC TOXICITY HAS BEEN MADE ON ANY OF YOUR DISCHARGES OR ON RECEIVING WATER IN RELATION TO YOUR DISCHARGE WITHIN THE LAST THREE YEARS?

YES (IDENTIFY THE TEST(S) AND DESCRIBE THEIR PURPOSES BELOW.) NO (GO TO 3.20)



3.20 CONTRACT ANALYSIS INFORMATION

WERE ANY OF THE ANALYSES REPORTED PERFORMED BY A CONTRACT LABORATORY OR CONSULTING FIRM?

YES (LIST THE NAME, ADDRESS AND TELEPHONE NUMBER OF AND POLLUTANTS ANALYZED BY EACH SUCH LABORATORY OR FIRM BELOW.) NO (GO TO 3.30)

A. NAME	B. ADDRESS	C. TELEPHONE (area code and number)	D. POLLUTANTS ANALYZED (list)
CSA LABOATORIES	1708 South 26th Street Rogers, AR. 72758	(479) 631-0410	BOD TSS pH NH3-N Oil & Grease Temperature D.O. Fecal

3.30 CERTIFICATION

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this application and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the information is true, accurate and complete. I am aware there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

NAME AND OFFICIAL TITLE (TYPE OR PRINT) CHARLES SMITH V.P. MIDWEST OPERATIONS	TELEPHONE NUMBER WITH AREA CODE 417-358-8104
SIGNATURE (SEE INSTRUCTIONS) <i>Charles Smith</i>	DATE SIGNED 05-10-2013

C S A Laboratories

C S A Laboratories (479) 631-0410

1708 South 26th Street Rogers, AR 72758

Client: **Windsor Foods**

Sample Location: **Effluent Outfall**

Sample Collection Date: 07/11-12/2012

07/12/2012

Date of Sample Receipt: 07/12/2012

Time: 08:00

Grab: 09:50

Lab Number: 0712079

Date of Report: 07/17/2012

Sample Collected by: Gene Grassle

Sample Delivered by: Gene Grassle

Parameter	Concentration	Units	Analysis		Analyst	Method	Page	Preserved	Sample Type	Prec.	Acc
			Date	Time							
pH	6.88	S.U.	07/12/2012	09:50	G2	STM18	4500H	Yes	Grab	0.000	
BOD	1.67	mg/L	07/12/2012	15:35	G2	STM18	5210B	Yes	Comp	1.932	98.33
TSS	5.4	mg/L	07/12/2012	14:00	G2	STM18	5540D	Yes	Comp	0.593	
NH₃-N	0.0978	mg/L	07/13/2012	17:00	G2	STM18	5210B	Yes	Grab	1.751	102.09
Oil & Grease	< 1	mg/L	07/12/2012	17:00	G2	STM18	5520B	Yes	Comp	0.379	99.17
F. Coliform	46	cfu/100ml	07/12/2012	11:05	G2	STM18		Yes	Grab		
Temperature	32.2	deg C	07/12/2012	09:50	G2	STM18	2550B	Yes	Grab		
D.O.	7.06	mg/L	07/12/2012	09:50	G2	STM18	4500OC	Yes	Grab		



Sampling and analyses are conducted according to the guidelines set forth in the Methods for Chemical Analysis of Water and Wastes (March 1979). Standard Methods 18th edition (1992). All reports are submitted to clients on a confidential basis. No reference to the results or the work performed will be released without written authorization from our clients. A minimum of 10% duplicate and spiked analyses are performed on a routine basis. All instruments are calibrated daily or prior to use.

Signature

Client: **Windsor Foods**

Sample Location: **Effluent Outfall**

Sample Collection Date: 09/05-06/2012 Time: 08:00

09/06/2012 Grab: 08:05

Date of Sample Receipt: 09/06/2012

Lab Number: 0912029

Date of Report: 09/11/2012

Sample Collected by: Gene Grassle

Sample Delivered by: Gene Grassle

Parameter	Concentration	Units	Analysis		Analyst	Method	Page	Preserved	Sample Type	Prec.	Acc
			Date	Time							
pH	6.90	S.U.	09/06/2012	08:05	G2	STM18	4500H	Yes	Grab	0.000	
BOD	3.53	mg/L	09/06/2012	14:30	G2	STM18	5210B	Yes	Comp	1.061	98.35
TSS	10.0	mg/L	09/06/2012	17:30	G2	STM18	5540D	Yes	Comp	0.000	
NH₃-N	0.0332	mg/L	09/07/2012	14:00	G2	STM18	5210B	Yes	Grab	0.331	102.21
Oil & Grease	< 1	mg/L	09/06/2012	07:00	G2	STM18	5520B	Yes	Grab	0.381	99.19
F. Coliform Temperature	40	cfu/100ml	09/06/2012	11:10	G2	STM18		Yes	Grab		
	22.4	deg C	09/06/2012	08:05	G2	STM18	2550B	Yes	Grab		
D.O.	7.82	mg/L	09/06/2012	08:05	G2	STM18	4500OC	Yes	Grab		



Sampling and analyses are conducted according to the guidelines set forth in the Methods for Chemical Analysis of Water and Wastes (March 1979). Standard Methods 18th edition (1992). All reports are submitted to clients on a confidential basis. No reference to the results or the work performed will be released without written authorization from our clients. A minimum of 10% duplicate and spiked analyses are performed on a routine basis. All instruments are calibrated daily or prior to use.

Signature

PLEASE PRINT OR TYPE. You may report some or all of this information on separate sheet instead of completing these pages.
 (Use the same format)
 SEE INSTRUCTIONS

FORM C
 TABLE 1 FOR 3.00 ITEM A AND B

INTAKE AND EFFLUENT CHARACTERISTICS

OUTFALL NO.
 001

PART A - You must provide the results of at least one analysis for every pollutant in this table. Complete one table for each outfall. See instructions for additional details.

1. POLLUTANT	A. MAXIMUM DAILY VALUE		B. MAXIMUM 30 DAY VALUE <i>(if available)</i>		C. LONG TERM AVRG. VALUE <i>(if available)</i>		D. NO. OF ANALYSES	3. UNITS <i>(specify if blank)</i>			4. INTAKE <i>(optional)</i>		B. NO. OF ANALYSES
	(1) CONCENTRATION	(2) MASS	(1) CONCENTRATION	(2) MASS	(1) CONCENTRATION	(2) MASS		A. CONCENTRATION	B. MASS	(1) CONCENTRATION	(2) MASS		
A. Biochemical Oxygen Demand (BOD)	SEE		3.53				1						
B. Chemical Oxygen Demand (COD)	ATTACHED						1						
C. Total organic Carbon (TOC)	RESULTS						1						
D. Total Suspended Solids (TSS)	FROM		10.0				1						
E. Ammonia (as N)	CSA LAB		0.0332				1						
F. Flow	VALUE		VALUE		VALUE		1			VALUE			
G. Temperature (winter)	VALUE		VALUE 22.4		VALUE		1			VALUE			
H. Temperature (summer)	VALUE		VALUE 32.2		VALUE		1			VALUE			
I. pH	MINIMUM	MAXIMUM	MINIMUM 6.88	MAXIMUM			1						

PART B - Mark "X" in column 2-a for each pollutant you know or have reason to believe is present. Mark "X" in column 2-b for each pollutant you believe to be absent. If you mark column 2-a for any pollutant, you must provide the results for at least one analysis for that pollutant. Complete one table for each outfall. See the instructions for additional details and requirements.

1. POLLUTANT AND CAS NUMBER <i>(if available)</i>	2. MARK "X"		3. EFFLUENT				4. UNITS			5. INTAKE <i>(optional)</i>		B. NO. OF ANALYSES	
	A. BELIEVED PRESENT	B. BELIEVED ABSENT	A. MAXIMUM DAILY VALUE (1) CONCENTRATION	(2) MASS	B. MAXIMUM 30 DAY VALUE <i>(if available)</i>	(1) CONCENTRATION	(2) MASS	C. LONG TERM AVRG. VALUE <i>(if available)</i>	(1) CONCENTRATION	(2) MASS	A. CONCENTRATION		B. MASS
A. Bromide (24959-67-9)													
B. Chlorine Total Residual													
C. Color													
D. Fecal Coliform	X		46										
E. Fluoride (16984-48-8)													
F. Nitrate-Nitrate (as N)							1						



1. POLLUTANT AND CAS NUMBER (if available)	2. MARK "X"		3. EFFLUENT						4. UNITS		5. INTAKE (optional)			
	A. BELIEVED PRESENT	B. BELIEVED ABSENT	A. MAXIMUM DAILY VALUE		B. MAXIMUM 30 DAY VALUE		C. LONG TERM AVRG. VALUE		D. NO. OF ANALYSES	A. CONCENTRATION	B. MASS	A. LONG TERM AVRG. VALUE		B. NO. OF ANALYSES
			(1) CONCENTRATION	(2) MASS	(1) CONCENTRATION	(2) MASS	(1) CONCENTRATION	(2) MASS				(1) CONCENTRATION	(2) MASS	
G. Nitrogen Total Organic (as N)		X							1					
H. Oil and Grease	X		<1						1					
I. Phosphorus (as P) Total (7723-14-0)		X												
J. Sulfate (as SO ₄) (14808-79-8)		X												
K. Sulfide (as S)		X												
L. Sulfite (as SO ₃) (14265-45-3)		X												
M. Surfactants		X												
N. Aluminum Total (7429-90-5)		X												
O. Barium Total (7440-39-3)		X												
P. Boron Total (7440-42-8)		X												
Q. Cobalt Total (7440-48-4)		X												
R. Iron Total (7439-89-6)		X												
S. Magnesium Total (7439-95-4)		X												
T. Molybdenum Total (7439-98-7)		X												
U. Manganese Total (7439-96-5)		X												
V. Tin Total (7440-31-5)		X												
W. Titanium Total (7440-32-6)		X												



1. POLLUTANT AND CAS NUMBER <i>(if available)</i>	2. MARK "X"		3. EFFLUENT						4. UNITS		5. INTAKE <i>(optional)</i>		B. NO. OF ANALYSES
	A. BELIEVED PRESENT	B. BELIEVED ABSENT	A. MAXIMUM DAILY VALUE		B. MAXIMUM 30 DAY VALUE		C. LONG TERM AVRG. VALUE		A. CONCENTRATION	B. MASS	A. LONG TERM AVRG. VALUE	(2) MASS	
			(1) CONCENTRATION	(2) MASS	(1) CONCENTRATION	(2) MASS	(1) CONCENTRATION	(2) MASS					
METALS, AND TOTAL PHENOLS													
1M. Antimony, Total (7440-36-9)		X											
2M. Beryllium, Total (7440-41-7)		X											
3M. Magnesium, Total (7439-95-4)		X											
4M. Molybdenum, Total (7439-98-7)		X											
5M. Tin, Total (7440-31-5)		X											
6M. Titanium, Total (7440-32-6)		X											
7M. Mercury, Total (7439-97-6)		X											
8M. Selenium, Total (7782-49-2)		X											
9M. Thallium, Total (7440-28-0)		X											
10M. Phenols, Total		X											
RADIOACTIVITY													
(1) Alpha Total		X											
(2) Beta Total		X											
(3) Radium Total		X											
(4) Radium 226 Total		X											

