

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION



CONSTRUCTION PERMIT

The Missouri Department of Natural Resources hereby issues a permit to:

NRW Management, LLC
ATTN: Norbert Werdehausen
615 South Summit Drive
Holts Summit, MO 65043

for the construction of (described facilities):

See attached.

Permit Conditions:

See attached.

Construction of such proposed facilities shall be in accordance with the provisions of the Missouri Clean Water Law, Chapter 644, RSMo, and regulation promulgated thereunder, or this permit may be revoked by the Department of Natural Resources (Department).


As the department does not examine structural features of design or the efficiency of mechanical equipment, the issuance of this permit does not include approval of these features.

A representative of the department may inspect the work covered by this permit during construction. Issuance of a permit to operate by the department will be contingent on the work substantially adhering to the approved plans and specifications.

This permit applies only to the construction of water pollution control components; it does not apply to other environmentally regulated areas.

April 10, 2015
Effective Date

April 9, 2016
Expiration Date


Sara Parker Pauley, Director, Department of Natural Resources


John Madras, Director, Water Protection Program

CONSTRUCTION PERMIT

I. CONSTRUCTION DESCRIPTION

Installation of addition of one Norweco Bio-Dynamic Model XT 4000-S tablet chlorinator, minimum 370-gallon baffled concrete chlorine contact chamber, one construct in place tablet dechlorinator, and all the necessary appurtenances to make the facilities complete and usable. This wastewater treatment facility is to serve 47 mobile homes in El Dorado Estates Mobile Home Park. The design flow is 10,600 gallons per day with a population equivalent (PE) of 141.

II. FINDING OF AFFORDABILITY

The Finding of Affordability is not applicable. The permittee is not a combined or separate sanitary sewer system or a publicly owned treatment works.

III. CONSTRUCTION PERMIT CONDITIONS

The permittee is authorized to construct subject to the following conditions:

1. This construction permit does not authorize discharge.
2. All construction shall be in accordance with the plans and specifications submitted by Engineering Surveys & Services on March 4, 2015.
3. The department must be contacted in writing prior to making any changes to the approved plans and specifications that would directly or indirectly have an impact on the capacity, flow, system layout, or reliability of the proposed wastewater treatment facilities or any design parameter that is addressed by 10 CSR 20-8, in accordance with 10 CSR 20-8.110(8).
4. State and federal law does not permit bypassing of raw wastewater, therefore steps must be taken to ensure that raw wastewater does not discharge during construction. If a sanitary sewer overflow or bypass occurs, report the appropriate information to the department's Northeast Regional Office per 10 CSR 20-7.015(9)(E)2.
5. This construction permit is invalid for projects required to comply with the requirements contained in 10 CSR 20-4, "Grants and Loans"
6. Protection of drinking water supplies shall be in accordance with 10 CSR 20-8.120(10). "There shall be no physical connections between a public or private potable water supply system and a sewer, or appurtenance thereto which would permit the passage of any wastewater or polluted water into the potable supply. No water pipe shall pass through or come in contact with any part of a sewer manhole."
 - A. Sewers in relation to water works structures shall meet the requirements of 10 CSR 23-3.010 with respect to minimum distances from public water supply wells or other water supply sources and structures.

- B.** Sewer mains shall be laid at least 10 feet horizontally from any existing or proposed water main. The distances shall be measured edge-to-edge. In cases where it is not practical to maintain a 10 foot separation, the department may allow a deviation on a case-by-case basis, if supported by data from the design engineer. Such a deviation may allow installation of the sewer closer to a water main, provided that the water main is in a separate trench or on an undisturbed earth shelf located on either side of the sewer and at an elevation so the bottom of the water main is at least 18 inches above the top of the sewer. If it is impossible to obtain proper horizontal and vertical separation as described above for sewers, the sewer must be constructed of slip-on or mechanical joint pipe or continuously encased and be pressure tested to 150 pounds per square inch to assure water tightness.
 - C.** Manholes should be located at least 10 feet horizontally from any existing or proposed water main.
 - D.** Sewers crossing water mains shall be laid to provide a minimum vertical distance of 18 inches between the outside of the water main and the outside of the sewer. This shall be the case where the water main is either above or below the sewer. The crossing shall be arranged so that the sewer joints will be equidistant and as far as possible from the water main joints. Where a water main crosses under a sewer, adequate structural support shall be provided for the sewer to maintain line and grade. When it is impossible to obtain proper vertical separation as stipulated above, one of the following methods must be specified:

 - a. The sewer shall be designed and constructed equal to the water pipe and shall be pressure tested to assure water tightness prior to backfilling; or
 - b. Either the water main or sewer line may be continuously encased or enclosed in a watertight carrier pipe which extends 10 feet on both sides of the crossing, measured perpendicular to the water main. The carrier pipe shall be of materials approved by the department for use in water main construction.
7. In addition to the requirements for a construction permit, 10 CSR 20-6.200 requires land disturbance activities of one acre or more to obtain a Missouri state operating permit to discharge stormwater. The permit requires best management practices sufficient to control runoff and sedimentation to protect waters of the state. Land disturbance permits will only be obtained by means of the department's ePermitting system available online at www.dnr.mo.gov/env/wpp/epermit/help.htm. See www.dnr.mo.gov/env/wpp/stormwater/sw-land-disturb-permits.htm for more information.
8. A United States (U.S.) Army Corps of Engineers (COE) permit (404) and a Water Quality Certification (401) issued by the department or permit waiver may be required for the activities described in this permit. This permit is not valid until these requirements are satisfied. If construction activity will disturb any land below the ordinary high water mark of jurisdictional waters of the U.S. then a 404/401 will be required. Since the COE makes determinations on what is jurisdictional, you must contact the COE to determine permitting requirements. You may call the department's Water Protection Program at 573-751-1300 for more information. See www.dnr.mo.gov/env/wpp/401/ for more information.

9. Upon completion of construction;
 - A. The owner will remain the continuing authority for operation, maintenance, and modernization of these facilities;
 - B. Submit the enclosed form Statement of Work Completed to the department in accordance with 10 CSR 20-6.010(5)(D);
 - C. Submit an electronic copy of the as built if the project was not constructed in accordance with previously submitted plans and specifications; and
 - D. Submit a Form B - Application for an Operating Permit for Domestic or Municipal Wastewater ($\leq 100,000$ gallons per day) along with the modification fee.

IV. REVIEW SUMMARY

1. AMMONIA

The Water Protection Program is providing this notice to inform permittees that EPA's published ammonia criteria for aquatic life protection is lower than the current Missouri criteria and will be proposed in the 2014 Missouri Water Quality Standards triennial review. More information can be found at <http://dnr.mo.gov/pubs/pub2481.pdf>.

The owner intends to operate the existing treatment facility so as to comply with both current and future ammonia discharge limits.

2. CONSTRUCTION PURPOSE

Facility is installing chlorine disinfection and dechlorination to comply with *E. Coli* effluent limitations in current operating permit.

3. FACILITY DESCRIPTION

Facility is an existing extended aeration package treatment plant. Proposed construction is to add disinfection and dechlorination.

4. COMPLIANCE PARAMETERS

Facility has reported occasional exceedances in permitted limitations: BOD – 6/11, 3/13, 6/13, and 1/14; and TSS – 4/10, 6/11, 3/13, 4/13, 5/13, 6/13, 12/13, 1/14, and 2/14. Facility has not submitted Discharge Monitoring Report data for *E. Coli*. Disinfection is proposed to meet the 126 colonies per 100 milliliters monthly average limit for *E. Coli* as a geometric mean. The BOD and TSS violations are being resolved by the new owner with improved operation and maintenance.

5. REVIEW of MAJOR TREATMENT DESIGN CRITERIA

The submittal proposes tablet feeders for chlorination and dechlorination, and a baffled chlorine contact tank. The design flow of the treatment plant was reduced to 10,600 gallons per day due peak flow capacity of the proposed 370-gallon chlorine contact tank.

6. OPERATING PERMIT MODIFICATION


Draft Missouri State Operating Permit MO-0101052, which reflects this proposed construction, is anticipated to be placed on the public notice for public comments on April 17, 2015. The comment period will continue for 30 days.

Operating permit MO-0101052 will require a modification to reflect the construction activities. Upon construction completion, submit a \$250 modification fee and Form B - Application for an Operating Permit for Domestic or Municipal Wastewater ($\leq 100,000$ gallons per day).

Keith Forck, P.E.
Engineering Section
keith.forck@dnr.mo.gov

RECEIVED

CP 0001 10 / 11001111000
AP 20687 C 14453
FOR DEPARTMENT USE ONLY
APP NO. CP NO.
FEE RECEIVED 51000.00 CHECK NO. 1954
DATE RECEIVED 2-23-15



MISSOURI DEPARTMENT OF NATURAL RESOURCES
WATER PROTECTION PROGRAM
APPLICATION FOR CONSTRUCTION PERMIT FEB 23 2015
WASTEWATER TREATMENT FACILITY

WATER PROTECTION PROGRAM

APPLICATION OVERVIEW

The Application for Construction Permit – Wastewater Treatment Facility form has been developed in a modular format and consists of Part A and B. All applicants must complete Part A. Part B should be completed for applicants who currently land-apply wastewater or propose land application for wastewater treatment. Please read the accompanying instructions before completing this form. Submittal of an incomplete application may result in the application being returned.

PART A – BASIC INFORMATION

1.0 APPLICATION INFORMATION (Note – If any of the questions in this section are answered NO, this application may be considered incomplete and returned.)

- 1.1 Is this a Federal/State funded project? YES N/A Funding Agency: _____ Project #: _____
- 1.2 Has the Missouri Department of Natural Resources approved the proposed project's antidegradation review?
 YES Date of Approval: _____ N/A - antidegradation does not apply
- 1.3 Has the department approved the proposed project's facility plan*?
 YES Date of Approval: _____ NO N/A (If Not Applicable, complete No. 1.4.)
- 1.4 [Complete only if answered Not Applicable on No. 1.3.] Is a copy of the engineering report* for wastewater treatment facilities with a design flow less than 22,500 gpd included with this application?
 YES NO
- 1.5 Is a copy of the appropriate plans* and specifications* included with this application?
 YES Denote which form is submitted: Hard copy Electronic copy (See instructions.) NO
- 1.6 Is a summary of design* included with this application? YES NO
- 1.7 Has the appropriate operating permit application (A, B, or B2) been submitted to the department?
 YES Date of submittal: _____
 Enclosed is the appropriate operating permit application submittal. Denote which form: A B B2
 N/A Please explain: _____
- 1.8 Is the facility currently under enforcement with the department or the Environmental Protection Agency? YES NO
- 1.9 Is the appropriate fee included with this application? YES NO (See instructions for appropriate fee.)

* Must be affixed with a Missouri registered professional engineer's seal, signature and date.

2.0 PROJECT INFORMATION

2.1 NAME OF PROJECT

El Dorado Estates Mobile Home Park WWTP Disinfection Upgrades

2.2 PROJECT DESCRIPTION

Upgrade existing 15,000 GPD WWTP system with a tablet chlorination / tablet dechlorination disinfection system to meet current regulations.

2.3 SLUDGE HANDLING, USE AND DISPOSAL DESCRIPTION

Sludge is disposed of by a contract hauler.

2.4 DESIGN INFORMATION

- A. Current population: _____; Design population: 187 PE
- B. Actual Flow: 9,580 gpd; Design Average Flow: 15,000 gpd;
Actual Peak Daily Flow: _____ gpd; Design Maximum Daily Flow: _____ gpd; Design Wet Weather Event: _____

2.5 ADDITIONAL INFORMATION

- A. Is a topographic map attached? YES NO
- B. Is a process flow diagram attached? YES NO

3.0 WASTEWATER TREATMENT FACILITY

NAME El Dorado Estates WWTP		TELEPHONE NUMBER WITH AREA CODE 573-353-1346	E-MAIL ADDRESS	
ADDRESS (PHYSICAL) 4200 Mac Road	CITY Fulton	STATE MO	ZIP CODE 65251	COUNTY Callaway

Wastewater Treatment Facility: Mo- 0101052 (Outfall 1 Of 1)

3.1 Legal Description: SW ¼, SW ¼, _____ ¼, Sec. 28, T 48N, R 9W
(Use additional pages if construction of more than one outfall is proposed.)3.2 UTM Coordinates Easting (X): 591743 Northing (Y): 4306470
For Universal Transverse Mercator (UTM), Zone 15 North referenced to North American Datum 1983 (NAD83)

3.3 Name of receiving streams: _____ Unnamed Tributary to Richland Creek

4.0 PROJECT OWNER

NAME NRW Management LLC		TELEPHONE NUMBER WITH AREA CODE (573) 353-1346	E-MAIL ADDRESS	
ADDRESS 615 South Summit Drive	CITY Holts Summit	STATE MO	ZIP CODE 65043	

5.0 CONTINUING AUTHORITY: Permanent organization that will serve as the continuing authority for the operation, maintenance and modernization of the wastewater collection system.

NAME NRW Management LLC		TELEPHONE NUMBER WITH AREA CODE (573) 353-1346	E-MAIL ADDRESS	
ADDRESS 615 South Summit Drive	CITY Holts Summit	STATE MO	ZIP CODE 65043	

5.1 A letter from the continuing authority, if different than the owner, is included with this application. YES NO N/A


5.2 COMPLETE THE FOLLOWING IF THE CONTINUING AUTHORITY IS A MISSOURI PUBLIC SERVICE COMMISSION REGULATED ENTITY.

A. Is a copy of the certificate of convenience and necessity included with this application? YES NO

5.3 COMPLETE THE FOLLOWING IF THE CONTINUING AUTHORITY IS A PROPERTY OWNERS ASSOCIATION.

A. Is a copy of the as-filed restrictions and covenants included with this application? YES NOB. Is a copy of the as-filed warranty deed, quitclaim deed or other legal instrument which transfers ownership of the land for the wastewater treatment facility to the association included with this application? YES NOC. Is a copy of the as-filed legal instrument (typically the plat) that provides the association with valid easements for all sewers included with this application? YES NOD. Is a copy of the Missouri Secretary of State's nonprofit corporation certificate included with this application? YES NO**6.0 ENGINEER**

ENGINEER NAME / COMPANY NAME David A. Bennett / Engineering Surveys and Services		TELEPHONE NUMBER WITH AREA CODE (573) 449-2646	E-MAIL ADDRESS dbennett@ess-inc.com	
ADDRESS 1113 Fay Street	CITY Columbia	STATE MO	ZIP CODE 65201	

7.0 PROJECT OWNER: I hereby certify that I am familiar with the information contained in this application and to the best of my knowledge and belief such information is true, complete, and accurate, and if granted this permit, I agree to abide by the Missouri Clean Water Law and all rules, regulations, orders, and decisions, subject to any legitimate appeal available to applicant under Missouri Clean Water Law. I also understand the issuance of the construction permit does not guarantee the proposed wastewater treatment will meet the required effluent limitations of the issued Missouri State Operating Permit for this facility.PROJECT OWNER SIGNATURE
PRINTED NAME
Norbert WerdehausenDATE
2-19-15TITLE OR CORPORATE POSITION
Owner / MemberTELEPHONE NUMBER WITH AREA CODE
(573) 353-1346

E-MAIL ADDRESS

Mail completed copy to: MISSOURI DEPARTMENT OF NATURAL RESOURCES
WATER PROTECTION PROGRAM
P.O. BOX 176
JEFFERSON CITY, MO 65102-0176**END OF PART A.**
REFER TO THE APPLICATION OVERVIEW TO DETERMINE WHETHER PART B NEEDS TO BE COMPLETE.