

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES

Bob Holden, Governor • Stephen M. Mahfood, Director

www.dnr.mo.gov

JUN 21 2004

Mr. Scott Negley
Manager, Global Dispenser Products
Dresser Wayne, Dresser Inc.
3814 Jarret Way
Austin, TX 78728

APPROVAL LETTER

04-2

Dear Mr. Negley:

The Missouri Department of Natural Resources' Air Pollution Control Program (APCP) has received your letter dated May 17, 2004, in which you requested to add two new dispenser models to the line of Ovation dispenser models that have previously obtained MOPETP approval. These two additional models, B 12/2 and B 23/3, employ the same vapor recovery plumbing and product plumbing used in previously tested and approved Ovation dispenser models B 12/3 and B 23/4. However, the electronics and fascia of these new models has been modified as a result of the removal of one of the grade select buttons and one of the unit price displays from each of the dispenser models.

My staff has reviewed the information submitted with your letter and has determined that the modifications to the electronics and fascia of the dispensers will not adversely affect the efficiency of the vapor recovery components or their ability to work in conjunction with a Balance Vapor Recovery system. Therefore, the APCP hereby approves the equipment listed below for use on all approved Balance Vapor Recovery systems. This approval, however, is subject to the terms and conditions of the initial approval for the Ovation line of dispensers granted under MOPETP Approval APCP-0002-001-99.

Manufacturer	Model	Component
Dresser Wayne, Dresser Inc.	Ovation B 12/2,	Dispenser, 2 product
Dresser Wayne, Dresser Inc.	Ovation B 23/3	Dispenser, 3 product

Integrity and excellence in all we do




Mr. Scott Negley
Page Two

Staff of the APCP would like to thank you and Dresser Wayne, Dresser Inc. for your cooperation in this matter. If you have any questions concerning this issue, please contact Bud Pratt, of my staff, at the APCP, P.O. Box 176, Jefferson City, MO 65102-0176, or by telephone at (573) 751-4817.

Sincerely,

AIR POLLUTION CONTROL PROGRAM



Leanne Tippett Mosby
Director

LTM:bpt

c: Stage II List
Local Agencies