

BP
2/29/08

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES

Matt Blunt, Governor • Doyle Childers, Director

www.dnr.mo.gov

FEB 28 2008

Andy Speidel
Goodyear Engineered Products, Norfolk Hose Plant
Veyance Technologies Inc.
2701 West Omaha Ave
Norfolk, NE 68701-4421

Approval 2008-1


The Missouri Department of Natural Resources' Air Pollution Control Program has received your letter of February 11, 2008, requesting the separation of the evaluation for approvals of the Goodyear Maxxim Premier Plus balance hose, with spring loaded needle check valve, from the Premier LX series. The testing and evaluation continues to be conducted on the later group at the COSTCO/Husky test site.

The Technical Review Committee conducted an engineering review of the spring loaded needle check valve modification and determined that the modification to the valve, of the already approved Goodyear Maxxim Premier Plus balance hoses, would not adversely affect the vapor recovery efficiency. Therefore, please consider this letter as your approval of the new Goodyear Maxxim Premier Plus balance hoses, with spring loaded needle check valve. The part number for the Goodyear Maxxim Premier Plus balance hose with spring loaded needle check valve is 532-365-441-08030. Only eight foot balance hoses, and balance whip hoses are approved.

As all Missouri performance evaluation test procedure approvals are based on the previous CARB EVR approvals, all conditions and limitations of that certification are part of the Missouri performance evaluation test procedure approval. The program thanks you for your concern and cooperation to these issues. If you have any questions you may contact Bud Pratt at the department's Air Pollution Control Program, P.O. Box 176, Jefferson City, MO 65102-0176, or by telephone at (573) 751-4817.

Sincerely,

AIR POLLUTION CONTROL PROGRAM


James L. Kavanaugh
Director

c: All Stage II List