



Missouri Department of dnr.mo.gov

NATURAL RESOURCES

Michael L. Parson, Governor

Carol S. Comer, Director

November 16, 2020

Kyla Rudd
Environmental Project Manager
QuikTrip Kitchen & Distribution
822 QuikTrip Way
Belton, MO 64012

RE: New Source Review Permit Amendment - Permit Number: 062020-009A
Project Number: 2020-09-014; Installation Number: 037-0072

Dear Kyla Rudd:

In the application for permit 062020-009 dated April 10, 2020, QuikTrip Kitchen & Distribution requested that their Mitsubishi HTW 2000 T6U (EU-05) be permitted for 200 hours of non-emergency operation per year. QuikTrip Kitchen & Distribution later determined that their Mitsubishi HTW 2000 T6U (EU-05) could not meet the Tier requirements for its year of manufacturer that would allow it to be operated in a role other than emergency engine as defined in NSPS III. QuikTrip Kitchen & Distribution requested in an application dated September 11, 2020 that permit 062020-009 be amended to reflect the operation of Mitsubishi HTW 2000 T6U (EU-05) as an emergency engine. Special Condition 2 of this amendment restricts operation of the Mitsubishi HTW 2000 T6U (EU-05) to the NSPS III operating limits for emergency engines, which allows a maximum of 100 hours of non-emergency operation per calendar year. With the NSPS III limit potential emissions would not increase and the applicable type of permit would not change.

If you were adversely affected by this permit decision, you may be entitled to pursue an appeal before the administrative hearing commission pursuant to Sections 621.250 and 643.075.6 RSMo. To appeal, you must file a petition with the administrative hearing commission within thirty days after the date this decision was mailed or the date it was delivered, whichever date was earlier. If any such petition is sent by registered mail or certified mail, it will be deemed filed on the date it is mailed; if it is sent by any method other than registered mail or certified mail, it will be deemed filed on the date it is received by the administrative hearing commission, whose contact information is: Administrative Hearing Commission, United States Post Office Building, 131 West High Street, Third Floor, P.O. Box 1557, Jefferson City, Missouri 65102, phone: 573-751-2422, fax: 573-751-5018, website: www.oa.mo.gov/ahc.



Kyla Rudd
Page Two

If you have any questions regarding this amendment, please do not hesitate to contact Jared Rhodes, at the department's Air Pollution Control Program, P.O. Box 176, Jefferson City, MO 65102 or at (573) 751-4817. Thank you for your attention to this matter.

Sincerely,

AIR POLLUTION CONTROL PROGRAM

A handwritten signature in blue ink that reads "Kendall B. Hale". The signature is written in a cursive style.

Kendall B. Hale
Permits Section Chief

KBH:jara

Enclosures

c: Kansas City Regional Office
PAMS File: 2020-09-014

Page No.	3
Permit No.	062020-009A
Project No.	2020-09-014

SPECIAL CONDITIONS:

The permittee is authorized to construct and operate subject to the following special conditions:

The special conditions listed in this permit were included based on the authority granted the Missouri Air Pollution Control Program by the Missouri Air Conservation Law (specifically 643.075) and by the Missouri Rules listed in Title 10, Division 10 of the Code of State Regulations (specifically 10 CSR 10-6.060). For specific details regarding conditions, see 10 CSR 10-6.060 paragraph (3)(E). "Conditions required by permitting authority."

QuikTrip Kitchen & Distribution
Cass County, S1 and S12, T46N, R33W

1. **Superseding Condition**
The conditions of this amendment supersede the following special condition found in previously issued construction permits issued by the Air Pollution Control Program.

Table 1: List of Superseded Condition

Permit and Special Condition	Description of Condition
062020-009 Special Condition 2.B	Limiting non-emergency operation of Mitsubishi HTW 2000 T6U (EU-05) to 200 hours per year.

2. **Operational Limitation**
QuikTrip Kitchen & Distribution shall operate their Mitsubishi HTW 2000 T6U (EU-05) according to the requirements for emergency stationary internal combustion engines found in 40 CFR 60.4211(f).