LCS Number	Date Reading Collected	Measured Liquid Level Above Transducer (Ft.)	Transducer Height above Floor of Quarry (Ft.)	Base of Sump Elevation (Ft. MSL)	Elevation of Leachate (Ft. MSL)	Pump on during measurement? (Y/N)	Liquid level meter used	Comments
LCS- 1D	6/20/14	80.9	97.0	252.22	430.12	N	Dedicated Transducer	Not Running, Fault = HI CNT FLT
LCS- 1D	7/1/14	41.0	97.0	252.22	390.22	Y	Dedicated Transducer	
LCS- 1D	7/3/14	41.0	97.0	252.22	390.22	Y	Dedicated Transducer	
LCS- 1D	7/10/14	41.0	97.0	252.22	390.22	Y	Dedicated Transducer	
LCS- 1D	7/18/14	41.0	97.0	252.22	390.22	Y	Dedicated Transducer	
LCS- 1D	7/25/14	43.0	97.0	252.22	392.22	Y	Dedicated Transducer	
LCS- 1D	8/1/14	43.0	97.0	252.22	392.22	Y	Dedicated Transducer	
LCS- 1D	8/8/14	43.0	97.0	252.22	392.22	Y	Dedicated Transducer	
LCS- 1D	8/15/14	45.0	97.0	252.22	394.22	Y	Dedicated Transducer	
LCS- 1D	8/22/14	45.0	97.0	252.22	394.22	Y	Dedicated Transducer	
LCS- 1D	8/29/14					N	Dedicated Transducer	Not running, leak in bulkhead of well
LCS- 1D	9/5/14					N	Dedicated Transducer	Not running, leak in bulkhead of well
LCS- 1D	9/12/14	45.0	97.0	252.22	394.22	Y	Dedicated Transducer	
LCS- 1D	9/19/14	45.0	97.0	252.22	394.22	Y	Dedicated Transducer	
LCS- 1D	9/26/14	45.0	97.0	252.22	394.22	Y	Dedicated Transducer	
LCS- 1D	10/4/14	45.0	97.0	252.22	394.22	Y	Dedicated Transducer	
LCS- 1D	10/10/14	45.0	97.0	252.22	394.22	Y	Dedicated Transducer	
LCS- 1D	10/17/14	45.0	97.0	252.22	394.22	Y	Dedicated Transducer	
LCS- 1D	10/24/14	N/A	97.0	252.22			Dedicated Transducer	
LCS- 1D	10/31/14	N/A	97.0	252.22		Y	Dedicated Transducer	Tranducer is out
LCS- 1D	11/7/14	N/A	97.0	252.22		Y	Dedicated Transducer	Tranducer is out
LCS- 1D	11/14/14	N/A	97.0	252.22		Y	Dedicated Transducer	Tranducer is out
LCS- 1D	11/25/14	N/A	97.0	252.22		Y	Dedicated Transducer	Tranducer is out
LCS- 1D	12/2/14	N/A	97.0	252.22		Y	Dedicated Transducer	Tranducer is out
LCS- 1D	12/9/14	N/A	97.0	252.22		Y	Dedicated Transducer	Tranducer is out
LCS- 1D	12/15/14	N/A	97.0	252.22		Y	Dedicated Transducer	Tranducer is out
LCS- 1D	12/23/14	N/A	97.0	252.22		Y	Dedicated Transducer	Tranducer is out
LCS- 1D	12/31/14	N/A	97.0	252.22		Y	Dedicated Transducer	Tranducer is out
LCS- 1D	1/7/15	N/A	97.0	252.22		Y	Dedicated Transducer	Tranducer is out
LCS- 1D	1/14/15	N/A	97.0	252.22		Y	Dedicated Transducer	Tranducer is out
LCS- 1D	1/21/15	N/A	97.0	252.22		Y	Dedicated Transducer	Tranducer is out
LCS- 1D	1/28/15	N/A	97.0	252.22		Y	Dedicated Transducer	Tranducer is out
LCS- 1D	2/4/15	N/A	97.0	252.22		Y	Dedicated Transducer	Tranducer is out
LCS- 1D	2/11/15	N/A	97.0	252.22		Y	Dedicated Transducer	Tranducer is out
LCS- 1D	2/18/15	N/A	97.0	252.22		Y	Dedicated Transducer	Tranducer is out
LCS- 1D	2/25/15	N/A	97.0	252.22		Y	Dedicated Transducer	Tranducer is out
LCS- 1D	3/4/15	N/A	97.0	252.22		Y	Dedicated Transducer	Transducer Replaced, Cal in Progress
LCS- 1D	3/11/15	>97.0	97.0	252.22	<342.22	Y	Dedicated Transducer	Liquid Level Below Transducer@90ft
LCS- 1D	3/17/15	>97.0	97.0	252.22	<342.22	Y	Dedicated Transducer	Liquid Level Below Transducer@92.4'
LCS- 1D	3/24/15	>97.0	97.0	252.22	<342.22	Y	Dedicated Transducer	Liquid Level Below Transducer@92.4'
LCS- 1D	3/31/15	>97.0	97.0	252.22	<342.22	Y	Dedicated Transducer	Liquid Level Below Transducer@92.4'
LCS- 1D	4/7/15	>97.0	97.0	252.22	<342.22	Y	Dedicated Transducer	Liquid Level Below Transducer@92.4'
LCS- 1D	4/14/15	>97.0	97.0	252.22	<342.22	Y	Dedicated Transducer	Liquid Level Below Transducer@92.4'
LCS- 1D	4/21/15	>97.0	97.0	252.22	<342.22	Y	Dedicated Transducer	Liquid Level Below Transducer@92.4'
LCS- 1D	4/28/15	>97.0	97.0	252.22	<342.22	Y	Dedicated Transducer	Liquid Level Below Transducer@92.4'

LCS Number	Date Reading Collected	Measured Liquid Level Above Transducer (Ft.)	Transducer Height above Floor of Quarry (Ft.)	Base of Sump Elevation (Ft. MSL)	Elevation of Leachate (Ft. MSL)	Pump on during measurement? (Y/N)	Liquid level meter used	Comments
LCS- 1D	5/5/15	>97.0	97.0	252.22	<342.22	Y	Dedicated Transducer	Liquid Level Below Transducer@92.4'
LCS- 1D	5/12/15	>97.0	97.0	252.22	<342.22	Y	Dedicated Transducer	Liquid Level Below Transducer@92.4'
LCS- 1D	5/19/15	>97.0	97.0	252.22	<342.22	Y	Dedicated Transducer	Liquid Level Below Transducer@92.4'
LCS- 1D	5/26/15	>97.0	97.0	252.22	<342.22	Y	Dedicated Transducer	Liquid Level Below Transducer@92.4'
LCS- 1D	6/2/15	>97.0	97.0	252.22	<342.22	Y	Dedicated Transducer	Liquid Level Below Transducer@92.4'
LCS- 1D	6/9/15	>97.0	97.0	252.22	<342.22	Y	Dedicated Transducer	Liquid Level Below Transducer@92.4'
LCS- 1D	6/16/15	>97.0	97.0	252.22	<342.22	Y	Dedicated Transducer	Liquid Level Below Transducer@92.4'

LCS Number	Date Reading Collected	Measured Liquid Level Above Transducer (Ft.)	Transducer Height above Floor of Quarry (Ft.)	Base of Sump Elevation (Ft. MSL)	Elevation of Leachate (Ft. MSL)	Pump on during measurement? (Y/N)	Liquid level meter used	Comments
LCS- 2D	6/20/14	13.9	14.4	235.92	264.22	Y	Dedicated Transducer	
LCS- 2D	7/1/14	13.7	14.4	235.92	264.02	Y	Dedicated Transducer	
LCS- 2D	7/3/14	13.9	14.4	235.92	264.22	Y	Dedicated Transducer	
LCS- 2D	7/10/14	13.9	14.4	235.92	264.22	Y	Dedicated Transducer	
LCS- 2D	7/18/14	13.9	14.4	235.92	264.22	Y	Dedicated Transducer	
LCS- 2D	7/25/14	13.9	14.4	235.92	264.22	Y	Dedicated Transducer	
LCS- 2D	8/1/14	13.9	14.4	235.92	264.22	Y	Dedicated Transducer	
LCS- 2D	8/8/14	14.1	14.4	235.92	264.42	Y	Dedicated Transducer	
LCS- 2D	8/15/14	13.8	14.4	235.92	264.12	Y	Dedicated Transducer	
LCS- 2D	8/22/14	13.8	14.4	235.92	264.12	Y	Dedicated Transducer	
LCS- 2D	8/29/14	13.9	14.4	235.92	264.22	Y	Dedicated Transducer	
LCS- 2D	9/5/14	13.6	14.4	235.92	263.92	Y	Dedicated Transducer	
LCS- 2D	9/12/14	13.6	14.4	235.92	263.92	Y	Dedicated Transducer	
LCS- 2D	9/19/14	13.9	14.4	235.92	264.22	Y	Dedicated Transducer	
LCS- 2D	9/26/14					Y	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	10/4/14					Y	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	10/10/14	N/A	14.4	235.92		Y	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	10/10/14	N/A	14.4	235.92		Y	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	10/24/14	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	10/31/14	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	11/7/14	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	11/14/14	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	11/25/14	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	12/2/14	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	12/9/14	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	12/15/14	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	12/23/14	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	12/31/14	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	1/7/15	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	1/14/15	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	1/21/15	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	1/28/15	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	2/4/15	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	2/11/15	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	2/18/15	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	2/25/15	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	3/4/15	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	3/11/15	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	3/17/15	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	3/24/15	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	3/31/15	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	4/7/15	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	4/14/15	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	4/21/15	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	4/28/15	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error

LCS Number	Date Reading Collected	Measured Liquid Level Above Transducer (Ft.)	Transducer Height above Floor of Quarry (Ft.)	Base of Sump Elevation (Ft. MSL)	Elevation of Leachate (Ft. MSL)	Pump on during measurement? (Y/N)	Liquid level meter used	Comments
LCS- 2D	5/5/15	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	5/12/15	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	5/19/15	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	5/26/15	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	6/2/15	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	6/9/15	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error
LCS- 2D	6/16/15	N/A	14.4	235.92		N	Dedicated Transducer	Pump Off - "Over Current" Error

LCS Number	Date Reading Collected	Measured Liquid Level in Well (Ft. TOC)	Transducer Total Depth (Ft.)	Transducer Reading	Well Total Depth from Top of Casing (Ft.)	Pump on during measurement? (Y/N)	Liquid level meter used	Comments
LCS- 3D	6/20/14				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	7/1/14				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	7/3/14				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	7/10/14				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	7/18/14				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	7/25/14				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	8/1/14				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	8/8/14				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	8/15/14				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	8/22/14				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	8/29/14				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	9/5/14				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	9/12/14				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	9/19/14				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	9/26/14				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	10/4/14				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	10/10/14				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	10/17/14				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	10/31/14				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	11/7/14				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	11/14/14				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	11/25/14				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	12/2/14				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	12/9/14				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	12/15/14				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	12/23/14				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	12/31/14				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	1/7/15				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	1/14/15				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	1/21/15				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	1/28/15				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	2/4/15				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	2/11/15				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	2/18/15				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	2/25/15				140	Y	Dedicated Transducer	Transducer Melted, seeking replacement
LCS- 3D	3/4/15				140	Y	Dedicated Transducer	Transducer Replaced, Cal in Progress
LCS- 3D	3/11/15	135.00	63.00	5.00	140	Y	Dedicated Transducer	
LCS- 3D	3/17/15	135.00	63.00	5.00	140	Y	Dedicated Transducer	
LCS- 3D	3/24/15	135.00	63.00	5.00	140	Y	Dedicated Transducer	
LCS- 3D	3/31/15	135.00	63.00	5.00	140	Y	Dedicated Transducer	
LCS- 3D	4/7/15	135.00	63.00	5.00	140	Y	Dedicated Transducer	
LCS- 3D	4/14/15	135.00	63.00	5.00	140	Y	Dedicated Transducer	
LCS- 3D	4/21/15	135.00	63.00	5.00	140	Y	Dedicated Transducer	
LCS- 3D	4/28/15	135.00	63.00	5.00	140	Y	Dedicated Transducer	
LCS- 3D	5/5/15	135.00	63.00	5.00	140	Y	Dedicated Transducer	
LCS- 3D	5/12/15	135.00	63.00	5.00	140	Y	Dedicated Transducer	
LCS- 3D	5/19/15	135.00	63.00	5.00	140	Y	Dedicated Transducer	

LCS Number	Date Reading Collected	Measured Liquid Level in Well (Ft. TOC)	Transducer Total Depth (Ft.)	Transducer Reading	Well Total Depth from Top of Casing (Ft.)	Pump on during measurement? (Y/N)	Liquid level meter used	Comments
LCS- 3D	5/26/15	135.00	63.00	5.00	140	Y	Dedicated Transducer	
LCS- 3D	6/2/15	135.00	63.00	5.00	140	Y	Dedicated Transducer	
LCS- 3D	6/9/15	135.00	63.00	5.00	140	Y	Dedicated Transducer	
LCS- 3D	6/16/15	135.00	63.00	5.00	140	Y	Dedicated Transducer	

LCS Number	Date Reading Collected	Transducer Reading	Transducer Total Depth (Ft)	Base of Sump Elevation (Ft. MSL)	Heiight of Liquid (feet)	Well Total Depth from Top of Casing (Ft. MSL)	Pump on during measurement? (Y/N)	Liquid level meter used	Comments
LCS- 4B	6/20/14					N/A	N/A		Non-Operational
LCS- 4B	7/1/14					N/A	N/A		Non-Operational
LCS- 4B	7/3/14					N/A	N/A		Non-Operational
LCS- 4B	7/10/14					N/A	N/A		Non-Operational
LCS- 4B	7/18/14					N/A	N/A		Non-Operational
LCS- 4B	7/25/14					N/A	N/A		Non-Operational
LCS- 4B	8/1/14					N/A	N/A		Non-Operational
LCS- 4B	8/8/14					N/A	N/A		Non-Operational
LCS- 4B	8/15/14					N/A	N/A		Non-Operational
LCS- 4B	8/22/14					N/A	N/A		Non-Operational
LCS- 4B	8/29/14					N/A	N/A		Non-Operational
LCS- 4B	9/5/14					N/A	N/A		Non-Operational
LCS- 4B	9/12/14					N/A	N/A		Non-Operational
LCS- 4B	9/19/14					N/A	N/A		Non-Operational
LCS- 4B	9/26/14					N/A	N/A		Non-Operational
LCS- 4B	10/4/14					N/A	N/A		Non-Operational
LCS- 4B	10/10/14					N/A	N/A		Non-Operational
LCS- 4B	10/17/14					N/A	N/A		Non-Operational
LCS- 4B	10/24/14					N/A	N/A		Non-Operational
LCS- 4B	10/31/14					N/A	N/A		Non-Operational
LCS- 4B	11/7/14					N/A	N/A		Non-Operational
LCS- 4B	11/14/14					N/A	N/A		Non-Operational
LCS- 4B	11/25/14					N/A	N/A		Non-Operational
LCS- 4B	12/2/14					N/A	N/A		Non-Operational
LCS- 4B	12/9/14					N/A	N/A		Non-Operational
LCS- 4B	12/15/14					N/A	N/A		Non-Operational
LCS- 4B	12/23/14					N/A	N/A		Non-Operational
LCS- 4B	12/31/14					N/A	N/A		Non-Operational
LCS- 4B	1/7/15					N/A	N/A		Non-Operational
LCS- 4B	1/14/15					N/A	N/A		Non-Operational
LCS- 4B	1/21/15					N/A	Y		No Transducer
LCS- 4B	1/28/15					N/A	Y		No Transducer
LCS- 4B	2/4/15					N/A	Y		No Transducer
LCS- 4B	2/11/15					N/A	Y		No Transducer
LCS- 4B	2/18/15					N/A	Y		No Transducer
LCS- 4B	2/25/15					N/A	Y		No Transducer
LCS- 4B	3/4/15					N/A	Y		Transducer Installed, Cal in Progress
LCS- 4B	3/11/15	63.0	74.0	163	181.0	244.00	Y	Dedicated Transducer	
LCS- 4B	3/17/15	63.0	74.0	163	181.0	244.00	Y	Dedicated Transducer	
LCS- 4B	3/24/15	63.0	74.0	163	181.0	244.00	Y	Dedicated Transducer	
LCS- 4B	3/31/15	74.0	74.0	163	170.0	244.00	Y	Dedicated Transducer	Liquid below pump depth from surface of 81'
LCS- 4B	4/7/15	74.0	74.0	163	170.0	244.00	Y	Dedicated Transducer	Liquid below pump depth from surface of 81'
LCS- 4B	4/14/15	74.0	74.0	163	170.0	244.00	Y	Dedicated Transducer	Liquid below pump depth from surface of 81'
LCS- 4B	4/21/15	74.0	74.0	163	170.0	244.00	Y	Dedicated Transducer	Liquid below pump depth from surface of 81'
LCS- 4B	4/28/15	74.0	74.0	163	170.0	244.00	Y	Dedicated Transducer	Liquid below pump depth from surface of 81'
LCS- 4B	5/5/15	74.0	74.0	163	170.0	244.00	Y	Dedicated Transducer	Liquid below pump depth from surface of 81'
LCS- 4B	5/12/15	74.0	74.0	163	170.0	244.00	Y	Dedicated Transducer	Liquid below pump depth from surface of 81'

LCS Number	Date Reading Collected	Transducer Reading	Transducer Total Depth (Ft)	Base of Sump Elevation (Ft. MSL)	Heiight of Liquid (feet)	Well Total Depth from Top of Casing (Ft. MSL)	Pump on during measurement? (Y/N)	Liquid level meter used	Comments
LCS- 4B	5/19/15	74.0	74.0	163	170.0	244.00	Y	Dedicated Transducer	Liquid below pump depth from surface of 81'
LCS- 4B	5/26/15	74.0	74.0	163	170.0	244.00	Y	Dedicated Transducer	Liquid below pump depth from surface of 81'
LCS- 4B	6/2/15	74.0	74.0	163	170.0	244.00	Y	Dedicated Transducer	Liquid below pump depth from surface of 81'
LCS- 4B	6/9/15	74.0	74.0	163	170.0	244.00	Y	Dedicated Transducer	Liquid below pump depth from surface of 81'
LCS- 4B	6/16/15	74.0	74.0	163	170.0	244.00	Y	Dedicated Transducer	Liquid below pump depth from surface of 81'

LCS Number	Date Reading Collected	Measured Liquid Level Above Transducer (Ft.)	Transducer Height above Floor of Quarry (Ft.)	Base of Sump Elevation (Ft. MSL)	Height of Liquid (Ft.)	Elevation of Leachate (Ft. MSL)	Pump on during measurement? (Y/N)	Liquid level meter used	Comments
LCS- 5A	6/20/14	10.1	15.0	235.4	25.1	260.50	Y	Dedicated Transducer	
LCS- 5A	7/1/14	10.0	15.0	235.4	25.0	260.40	Y	Dedicated Transducer	
LCS- 5A	7/3/14	10.1	15.0	235.4	25.1	260.50	Y	Dedicated Transducer	
LCS- 5A	7/10/14	10.1	15.0	235.4	25.1	260.50	Y	Dedicated Transducer	
LCS- 5A	7/18/14	10.1	15.0	235.4	25.1	260.50	Y	Dedicated Transducer	
LCS- 5A	7/25/14	10.2	15.0	235.4	25.2	260.60	Y	Dedicated Transducer	
LCS- 5A	8/1/14	10.1	15.0	235.4	25.1	260.50	Y	Dedicated Transducer	
LCS- 5A	8/8/14	11.9	15.0	235.4	26.9	262.30	Y	Dedicated Transducer	
LCS- 5A	8/15/14	10.1	15.0	235.4	25.1	260.50	Y	Dedicated Transducer	
LCS- 5A	8/22/14	10.1	15.0	235.4	25.1	260.50	Y	Dedicated Transducer	
LCS- 5A	8/29/14	29.0	15.0	235.4	44.0	279.40	Y	Dedicated Transducer	
LCS- 5A	9/5/14	28.7	15.0	235.4	43.7	279.10	Y	Dedicated Transducer	
LCS- 5A	9/12/14	10.0	15.0	235.4	25.0	260.40	Y	Dedicated Transducer	
LCS- 5A	9/19/14	10.1	15.0	235.4	25.1	260.50	Y	Dedicated Transducer	
LCS- 5A	9/26/14	10.1	15.0	235.4	25.1	260.50	Y	Dedicated Transducer	
LCS- 5A	10/4/14	10.1	15.0	235.4	25.1	260.50	Y	Dedicated Transducer	
LCS- 5A	10/10/14	10.2	15.0	235.4	25.2	260.60	Y	Dedicated Transducer	
LCS- 5A	10/17/14	10.1	15.0	235.4	25.1	260.50	Y	Dedicated Transducer	
LCS- 5A	10/24/14	10.0	15.0	235.4	25.0	260.40	Y	Dedicated Transducer	
LCS- 5A	10/31/14	10.0	15.0	235.4	25.0	260.40	Y	Dedicated Transducer	
LCS- 5A	11/7/14	10.0	15.0	235.4	25.0	260.40	Y	Dedicated Transducer	
LCS- 5A	11/14/14	10.0	15.0	235.4	25.0	260.40	Y	Dedicated Transducer	
LCS- 5A	11/25/14	10.0	15.0	235.4	25.0	260.40	Y	Dedicated Transducer	
LCS- 5A	12/2/14	10.1	15.0	235.4	25.1	260.50	Y	Dedicated Transducer	
LCS- 5A	12/9/14	10.1	15.0	235.4	25.1	260.50	Y	Dedicated Transducer	
LCS- 5A	12/15/14	10.1	15.0	235.4	25.1	260.50	Y	Dedicated Transducer	
LCS- 5A	12/23/14	10.1	15.0	235.4	25.1	260.50	Y	Dedicated Transducer	
LCS- 5A	12/31/14	10.0	15.0	235.4	25.0	260.40	Y	Dedicated Transducer	
LCS- 5A	1/7/15	10.0	15.0	235.4	25.0	260.40	Y	Dedicated Transducer	
LCS- 5A	1/14/15	10.1	15.0	235.4	25.1	260.50	Y	Dedicated Transducer	
LCS- 5A	1/21/15	10.1	15.0	235.4	25.1	260.50	Y	Dedicated Transducer	
LCS- 5A	1/28/15	10.2	15.0	235.4	25.2	260.60	Y	Dedicated Transducer	
LCS- 5A	2/4/15	10.1	15.0	235.4	25.1	260.50	Y	Dedicated Transducer	
LCS- 5A	2/11/15	10.2	15.0	235.4	25.2	260.60	Y	Dedicated Transducer	
LCS- 5A	2/18/15	10.1	15.0	235.4	25.1	260.50	Y	Dedicated Transducer	
LCS- 5A	2/25/15	10.0	15.0	235.4	25.0	260.40	Y	Dedicated Transducer	
LCS- 5A	3/4/15	10.2	15.0	235.4	25.2	260.60	Y	Dedicated Transducer	
LCS- 5A	3/11/15	10.1	15.0	235.4	25.1	260.50	Y	Dedicated Transducer	
LCS- 5A	3/17/15	10.0	15.0	235.4	25.0	260.40	Y	Dedicated Transducer	
LCS- 5A	3/24/15	10.2	15.0	235.4	25.2	260.60	Y	Dedicated Transducer	
LCS- 5A	3/31/15	10.0	15.0	235.4	25.0	260.40	Y	Dedicated Transducer	
LCS- 5A	4/7/15	10.1	15.0	235.4	25.1	260.50	Y	Dedicated Transducer	
LCS- 5A	4/14/15	33.4	15.0	235.4	48.4	283.80	Y	Dedicated Transducer	
LCS- 5A	4/21/15	33.3	15.0	235.4	48.3	283.70	Y	Dedicated Transducer	
LCS- 5A	4/28/15	33.7	15.0	235.4	48.7	284.10	Y	Dedicated Transducer	
LCS- 5A	5/5/15	33.4	15.0	235.4	48.4	283.80	Y	Dedicated Transducer	
LCS- 5A	5/12/15	33.8	15.0	235.4	48.8	284.20	Y	Dedicated Transducer	
LCS- 5A	5/19/15	34.0	15.0	235.4	49.0	284.40	Y	Dedicated Transducer	

LCS Number	Date Reading Collected	Measured Liquid Level Above Transducer (Ft.)	Transducer Height above Floor of Quarry (Ft.)	Base of Sump Elevation (Ft. MSL)	Height of Liquid (Ft.)	Elevation of Leachate (Ft. MSL)	Pump on during measurement? (Y/N)	Liquid level meter used	Comments
LCS- 5A	5/26/15	33.8	15.0	235.4	48.8	284.20	Y	Dedicated Transducer	
LCS- 5A	6/2/15	34.2	15.0	235.4	49.2	284.60	Y	Dedicated Transducer	
LCS- 5A	6/9/15	33.3	15.0	235.4	48.3	283.70	Y	Dedicated Transducer	
LCS- 5A	6/16/15	34.3	15.0	235.4	49.3	284.70	Y	Dedicated Transducer	

LCS Number	Date Reading Collected	Measured Liquid Level Above Transducer (Ft.)	Transducer Height above Floor of Quarry (Ft.)	Base of Sump Elevation (Ft. MSL)	Height of Liquid (Ft.)	Elevation of Leachate (Ft. MSL)	Pump on during measurement? (Y/N)	Liquid level meter used	Comments
LCS- 6B	6/20/14	3.8	9.4	428.52	13.2	441.72	Y	Dedicated Transducer	
LCS- 6B	7/1/14	3.8	9.4	428.52	13.2	441.72	Y	Dedicated Transducer	
LCS- 6B	7/3/14	3.8	9.4	428.52	13.2	441.72	Y	Dedicated Transducer	
LCS- 6B	7/10/14	3.5	9.4	428.52	12.9	441.42	Y	Dedicated Transducer	
LCS- 6B	7/18/14	3.9	9.4	428.52	13.3	441.82	Y	Dedicated Transducer	
LCS- 6B	7/25/14	4.2	9.4	428.52	13.6	442.12	Y	Dedicated Transducer	
LCS- 6B	8/1/14	3.5	9.4	428.52	12.9	441.42	Y	Dedicated Transducer	
LCS- 6B	8/8/14	3.9	9.4	428.52	13.3	441.82	Y	Dedicated Transducer	
LCS- 6B	8/15/14	3.5	9.4	428.52	12.9	441.42	Y	Dedicated Transducer	
LCS- 6B	8/22/14	3.7	9.4	428.52	13.1	441.62	Y	Dedicated Transducer	
LCS- 6B	8/29/14	3.5	9.4	428.52	12.9	441.42	Y	Dedicated Transducer	
LCS- 6B	9/5/14	3.4	9.4	428.52	12.8	441.32	Y	Dedicated Transducer	
LCS- 6B	9/12/14	4.2	9.4	428.52	13.6	442.12	Y	Dedicated Transducer	
LCS- 6B	9/19/14	4.1	9.4	428.52	13.5	442.02	Y	Dedicated Transducer	
LCS- 6B	9/26/14	4.0	9.4	428.52	13.4	441.92	Y	Dedicated Transducer	
LCS- 6B	10/4/14	4.6	9.4	428.52	14.0	442.52	Y	Dedicated Transducer	
LCS- 6B	10/10/14	4.7	9.4	428.52	14.1	442.62	Y	Dedicated Transducer	
LCS- 6B	10/17/14	4.7	9.4	428.52	14.1	442.62	Y	Dedicated Transducer	
LCS- 6B	10/24/14	4.4	9.4	428.52	13.8	442.32	Y	Dedicated Transducer	
LCS- 6B	10/31/14	5.3	9.4	428.52	14.7	443.22	Y	Dedicated Transducer	
LCS- 6B	11/7/14	4.8	9.4	428.52	14.2	442.72	Y	Dedicated Transducer	
LCS- 6B	11/14/14	5.0	9.4	428.52	14.4	442.92	Y	Dedicated Transducer	
LCS- 6B	11/25/14	5.1	9.4	428.52	14.5	443.02	Y	Dedicated Transducer	
LCS- 6B	12/2/14	5.7	9.4	428.52	15.1	443.62	Y	Dedicated Transducer	
LCS- 6B	12/9/14	5.8	9.4	428.52	15.2	443.72	Y	Dedicated Transducer	
LCS- 6B	12/15/14	5.6	9.4	428.52	15.0	443.52	Y	Dedicated Transducer	
LCS- 6B	12/23/14	5.4	9.4	428.52	14.8	443.32	Y	Dedicated Transducer	
LCS- 6B	12/31/14	6.3	9.4	428.52	15.7	444.22	Y	Dedicated Transducer	
LCS- 6B	1/7/15	6.5	9.4	429.52	15.9	445.42	Y	Dedicated Transducer	
LCS- 6B	1/14/15	6.0	9.4	429.52	15.4	444.92	Y	Dedicated Transducer	
LCS- 6B	1/21/15	6.5	9.4	429.52	15.9	445.42	Y	Dedicated Transducer	
LCS- 6B	1/28/15	6.4	9.4	429.52	15.8	445.32	Y	Dedicated Transducer	
LCS- 6B	2/4/15	6.3	9.4	429.52	15.7	445.22	Y	Dedicated Transducer	
LCS- 6B	2/11/15	6.4	9.4	429.52	15.8	445.32	Y	Dedicated Transducer	
LCS- 6B	2/18/15	6.4	9.4	429.52	15.8	445.32	Y	Dedicated Transducer	
LCS- 6B	2/25/15	6.6	9.4	429.52	16.0	445.52	Y	Dedicated Transducer	
LCS- 6B	3/4/15	6.3	9.4	429.52	15.7	445.22	Y	Dedicated Transducer	
LCS- 6B	3/11/15	6.4	9.4	429.52	15.8	445.32	Y	Dedicated Transducer	
LCS- 6B	3/17/15	6.5	9.4	429.52	15.9	445.42	Y	Dedicated Transducer	
LCS- 6B	3/24/15	7.0	9.4	429.52	16.4	445.92	Y	Dedicated Transducer	
LCS- 6B	3/31/15	7.2	9.4	429.52	16.6	446.12	Y	Dedicated Transducer	
LCS- 6B	4/7/15	7.5	9.4	429.52	16.9	446.42	Y	Dedicated Transducer	
LCS- 6B	4/14/15	9.3	9.4	429.52	18.7	448.22	Y	Dedicated Transducer	
LCS- 6B	4/21/15	9.3	9.4	429.52	18.7	448.22	Y	Dedicated Transducer	
LCS- 6B	4/28/15	9.4	9.4	429.52	18.8	448.32	Y	Dedicated Transducer	
LCS- 6B	5/5/15	9.4	9.4	429.52	18.8	448.32	Y	Dedicated Transducer	
LCS- 6B	5/12/15	9.6	9.4	429.52	19.0	448.52	Y	Dedicated Transducer	
LCS- 6B	5/19/15	10.0	9.4	429.52	19.4	448.92	Y	Dedicated Transducer	

LCS Number	Date Reading Collected	Measured Liquid Level Above Transducer (Ft.)	Transducer Height above Floor of Quarry (Ft.)	Base of Sump Elevation (Ft. MSL)	Height of Liquid (Ft.)	Elevation of Leachate (Ft. MSL)	Pump on during measurement? (Y/N)	Liquid level meter used	Comments
LCS- 6B	5/26/15	10.2	9.4	429.52	19.6	449.12	Y	Dedicated Transducer	
LCS- 6B	6/2/15	7.8	9.4	429.52	17.2	446.72	Y	Dedicated Transducer	
LCS- 6B	6/9/15	7.9	9.4	429.52	17.3	446.82	Y	Dedicated Transducer	
LCS- 6B	6/16/15	7.9	9.4	429.52	17.3	446.82	Y	Dedicated Transducer	