

From: Alex Tabb [<mailto:atabb@smithandloveless.com>]
Sent: Friday, August 28, 2015 3:35 PM
To: Meyers, Leasue
Subject: 10 CSR 20-8 Design Guides Stakeholder Meeting August 26

Leasue,

I wanted to submit a note on page 10 of the 8/05/15. For our above grade systems routine maintenance is all above grade with no wet well access required for routine maintenance.

Paragraph (B) Equipment, Wet Well Access, and Valve Location.

States that....."Wet well access shall not be through the equipment compartment and shall be at least twenty-four inches (24") (61 cm) in diameter."

We strongly fee this is not required on our style of station due to the maintenance and equipment being above grade. For underground stations, or those with mechanical equipment in the wet well, I understand the intent and necessity for this - I would submit for our style of station this should not be required.

Thank you
Alex

--

Alex Tabb
Manager, Municipal Pumping Systems

Smith & Loveless Inc.
smithandloveless.com
Office: (913) 888-5201 ext. 370

Above All Others™ | Pumping. Treatment. Separation.

Don't miss S&L's New Products at WEFTEC.15 | **Booth #3648**