

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES

MISSOURI CLEAN WATER COMMISSION



MISSOURI STATE OPERATING PERMIT

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92nd Congress) as amended,

Permit No. MO-0110752

Owner: Northeast Public Sewer District (NPSD)
Address: 400 Biltmore, Suite 414, Fenton, MO 63026

Continuing Authority: Same as above
Address: Same as above

Facility Name: NPSD – Country Club of Sugar Creek
Facility Address: 4914 Country Club Drive, High Ridge, MO 63049

Legal Description: SE ¼, NE ¼, SW ¼, Sec. 7, T43N, R5E, Jefferson County
Latitude/Longitude: +3828326/-09030091

Receiving Stream: Unnamed Tributary to Saline Creek (U) (Losing)
First Classified Stream and ID: Saline Creek (C) (02190)
USGS Basin & Sub-watershed No.: (07140102-080004)

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:


FACILITY DESCRIPTION

Outfall #001 - POTW - SIC #4952 - Certified "B" Operator Required

Extended aeration/sock filters/chlorination/aerated sludge holding tank/sludge disposal is by contract hauler/sludge is land applied
Design population equivalent is 1134
Design flow is 114,000 gallons per day.
Actual flow is 68,500 gallons per day.
Design sludge production is 21.6 dry tons/year.

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Section 644.051.6 of the Law.

June 5, 2009
Effective Date


Mark N. Templeton, Director, Department of Natural Resources

June 4, 2014
Expiration Date


Mike Struckhoff, Director, St. Louis Regional Office

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The Interim effluent limitations shall become effective upon issuance of the permit and remain in effect until **June 30, 2012**. Such discharges shall be controlled, limited and monitored by the permittee as specified below:

| OUTFALL NUMBER AND EFFLUENT PARAMETER(S) | UNITS | INTERIM EFFLUENT LIMITATIONS | | | MONITORING REQUIREMENTS | |
|--|----------|------------------------------|----------------|-----------------|-------------------------|-----------------|
| | | DAILY MAXIMUM | WEEKLY AVERAGE | MONTHLY AVERAGE | MEASUREMENT FREQUENCY | SAMPLE TYPE |
| <u>Outfall #001</u> | | | | | | |
| Flow | MGD | * | | * | Once/weekday | 24 hr total |
| Biochemical Oxygen Demand ₅ | mg/L | | 15 | 10 | Once/month | 24 hr composite |
| Total Suspended Solids | mg/L | | 20 | 15 | Once/month | 24 hr composite |
| pH – Units | SU | *** | | *** | Once/month | Grab |
| Oil & Grease | mg/L | 15 | | 10 | Once/month | Grab |
| Fecal Coliform**** | #/100 ml | 1000 | | 400 | Once/month | Grab |
| Total Residual Chlorine | mg/L | 1.0 | | 1.0 | Once/month | Grab |

MONITORING REPORTS SHALL BE SUBMITTED **MONTHLY**; THE FIRST REPORT IS DUE **July 28, 2009**. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.

| OUTFALL NUMBER AND EFFLUENT PARAMETER(S) | UNITS | INTERIM EFFLUENT LIMITATIONS | | | MONITORING REQUIREMENTS | |
|--|-------|------------------------------|----------------|-----------------|-------------------------|-------------|
| | | DAILY MAXIMUM | WEEKLY AVERAGE | MONTHLY AVERAGE | MEASUREMENT FREQUENCY | SAMPLE TYPE |
| <u>Outfall #001</u> | | | | | | |
| Ammonia as N (May 1 – Oct 31) (Nov 1 – April 30) | mg/L | * | | * | Once/quarter** | Grab |
| Temperature | °C | * | | * | Once/quarter** | Grab |
| Nitrate + Nitrite | mg/L | * | | * | Once/quarter** | Grab |

MONITORING REPORTS SHALL BE SUBMITTED **QUARTERLY**; THE FIRST REPORT IS DUE **October 28, 2009**. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.

MO 780-0010 (8/91)

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

* Monitoring requirement only.

** Sample once per quarter:

| Sample discharge at least once for the months of: | Report is due: |
|---|----------------|
| January, February, March (1st Quarter) | April 28 |
| April, May, June (2nd Quarter) | July 28 |
| July, August, September (3rd Quarter) | October 28 |
| October, November, December (4th Quarter) | January 28 |

*** pH is measured in pH units and is not to be averaged. The pH is limited to the range of 6.0-9.0 pH units.

**** The Monthly Average Limit for Fecal Coliform is expressed as a geometric mean.

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective on **July 1, 2012** and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:

| OUTFALL NUMBER AND EFFLUENT PARAMETER(S) | UNITS | FINAL EFFLUENT LIMITATIONS | | | MONITORING REQUIREMENTS | |
|--|----------|----------------------------|----------------|-----------------|-------------------------|-----------------|
| | | DAILY MAXIMUM | WEEKLY AVERAGE | MONTHLY AVERAGE | MEASUREMENT FREQUENCY | SAMPLE TYPE |
| <u>Outfall #001</u> | | | | | | |
| Flow | MGD | * | | * | Once/weekday | 24 hr total |
| Biochemical Oxygen Demand ₅ | mg/L | | 15 | 10 | Once/month | 24 hr composite |
| Total Suspended Solids | mg/L | | 20 | 15 | Once/month | 24 hr composite |
| pH – Units | SU | *** | | *** | Once/month | Grab |
| Oil & Grease | mg/L | 15 | | 10 | Once/month | Grab |
| Fecal Coliform**** | #/100 ml | 1000 | | 400 | Once/month | Grab |
| Total Residual Chlorine (Note 1) | mg/L | 0.017 | | 0.008 | Once/month | Grab |

MONITORING REPORTS SHALL BE SUBMITTED **MONTHLY**; THE FIRST REPORT IS DUE **August 28, 2012**. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.

| OUTFALL NUMBER AND EFFLUENT PARAMETER(S) | UNITS | FINAL EFFLUENT LIMITATIONS | | | MONITORING REQUIREMENTS | |
|--|-------|----------------------------|----------------|-----------------|-------------------------|-------------|
| | | DAILY MAXIMUM | WEEKLY AVERAGE | MONTHLY AVERAGE | MEASUREMENT FREQUENCY | SAMPLE TYPE |
| <u>Outfall #001</u> | | | | | | |
| Ammonia as N (May 1 – Oct 31) (Nov 1 – April 30) | mg/L | * | | * | Once/quarter** | Grab |
| Temperature | °C | * | | * | Once/quarter** | Grab |
| Nitrate + Nitrite | mg/L | * | | * | Once/quarter** | Grab |

MONITORING REPORTS SHALL BE SUBMITTED **QUARTERLY**; THE FIRST REPORT IS DUE **October 28, 2012**. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.

| | | | | |
|------------------------------------|------------|------------------------|-------------------|-----------------|
| Whole Effluent Toxicity (WET) test | % Survival | See Special Conditions | once/permit cycle | 24 hr composite |
|------------------------------------|------------|------------------------|-------------------|-----------------|

MONITORING REPORTS SHALL BE SUBMITTED **ONCE**; THE FIRST REPORT IS DUE **October 28, 2013**.

MO 780-0010 (8/91)

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

* Monitoring requirement only.

** Sample once per quarter:

| Sample discharge at least once for the months of: | Report is due: |
|---|----------------|
| January, February, March (1st Quarter) | April 28 |
| April, May, June (2nd Quarter) | July 28 |
| July, August, September (3rd Quarter) | October 28 |
| October, November, December (4th Quarter) | January 28 |

*** pH is measured in pH units and is not to be averaged. The pH is limited to the range of 6.0-9.0 pH units.

**** The Monthly Average Limit for Fecal Coliform is expressed as a geometric mean.

| B. INFLUENT MONITORING REQUIREMENTS | | PAGE NUMBER 4 of 9 | |
|--|-------|--------------------------|-------------|
| | | PERMIT NUMBER MO-0110752 | |
| The facility is required to meet a removal efficiency of 85% or more. The monitoring requirements shall become effective upon issuance and remain in effect until expiration of the permit. To determine removal efficiencies, the influent wastewater shall be monitored by the permittee as specified below: | | | |
| SAMPLING LOCATION AND PARAMETER(S) | UNITS | MONITORING REQUIREMENTS | |
| | | MEASUREMENT FREQUENCY | SAMPLE TYPE |
| <u>Influent</u> | | | |
| Biochemical Oxygen Demand ₅ | mg/L | once/quarter** | grab |
| Total Suspended Solids | mg/L | once/quarter** | grab |
| MONITORING REPORTS SHALL BE SUBMITTED <u>QUARTERLY</u> ; THE FIRST REPORT IS DUE <u>October 28, 2009</u> . | | | |

MO 780-0010 (8/91)

B. INFLUENT MONITORING REQUIREMENTS (continued)

** Sample once per quarter:

| Sample discharge at least once for the months of: | Report is due: |
|---|----------------|
| January, February, March (1st Quarter) | April 28 |
| April, May, June (2nd Quarter) | July 28 |
| July, August, September (3rd Quarter) | October 28 |
| October, November, December (4th Quarter) | January 28 |

Note 1 - This permit contains a Total Residual Chlorine (TRC) limit.

- (a) This effluent limit is below the minimum quantification level (ML) of the most common and practical EPA approved CLTRC methods. The department has determined the current acceptable ML for total residual chlorine to be 0.13 mg/L when using the DPD Colorimetric Method #4500 – CL G. from Standard Methods for the Examination of Waters and Wastewater. The permittee will conduct analyses in accordance with this method, or equivalent, and report actual analytical values. Measured values greater than or equal to the minimum quantification level of 0.13 mg/L will be considered violations of the permit and values less than the minimum quantification level of 0.13 mg/L will be considered to be in compliance with the permit limitation. The minimum quantification level does not authorize the discharge of chlorine in excess of the effluent limits stated in the permit.
- (b) Disinfection is required year-round unless the permit specifically states that “Final limitations and monitoring requirements for Fecal Coliform are applicable only during the recreational season from April 1 through October 31.” If your permit does not require disinfection during the non-recreational months, do not chlorinate in those months.
- (c) Do not chemically dechlorinate **if it is not needed to meet the limits in your permit**.
- (d) If no chlorine was used in a given sampling period, an actual analysis is not necessary. Simply report as “0 mg/L” TRC.

C. STANDARD CONDITIONS

In addition to specified conditions stated herein, this permit is subject to the attached Parts I, II, & III standard conditions dated October 1, 1980 and August 15, 1994, and hereby incorporated as though fully set forth herein.

D. SPECIAL CONDITIONS

1. This permit may be reopened and modified, or alternatively revoked and reissued, to:
 - (a) Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a) (2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
 - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
 - (2) controls any pollutant not limited in the permit.
 - (b) Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri's Water Quality Standards.
 - (c) Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri's list of waters of the state not fully achieving the state's water quality standards, also called the 303(d) list.

The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.

2. All outfalls must be clearly marked in the field.
3. Permittee will cease discharge by connection to area-wide wastewater treatment system within 90 days of notice of its availability.
4. Changes in Discharges of Toxic Substances

The permittee shall notify the Director as soon as it knows or has reason to believe:

- (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:"
 - (1) One hundred micrograms per liter (100 µg/L);
 - (2) Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,5 dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
 - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;
 - (4) The level established in Part A of the permit by the Director.
 - (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.
5. Report as no-discharge when a discharge does not occur during the report period.

6. Water Quality Standards

- (a) Discharges to waters of the state shall not cause a violation of water quality standards rule under 10 CSR 20-7.031, including both specific and general criteria.
- (b) General Criteria. The following general water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:
 - (1) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
 - (2) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
 - (3) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
 - (4) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
 - (5) There shall be no significant human health hazard from incidental contact with the water;
 - (6) There shall be no acute toxicity to livestock or wildlife watering;
 - (7) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
 - (8) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.

D. SPECIAL CONDITIONS (continued)

7. Sludge and Biosolids Use For Domestic Wastewater Treatment Facilities
 - (a) Permittee shall comply with the pollutant limitations, monitoring, reporting, and other requirements in accordance with the attached permit Standard Conditions.
 - (b) If sludge is not removed by a contract hauler, permittee is authorized to land apply biosolids. Permit Standard Conditions, Part III shall apply to the land application of biosolids. Permittee shall notify the department at least 180 days prior to the planned removal of biosolids. The department may require submittal of a biosolids management plan for department review and approval as determined appropriate on a case-by-case basis.

8. The permittee shall comply with any applicable requirements listed in 10 CSR 20-8 and 10 CSR 20-9, unless the facility has received written notification that the Department has approved a modification to the requirements. The monitoring frequencies contained in this permit shall not be construed by the permittee as a modification of the monitoring frequencies listed in 10 CSR 20-9. If a modification of the monitoring frequencies listed in 10 CSR 20-9 is needed, the permittee shall submit a written request to the department for review and, if deemed necessary, approval.

9. Whole Effluent Toxicity (WET) Test shall be conducted as follows:

| SUMMARY OF WET TESTING FOR THIS PERMIT | | | | |
|--|----------|--------------------|-----------------|-----------------------------------|
| OUTFALL | A.E.C. % | FREQUENCY | SAMPLE TYPE | MONTH |
| #001 | 100 | Once/ Permit cycle | 24 hr composite | August 2013. Report in October |

- (a) Test Schedule and Follow-Up Requirements
 - (1) Perform a SINGLE-dilution test in the months and at the frequency specified above. For tests which are successfully passed, submit test results USING THE DEPARTMENT'S WET TEST REPORT FORM #MO-780-1899 along with complete copies of the test reports as received from the laboratory, including copies of chain-of-custody forms within 30 calendar days of availability to the WATER PROTECTION PROGRAM, P.O. Box 176, Jefferson City, MO 65102. If the effluent passes the test, do not repeat the test until the next test period.
 - (a) For discharges of stormwater, samples shall be collected within three hours from when discharge first occurs.
 - (b) Samples submitted for analysis of stormwater discharges shall be collected as a grab.
 - (c) For discharges of non-stormwater, samples shall be collected only when precipitation has not occurred for a period of forty-eight hours prior to sample collection. In no event shall sample collection occur simultaneously with the occurrence of precipitation excepting for stormwater samples.
 - (d) A twenty-four hour composite sample shall be submitted for analysis of non-stormwater discharges.
 - (e) Upstream receiving water samples, where required, shall be collected upstream from any influence of the effluent where downstream flow is clearly evident.
 - (f) Samples submitted for analysis of upstream receiving water may be collected as either a grab or twenty-four-hour composite as appropriate to the nature of the discharge.
 - (g) Chemical and physical analysis of the upstream control and effluent sample shall occur immediately upon being received by the laboratory, prior to any manipulation of the effluent sample beyond preservation methods consistent with federal guidelines for WET testing that are required to stabilize the sample during shipping.
 - (h) Any and all chemical or physical analysis of the effluent sample performed in conjunction with the WET test shall be performed at the 100% Effluent concentration in addition to analyses performed upon any other effluent concentration.
 - (i) All chemical analyses included in the Missouri Department of Natural Resources WET test report form #MO-780-1899 shall be performed and results shall be recorded in the appropriate field of the report form.

D. SPECIAL CONDITIONS (continued)

9. WET Test (continued):

- (j) Where flow-weighted composite sample is required for analysis, the samples shall be composited at the laboratory where the test is to be performed.
 - (k) Where in stream testing is required downstream from the discharge, sample collection shall occur immediately below the established Zone of Initial Dilution in conjunction with or immediately following a release or discharge.
 - (l) Samples submitted for analysis of downstream receiving water may be collected as either a grab or twenty-four-hour composite as appropriate to the nature of the discharge.
 - (m) All instream samples, including downstream samples, shall be tested for toxicity at the 100% concentration in addition to any other assigned AEC for in-stream samples.
- (2) All failing test results along with complete copies of the test reports as received from the laboratory, INCLUDING THOSE TESTS CONDUCTED UNDER CONDITION (3) BELOW, shall be reported to the WATER PROTECTION PROGRAM, P.O. Box 176, Jefferson City, MO 65102 within 14 calendar days of the availability of the results.
- (3) If the effluent fails the test, a multiple dilution test shall be performed for BOTH test species within 30 calendar days and biweekly thereafter (for storm water, tests shall be performed on the next and subsequent storm water discharges as they occur), until one of the following conditions are met:
- (a) THREE CONSECUTIVE MULTIPLE-DILUTION TESTS PASS. No further tests need to be performed until next regularly scheduled test period.
 - (b) A TOTAL OF THREE MULTIPLE-DILUTION TESTS FAIL.
- (4) Failure of at least two multiple-dilution tests during any period of accelerated monitoring violates the permit narrative requirement for aquatic life protection.
- (5) The permittee shall submit a concise summary of all test results for the test series to the WATER PROTECTION PROGRAM, P.O. Box 176, Jefferson City, MO 65102 within 14 calendar days of the third failed test.
- (6) Additionally, the following shall apply upon failure of the third MULTIPLE DILUTION test: A toxicity identification evaluation (TIE) or toxicity reduction evaluation (TRE) is automatically triggered. The permittee shall contact THE WATER PROTECTION PROGRAM within 14 calendar days from availability of the test results to ascertain as to whether a TIE or TRE is appropriate. The permittee shall submit a plan for conducting a TIE or TRE to the WATER PROTECTION PROGRAM within 60 calendar days of the date of DNR's direction to perform either a TIE or TRE. This plan must be approved by DNR before the TIE or TRE is begun. A schedule for completing the TIE or TRE shall be established in the plan approval.
- (7) Upon DNR's approval, the TIE/TRE schedule may be modified if toxicity is intermittent during the TIE/TRE investigations. A revised WET test schedule may be established by DNR for this period.
- (8) If a previously completed TIE has clearly identified the cause of toxicity, additional TIEs will not be required as long as effluent characteristics remain essentially unchanged and the permittee is proceeding according to a DNR approved schedule to complete a TRE and reduce toxicity. Regularly scheduled WET testing as required in the permit, without the follow-up requirements, will be required during this period.
- (9) When WET test sampling is required to run over one DMR period, each DMR report shall contain a copy of the Department's WET test report form that was generated during the reporting period.
- (10) Submit a concise summary in tabular format of all test results with the annual report.
- (b) PASS/FAIL procedure and effluent limitations:
- (1) To pass a single-dilution test, mortality observed in the AEC test concentration shall not be significantly different (at the 95% confidence level; $p = 0.05$) than that observed in the upstream receiving-water control sample. Where upstream receiving water is not available mortality observed in the AEC test concentration shall not be significantly different (at the 95% confidence level; $p = 0.05$) than that observed in the laboratory control. The appropriate statistical tests of significance shall be consistent with the most current edition of METHODS FOR MEASURING THE ACUTE TOXICITY OF EFFLUENTS AND RECEIVING WATERS TO FRESHWATER AND MARINE ORGANISMS or other Federal guidelines as appropriate or required.
 - (2) To pass a multiple-dilution test:
 - (a) For facilities with a computed percent effluent at the edge of the zone of initial dilution, Allowable Effluent Concentration (AEC) OF 30% OR LESS, the AEC must be less than three-tenths (0.3) of the LC_{50} concentration for the most sensitive of the test organisms; **OR**,
 - (b) For facilities with an AEC greater than 30% the LC_{50} concentration must be greater than 100%; **AND**,

D. SPECIAL CONDITIONS (continued)

9. WET Test (continued):

- (c) all effluent concentrations equal to or less than the AEC must be nontoxic. Mortality observed in all effluent concentrations equal to or less than the AEC shall not be significantly different (at the 95% confidence level; $p = 0.05$) than that observed in the upstream receiving-water control sample. Where upstream receiving water is not available mortality observed in the AEC test concentration shall not be significantly different (at the 95% confidence level; $p = 0.05$) than that observed in the laboratory control. The appropriate statistical tests of significance shall be consistent with the most current edition of METHODS FOR MEASURING THE ACUTE TOXICITY OF EFFLUENTS AND RECEIVING WATERS TO FRESHWATER AND MARINE ORGANISMS or other federal guidelines as appropriate or required. Failure of one multiple-dilution test may be considered an effluent limit violation.

(c) Test Conditions

- (1) Test Type: Acute Static non-renewal.
- (2) All tests, including repeat tests for previous failures, shall include both test species listed below.
- (3) Test species: *Ceriodaphnia dubia* and *Pimephales promelas* (fathead minnow). Organisms used in WET testing shall come from cultures reared for the purpose of conducting toxicity tests and cultured in a manner consistent with the most current USEPA guidelines. All test animals shall be cultured as described in the most current edition of METHODS FOR MEASURING THE ACUTE TOXICITY OF EFFLUENTS AND RECEIVING WATERS TO FRESHWATER AND MARINE ORGANISMS.
- (4) Test period: 48 hours at the "Acceptable Effluent Concentration" (AEC) specified above.
- (5) When dilutions are required, upstream receiving stream water shall be used as dilution water. If upstream water is unavailable or if mortality in the upstream water exceeds 10%, "reconstituted" water will be used as dilution water. Procedures for generating reconstituted water will be supplied by the MDNR upon request.
- (6) Single-dilution tests will be run with:
 - (a) Effluent at the AEC concentration;
 - (b) 100% receiving-stream water (if available), collected upstream of the outfall at a point beyond any influence of the effluent; and
 - (c) reconstituted water.
- (7) Multiple-dilution tests will be run with:
 - (a) 100%, 50%, 25%, 12.5%, and 6.25% effluent, unless the AEC is less than 25% effluent, in which case dilutions will be 4 times the AEC, two times the AEC, AEC, 1/2 AEC and 1/4 AEC;
 - (b) 100% receiving-stream water (if available), collected upstream of the outfall at a point beyond any influence of the effluent; and
 - (c) reconstituted water.
- (8) If reconstituted-water control mortality for a test species exceeds 10%, the entire test will be rerun.
- (9) If upstream control mortality exceeds 10%, the entire test will be rerun using reconstituted water as the dilutant.

E. SCHEDULE OF COMPLIANCE

1. By **June 5, 2010** the permittee shall submit an engineering report to describe facility upgrades and modifications that will be necessary to allow the facility to meet the final effluent limitations for total residual chlorine in Table A on Page 3 of 9.
2. By **December 5, 2010** the permittee shall submit an application for a construction permit to construct facilities as necessary to enable the treatment facility to comply with the final effluent limitations described herein.
3. By **December 5, 2011** the permittee shall submit a construction progress report.
4. By **June 5, 2012** the permittee shall complete construction of whatever facilities are needed to comply with the final effluent limitations described herein

SUMMARY OF TEST METHODOLOGY FOR WHOLE-EFFLUENT TOXICITY TESTS

Whole-effluent-toxicity test required in NPDES permits shall use the following test conditions when performing single or multiple dilution methods. Any future changes in methodology will be supplied to the permittee by the Missouri Department of Natural Resources (MDNR). Unless more stringent methods are specified by the DNR, the procedures shall be consistent with the most current edition of Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms,

Test conditions for Ceriodaphnia dubia:

| | |
|----------------------------------|--|
| Test duration: | 48 h |
| Temperature: | 25 ± 1°C Temperatures shall not deviate by more than 3°C during the test. |
| Light Quality: | Ambient laboratory illumination |
| Photoperiod: | 16 h light, 8 h dark |
| Size of test vessel: | 30 mL (minimum) |
| Volume of test solution: | 15 mL (minimum) |
| Age of test organisms: | <24 h old |
| No. of animals/test vessel: | 5 |
| No. of replicates/concentration: | 4 |
| No. of organisms/concentration: | 20 (minimum) |
| Feeding regime: | None (feed prior to test) |
| Aeration: | None |
| Dilution water: | Upstream receiving water; if no upstream flow, synthetic water modified to reflect effluent hardness. |
| Endpoint: | Pass/Fail (Statistically significant Mortality when compared to upstream receiving water control or synthetic control if upstream water was not available at $p \leq 0.05$) |
| Test acceptability criterion: | 90% or greater survival in controls |

Test conditions for Pimephales promelas:

| | |
|----------------------------------|--|
| Test duration: | 48 h |
| Temperature: | 25 ± 1°C Temperatures shall not deviate by more than 3°C during the test. |
| Light Quality: | Ambient laboratory illumination |
| Photoperiod: | 16 h light/ 8 h dark |
| Size of test vessel: | 250 mL (minimum) |
| Volume of test solution: | 200 mL (minimum) |
| Age of test organisms: | 1-14 days (all same age) |
| No. of animals/test vessel: | 10 |
| No. of replicates/concentration: | 4 (minimum) single dilution method 2 (minimum) multiple dilution method |
| No. of organisms/concentration: | 40 (minimum) single dilution method 20 (minimum) multiple dilution method |
| Feeding regime: | None (feed prior to test) |
| Aeration: | None, unless DO concentration falls below 4.0 mg/L; rate should not exceed 100 bubbles/min. |
| Dilution water: | Upstream receiving water; if no upstream flow, synthetic water modified to reflect effluent hardness. |
| Endpoint: | Pass/Fail (Statistically significant Mortality when compared to upstream receiving water control or synthetic control if upstream water was not available at $p \leq 0.05$) |
| Test Acceptability criterion: | 90% or greater survival in controls |

Missouri Department of Natural Resources
FACT SHEET
FOR THE PURPOSE OF RENEWAL
OF
MO-0110752
NPSD – COUNTRY CLUB OF SUGAR CREEK

The Federal Water Pollution Control Act ("Clean Water Act" Section 402 Public Law 92-500 as amended) established the National Pollution Discharge Elimination System (NPDES) permit program. This program regulates the discharge of pollutants from point sources into the waters of the United States, and the release of storm water from certain point sources. All such discharges are unlawful without a permit (Section 301 of the "Clean Water Act"). After a permit is obtained, a discharge not in compliance with all permit terms and conditions is unlawful. Missouri State Operating Permits (MSOPs) are issued by the Director of the Missouri Department of Natural Resources (department) under an approved program, operating in accordance with federal and state laws (Federal "Clean Water Act" and "Missouri Clean Water Law" Section 644 as amended). MSOPs are issued for a period of five (5) years unless otherwise specified.

As per [40 CFR Part 124.8(a)] and [10 CSR 20-6.020(1)2.] a Factsheet shall be prepared to give pertinent information regarding the applicable regulations, rationale for the development of effluent limitations and conditions, and the public participation process for the Missouri State Operating Permit (operating permit) listed below.

A Factsheet is not an enforceable part of an operating permit.

This Factsheet is for a Major , Minor , Industrial Facility ; Variance ;
Master General Permit ; General Permit Covered Facility ; and/or permit with widespread public interest .

Part I – Facility Information

Facility Type: POTW
Facility SIC Code(s): 4952

Facility Description:

Extended aeration/sock filters/chlorination/aerated sludge holding tank/sludge disposal is by contract hauler/sludge is land applied

Application Date: June 4, 2008

Expiration Date: December 11, 2008

Last Inspection: 08/26/2004 in Compliance ; Non-Compliance

OUTFALL(S) TABLE:

| OUTFALL | DESIGN FLOW (CFS) | TREATMENT LEVEL | EFFLUENT TYPE | DISTANCE TO CLASSIFIED SEGMENT (MI) |
|---------|-------------------|-----------------|---------------|-------------------------------------|
| #001 | 0.18 | Advanced | Domestic | 3.31 |

Outfall #001

Legal Description: SE ¼, NE ¼, SW ¼, Sec. 7, T43N, R5E, Jefferson County

Latitude/Longitude: +3828326/-09030091

Receiving Stream: Unnamed Tributary to Saline Creek (U) (Losing)

First Classified Stream and ID: Saline Creek (C) (02190)

USGS Basin & Sub-watershed No.: (07140102-080004)

Water Quality History:

No permit exceedences in the last five years.

Comments:

None.

Part II – Operator Certification Requirements

As per [10 CSR 20-6.010(8) Terms and Conditions of a Permit], permittees shall operate and maintain facilities to comply with the Missouri Clean Water Law and applicable permit conditions and regulations. Operators or supervisors of operations at regulated wastewater treatment facilities shall be certified in accordance with [10 CSR 20-9.020(2)] and any other applicable state law or regulation. As per [10 CSR 20-9.010(2)(A)], requirements for operation by certified personnel shall apply to all wastewater treatment systems, if applicable, as listed below:

Check boxes below that are applicable to the facility;

- Owned or operated by or for:
 - Municipalities
 - Public Sewer District:
 - County
 - Public Water Supply Districts:
 - Private sewer company regulated by the Public Service Commission:
 - State or Federal agencies:

Each of the above entities are only applicable if they have a Population Equivalent greater than two hundred (200) and/or fifty (50) or more service connections.

- Department required:
The Department requires this facility to retain the services of a certified operator due to:

This facility currently requires an operator with a **“B”** Certification Level. Please see **Appendix A - Classification Worksheet** Modifications made to the wastewater treatment facility may cause the classification to be modified.

Lead Operator’s Name: Joseph Richardson
Certification Number: 4842
Certification Level: A

- This facility does not currently retain an operator with the correct level of certification required to operate the wastewater treatment facility. Missouri Clean Water Law and its implementing regulation 10 CSR 20-9.020(2)(F) allows the department to develop a schedule of activities including the date by which compliance shall be obtained. This schedule of activities shall be established in this operating permit as a Schedule of Compliance.

Not Applicable ; This facility is not required to have a certified operator.

Part III – Receiving Stream Information

APPLICABLE DESIGNATIONS OF WATERS OF THE STATE:

As per Missouri’s Effluent Regulations [10 CSR 20-7.015], the waters of the state are divided into the below listed seven (7) categories. Each category lists effluent limitations for specific parameters, which are presented in each outfall’s Effluent Limitation Table and further discussed in the Derivation & Discussion of Limits section.

- Missouri or Mississippi River [10 CSR 20-7.015(2)]:
- Lake or Reservoir [10 CSR 20-7.015(3)]:
- Losing [10 CSR 20-7.015(4)]:
- Metropolitan No-Discharge [10 CSR 20-7.015(5)]:
- Special Stream [10 CSR 20-7.015(6)]:
- Subsurface Water [10 CSR 20-7.015(7)]:
- All Other Waters [10 CSR 20-7.015(8)]:

10 CSR 20-7.031 Missouri Water Quality Standards, the department defines the Clean Water Commission water quality objectives in terms of "water uses to be maintained and the criteria to protect those uses." The receiving stream and/or 1st classified receiving stream’s beneficial water uses to be maintained are located in the Receiving Stream Table located below in accordance with [10 CSR 20-7.031(3)].

RECEIVING STREAM(S) TABLE:

| WATERBODY NAME | CLASS | WBID | DESIGNATED USES* | 8-DIGIT HUC | EDU** |
|-----------------------------------|-------|-------|--------------------|-------------|---------------|
| Unnamed Tributary to Saline Creek | U | | General, Losing | 07140102 | Ozark Meramec |
| Saline Creek | C | 02190 | LWW, AQL, WBC-B*** | | |

* - Irrigation (IRR), Livestock & Wildlife Watering (LWW), Protection of Warm Water Aquatic Life and Human Health-Fish Consumption (AQL), Cool Water Fishery(CLF), Cold Water Fishery (CDF), Whole Body Contact Recreation (WBC), Secondary Contact Recreation (SCR), Drinking Water Supply (DWS), Industrial (IND), Groundwater (GRW).

** - Ecological Drainage Unit

*** - UAA conducted on May 15, 2007 and approved on November 19, 2007.

RECEIVING STREAM(S) LOW-FLOW VALUES TABLE:

| RECEIVING STREAM (U, C, P) | LOW-FLOW VALUES (CFS) | | |
|---------------------------------------|-----------------------|------|-------|
| | 1Q10 | 7Q10 | 30Q10 |
| Unnamed Tributary to Saline Creek (U) | 0.0 | 0.0 | 0.0 |
| Saline Creek (C) | 0.0 | 0.0 | 0.1 |

Mixing Zone: Not Allowed [10 CSR 20-7.031(4)(A)4.B.(I)(a)].

Zone of Initial Dilution: Not Allowed [10 CSR 20-7.031(4)(A)4.B.(I)(b)].

RECEIVING STREAM MONITORING REQUIREMENTS:

No receiving water monitoring requirements recommended at this time.

Part IV – Rationale and Derivation of Effluent Limitations & Permit Conditions

ALTERNATIVE EVALUATIONS FOR NEW FACILITIES:

As per [10 CSR 20-7.015(4)(A)], discharges to losing streams shall be permitted only after other alternatives including land application, discharges to a gaining stream and connection to a regional wastewater treatment facility have been evaluated and determined to be unacceptable for environmental and/or economic reasons.

Not Applicable ;

The facility does not discharge to a Losing Stream as defined by [10 CSR 20-2.010(36)] & [10 CSR 20-7.031(1)(N)], or is an existing facility.

ANTI-BACKSLIDING:

A provision in the Federal Regulations [CWA §303(d)(4); CWA §402(c); 40 CFR Part 122.44(I)] that requires a reissued permit to be as stringent as the previous permit with some exceptions.

- All limits in this Factsheet are at least as protective as those previously established; therefore, backsliding does not apply.

ANTIDegradation:

In accordance with Missouri's Water Quality Standard [10 CSR 20-7.031(2)], the department is to document by means of Antidegradation Review that the use of a water body's available assimilative capacity is justified. Degradation is justified by documenting the socio-economic importance of a discharging activity after determining the necessity of the discharge.

- Renewal no degradation proposed and no further review necessary.

BIO-SOLIDS, SLUDGE, & SEWAGE SLUDGE:

Bio-solids are solid materials resulting from wastewater treatment that meet federal and state criteria for beneficial uses (i.e. fertilizer). Sludge is any solid, semi-solid, or liquid waste generated from a municipal, commercial, or industrial wastewater treatment plant, water supply treatment plant, or air pollution control facility or any other such waste having similar characteristics and effect. Sewage sludge is solids, semi-solids, or liquid residue generated during the treatment of domestic sewage in a treatment works; including but not limited to, domestic septage; scum or solids removed in primary, secondary, or advanced wastewater treatment process; and a material derived from sewage sludge. Sewage sludge does not include ash generated during the firing of sewage sludge in a sewage sludge incinerator or grit and screening generated during preliminary treatment of domestic sewage in a treatment works.

Applicable (renewal and modifications to existing operating permits) ;

This facility has been approved to land apply as per Permit Standard Conditions III and a department approved bio-solids management plan.

COMPLIANCE AND ENFORCEMENT:

Enforcement is the action taken by the Water Protection Program (WPP) to bring an entity into compliance with the Missouri Clean Water Law, its implementing regulations, and/or any terms and conditions of an operating permit. The primary purpose of the enforcement activity in the WPP is to resolve violations and return the entity to compliance.

Not Applicable ;

The permittee/facility is not currently under Water Protection Program enforcement action.

PRETREATMENT PROGRAM:

The reduction of the amount of pollutants, the elimination of pollutants, or the alteration of the nature of pollutant properties in wastewater prior to or in lieu of discharging or otherwise introducing such pollutants into a Publicly Owned Treatment Works [40 CFR Part 403.3(q)].

Pretreatment programs are required at any POTW (or combination of POTW operated by the same authority) and/or municipality with a total design flow greater than 5.0 MGD and receiving industrial wastes that interfere with or pass through the treatment works or are otherwise subject to the pretreatment standards. Pretreatment programs can also be required at POTWs/municipals with a design flow less than 5.0 MGD if needed to prevent interference with operations or pass through.

Several special conditions pertaining to the permittee's pretreatment program may be included in the permit, and are as follows:

- Implementation and enforcement of the program,
- Annual pretreatment report submittal,
- Submittal of list of industrial users,
- Technical evaluation of need to establish local limitations, and
- Submittal of the results of the evaluation

Not Applicable ;

The permittee, at this time, is not required to have a Pretreatment Program or does not have an approved pretreatment program.

REASONABLE POTENTIAL ANALYSIS (RPA):

Federal regulation [40 CFR Part 122.44(d)(1)(i)] requires effluent limitations for all pollutants that are or may be discharged at a level that will cause or have the reasonable potential to cause or contribute to an in-stream excursion above narrative or numeric water quality standard.

Not Applicable ;

A RPA was not conducted for this facility.

REMOVAL EFFICIENCY:

Removal efficiency is a method by which the Federal Regulations define Secondary Treatment and Equivalent to Secondary Treatment, which applies to Biochemical Oxygen Demand 5-day (BOD₅) and Total Suspended Solids (TSS) for Publicly Owned Treatment Works (POTWs)/municipals. Please see the United States Environmental Protection Agency's (EPA) website for interpretation of percent removal requirements for National Pollutant Discharge Elimination System Permit Application Requirements for Publicly Owned Treatment Works and Other Treatment Works Treating Domestic Sewage @ www.epa.gov/fedrgstr/EPA-WATER/1999/August/Day-04/w18866.htm.

Applicable ;

Secondary Treatment is 85% removal [40 CFR Part 133.102(a)(3) & (b)(3)].

SANITARY SEWER OVERFLOWS (SSOs), AND INFLOW & INFILTRATION (I&I):

Collection systems are a critical element in the successful performance of the wastewater treatment process. Under certain conditions, poorly designed, built, managed, operated, and/or maintained systems can pose risks to public health, the environment, or both. Causes of SSOs include, but are not limited to, the following: high levels of I&I during wet weather; blockages; structural, mechanical, or electrical failures; collapsed or broken sewer pipes; insufficient conveyance capacity; and vandalism. Effective and continuous management, operation, and maintenance, as well as ensuring adequate capacity and rehabilitation when necessary are critical to maintaining collection system capacity and performance while extending the life of the system.

Not Applicable ;

This facility is not required to develop or implement a program for maintenance and repair of the collection system; however, it is a violation of Missouri State Environmental Laws and Regulations to allow untreated wastewater to discharge to waters of the state.

SCHEDULE OF COMPLIANCE (SOC):

A schedule of remedial measures included in a permit, including an enforceable sequence of interim requirements (actions, operations, or milestone events) leading to compliance with the Missouri Clean Water Law, its implementing regulations, and/or the terms and conditions of an operating permit.

Applicable ;

The time given for effluent limitations of this permit listed under Interim Effluent Limitation and Final Effluent Limitations were established in accordance with [10 CSR 20-7.031(10)].

STORM WATER POLLUTION PREVENTION PLAN (SWPPP):

A plan to schedule activities, prohibitions of practices, maintenance procedures, and other management practices to prevent or reduce the pollution of waters of the state. The plan may include, but is not limited to, treatment requirements, operating procedures, and practices to control facility site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage.

Applicable ;

A SWPPP shall be developed and implemented for each site and shall incorporate required practices identified by the department with jurisdiction, incorporate erosion control practices specific to site conditions, and provide for maintenance and adherence to the plan.

Not Applicable ;

At this time, the permittee is not required to develop and implement a SWPPP.

VARIANCE:

As per the Missouri Clean Water Law § 644.061.4, variances shall be granted for such period of time and under such terms and conditions as shall be specified by the commission in its order. The variance may be extended by affirmative action of the commission. In no event shall the variance be granted for a period of time greater than is reasonably necessary for complying with the Missouri Clean Water Law §§644.006 to 644.141 or any standard, rule or regulation promulgated pursuant to Missouri Clean Water Law §§644.006 to 644.141.

Not Applicable ;

This operating permit is not drafted under premises of a petition for variance.

WASTELOAD ALLOCATIONS (WLA) FOR LIMITS:

As per [10 CSR 20-2.010(78)], the amount of pollutant each discharger is allowed by the department to release into a given stream after the department has determined total amount of pollutant that may be discharged into that stream without endangering its water quality.

Not Applicable ;

Wasteload allocations were not calculated.

WLA MODELING:

There are two general types of effluent limitations, technology-based effluent limits (TBELs) and water quality based effluent limits (WQBELs). If TBELs do not provide adequate protection for the receiving waters, then WQBEL must be used.

Not Applicable ;

A WLA study was either not submitted or determined not applicable by department staff.

WHOLE EFFLUENT TOXICITY (WET) TEST:

A WET test is a quantifiable method of determining if a discharge from a facility may be causing toxicity to aquatic life by itself, in combination with or through synergistic responses when mixed with receiving stream water.

Applicable ;

In accordance with the Clean Water Act (CWA) §101(a)(3), requiring WET testing is reasonably appropriate for site-specific Missouri State Operating Permits for discharges to waters of the state issued under the National Pollutant Discharge Elimination System. Furthermore, WET testing is a means by which the department determines that [10 CSR 20-7.031(3)(D, F, & G)] are being met by the permitted facility. In addition to justification for the WET testing, WET tests are required under [10 CSR 20-6.010(8)(A)4] to be performed by specialists who are properly trained in conducting the test according to the methods prescribed by the Federal Government as referenced in [40 CFR Part 136]. WET test will be required by all facilities meeting the following criteria:

- Facility is a designated Major.
- Facility continuously or routinely exceeds its design flow.
- Facility (industrial) that alters its production process throughout the year.
- Facility handles large quantities of toxic substances, or substances that are toxic in large amounts.
- Facility has Water Quality-based Effluent Limitations for toxic substances (other than NH₃)
- Facility is a municipality or domestic discharger with a Design Flow \geq 22,500 gpd.
- Other – please justify.

303(d) LIST & TOTAL MAXIMUM DAILY LOAD (TMDL):

Section 303(d) of the federal Clean Water Act requires that each state identify waters that are not meeting water quality standards and for which adequate water pollution controls have not been required. Water quality standards protect such beneficial uses of water as whole body contact (such as swimming), maintaining fish and other aquatic life, and providing drinking water for people, livestock and wildlife. The 303(d) list helps state and federal agencies keep track of waters that are impaired but not addressed by normal water pollution control programs.

A TMDL is a calculation of the maximum amount of a given pollutant that a body of water can absorb before its water quality is affected. If a water body is determined to be impaired as listed on the 303(d) list, then a watershed management plan will be developed that shall include the TMDL calculation

Not Applicable ;

This facility does not discharge to a 303(d) listed stream.

Part V – Effluent Limits Determination

Outfall #001 – Main Facility Outfall

EFFLUENT LIMITATIONS TABLE:

| PARAMETER | UNIT | BASIS FOR LIMITS | DAILY MAXIMUM | WEEKLY AVERAGE | MONTHLY AVERAGE | MODIFIED | PREVIOUS PERMIT LIMITATIONS |
|---------------------------------------|--|------------------|---|----------------|-----------------|----------|-----------------------------|
| FLOW | GPD | 1 | * | | * | No | */* |
| BOD ₅ | MG/L | 1 | | 15 | 10 | No | 15/10 |
| TSS | MG/L | 1 | | 20 | 15 | No | 20/15 |
| pH | SU | 1 | 6-9 | | 6-9 | No | 6-9 |
| TEMPERATURE | °C | 1/8 | * | | * | YES | *** |
| AMMONIA AS N (MAY 1 – OCT 31) | MG/L | 2/3/5 | * | | * | YES | *** |
| AMMONIA AS N (NOV 1 – APR 30) | MG/L | 2/3/5 | * | | * | YES | *** |
| ESCHERICHIA COLI | ** | 1/2 | Please see Escherichia Coli (E. coli) in the Derivation and Discussion Section below. | | | | |
| NITRATE + NITRITE | MG/L | 9 | * | | * | YES | *** |
| FECAL COLIFORM | ** | 1/2 | 1000 | | 400 | No | 1000/400 |
| CHLORINE, TOTAL RESIDUAL | MG/L | 1/2 | 0.017 | | 0.008 | YES | 1.0/1.0 |
| OIL & GREASE (MG/L) | MG/L | 1 | 15 | | 10 | YES | *** |
| WHOLE EFFLUENT TOXICITY (WET) TEST | % Survival | 11 | Please see WET Test in the Derivation and Discussion Section below. | | | | |
| MONITORING FREQUENCY | Please see Minimum Sampling and Reporting Frequency Requirements in the Derivation and Discussion Section below. | | | | | | |

* - Monitoring requirement only

** - # of colonies/100mL; the Monthly Average for Fecal Coliform is a geometric mean.

*** - Parameter not previously established in previous state operating permit.

N/A – Not applicable

Basis for Limitations Codes:

- | | |
|--|------------------------------------|
| 1. State or Federal Regulation/Law | 7. Antidegradation Policy |
| 2. Water Quality Standard (includes RPA) | 8. Water Quality Model |
| 3. Water Quality Based Effluent Limits | 9. Best Professional Judgment |
| 4. Lagoon Policy | 10. TMDL or Permit in lieu of TMDL |
| 5. Ammonia Policy | 11. WET Test Policy |
| 6. Dissolved Oxygen Policy | |

OUTFALL #001 – DERIVATION AND DISCUSSION OF LIMITS:

- **Flow.** In accordance with [40 CFR Part 122.44(i)(1)(ii)] the volume of effluent discharged from each outfall is needed to assure compliance with permitted effluent limitations. If the permittee is unable to obtain effluent flow, then it is the responsibility of the permittee to inform the department, which may require the submittal of an operating permit modification.
- **Biochemical Oxygen Demand (BOD₅).** Effluent limitations have been retained from previous state operating permit, please see the **APPLICABLE DESIGNATION OF WATERS OF THE STATE** sub-section of the **Receiving Stream Information.**
- **Total Suspended Solids (TSS).** Effluent limitations have been retained from previous state operating permit, please see the **APPLICABLE DESIGNATION OF WATERS OF THE STATE** sub-section of the **Receiving Stream Information.**
- **pH.** Effluent limitations have been retained from previous state operating permit, please see the **APPLICABLE DESIGNATION OF WATERS OF THE STATE** sub-section of the **Receiving Stream Information.**
- **Temperature.** Monitoring requirement due to the toxicity of Ammonia varies by temperature
- **Total Ammonia Nitrogen.** Monitoring requirement only to determine reasonable potential to cause an excursion in water quality criteria.

- **Escherichia coli (E. coli)**. This facility may be required to have *E. coli* effluent limitations when Missouri adopts the implementation of the *E. coli* standards, as per [10 CSR 20-7.031(4)(C)].
- **Nitrate + Nitrite**. Monitoring requirement only to determine reasonable potential. The receiving stream is a losing stream and has direct hydraulic connection to ground water. Nitrate has a drinking water limit of 10 mg/L
- **Fecal Coliform**. Discharge shall not contain more than a monthly geometric mean of 400 colonies/100 mL and a daily maximum of 1000 colonies/100 mL, please see the **APPLICABLE DESIGNATION OF WATERS OF THE STATE** sub-section of the **Receiving Stream Information**. [10 CSR 20-7.015(4)(B)4.]. Future renewals of the facility operating permit will contain effluent limitations for *E. coli*, which will replace fecal coliform as the applicable bacteria criteria in Missouri’s water quality standards.
- **Total Residual Chlorine (TRC)**. Warm-water Protection of Aquatic Life CCC = 10 µg/L, CMC = 19 µg/L [10 CSR 20-7.031, Table A]. Background TRC = 0.0 µg/L.

Chronic WLA: $C_e = ((10.08 + 0.0)10 - (0.0 * 0.0))/10.08$
 $C_e = 10 \mu\text{g/L}$

Acute WLA: $C_e = ((10.08 + 0.0)19 - (0.0 * 0.0))/10.08$
 $C_e = 19 \mu\text{g/L}$

$LTA_c = 10 (0.527) = 5.3 \mu\text{g/L}$ [CV = 0.6, 99th Percentile]
 $LTA_a = 19 (0.321) = 6.1 \mu\text{g/L}$ [CV = 0.6, 99th Percentile]

Use most protective number of LTA_c or LTA_a .

$MDL = 5.3 (3.11) = 16.5 \mu\text{g/L}$ [CV = 0.6, 99th Percentile]
 $AML = 5.3 (1.55) = 8.2 \mu\text{g/L}$ [CV = 0.6, 95th Percentile, n = 4]

Total Residual Chlorine effluent limits of 0.017 mg/L daily maximum, 0.008 mg/L monthly average are recommended if chlorine is used as a disinfectant. Standard compliance language for TRC, including the minimum level (ML), should be included in the permit.

- **Oil & Grease**. Conventional pollutant, effluent limitation for protection of aquatic life; 10 mg/L monthly average, 15 mg/L daily maximum.
- **WET Test**. WET Testing schedules and intervals are established in accordance with the department’s Permit Manual; Section 5.2 *Effluent Limits / WET Testing for Compliance Bio-monitoring*. It is recommended that WET testing be conducted during the period of lowest stream flow.

- Chronic
- Acute

No less than ONCE/PERMIT CYCLE:

- Municipality or domestic facility with a design flow $\geq 22,500$ gpd, but less than 1.0 MGD.
- Other, please justify.

No less than ONCE/YEAR:

- Facility is designated as a Major facility or has a design flow ≥ 1.0 MGD.
- Facility continuously or routinely exceeds their design flow.
- Facility exceeds its design population equivalent (PE) for BOD₅ whether or not its design flow is being exceeded.
- Facility has Water Quality-based effluent limitations for toxic substances (other than NH₃).

No less than TWICE/YEAR:

- Facility is subject to production processes alterations throughout the year.
- Facility handles large quantities of toxic substances, or substances that are toxic in large amounts.
- Facility has been granted seasonal relief of numeric limitations.

Allowable Effluent Concentration (AEC) calculations determine if the facility is to conduct single dilution or multiple dilution WET testing. Facilities that discharge to unclassified or Class C receiving streams, the AEC% is 100%. Facilities with less than 100% for an AEC% will have multiple dilution WET testing. Facilities that discharge to Lakes and have Acute WET testing, the AEC% is 100% due to [10 CSR 20-7.031(4)(A)4.B.(IV)(b)] ZID not allowed for Lakes.

- **Minimum Effluent Sampling and Reporting Frequency Requirements**

| PARAMETER | SAMPLING FREQUENCY | REPORTING FREQUENCY |
|----------------------------------|--------------------|---------------------|
| FLOW | ONCE/DAY | ONCE/MONTH |
| BOD ₅ | ONCE/MONTH | ONCE/MONTH |
| TSS | ONCE/MONTH | ONCE/MONTH |
| PH | ONCE/MONTH | ONCE/MONTH |
| FECAL COLIFORM | ONCE/MONTH | ONCE/MONTH |
| CHLORINE, TOTAL RESIDUAL | ONCE/MONTH | ONCE/MONTH |
| OIL & GREASE | ONCE/MONTH | ONCE/MONTH |
| TEMPERATURE | ONCE/QUARTER | ONCE/QUARTER |
| AMMONIA AS N (MAY 1 – OCT 31) | ONCE/QUARTER | ONCE/QUARTER |
| AMMONIA AS N (NOV 1 – APR 30) | ONCE/QUARTER | ONCE/QUARTER |
| NITRATE + NITRITE | ONCE/QUARTER | ONCE/QUARTER |

- **Minimum Influent Sampling and Reporting Frequency Requirements**

| PARAMETER | SAMPLING FREQUENCY | REPORTING FREQUENCY |
|------------------|--------------------|---------------------|
| BOD ₅ | ONCE/QUARTER | ONCE/QUARTER |
| TSS | ONCE/QUARTER | ONCE/QUARTER |

Part VI – Administrative Requirements

On the basis of preliminary staff review and the application of applicable standards and regulations, the Department, as administrative agent for the Missouri Clean Water Commission, proposes to issue a permit(s) subject to certain effluent limitations, schedules, and special conditions contained herein and within the operating permit. The proposed determinations are tentative pending public comment.

PUBLIC NOTICE:

As per the Missouri Clean Water Law, the Missouri Clean Water Commission, and the federal Clean Water Act, persons wishing to comment on Missouri State Operating Permits are directed to do so by a department approved Public Notice coversheet. This Public Notice coversheet is attached to a Missouri State Operating Permit during the Public Notice period.

- The Public Notice period for this operating permit is tentatively schedule to begin on April 24, 2009 or is in process.

DATE OF FACT SHEET: APRIL 16, 2009

COMPLETED BY:

STEVEN LANG, ENVIRONMENTAL ENGINEER
ST. LOUIS REGIONAL OFFICE
(314) 416-2960
STEVE.LANG@DNR.MO.GOV

Part VII – Appendices

APPENDIX A - CLASSIFICATION WORKSHEET:

| ITEM | POINTS POSSIBLE | POINTS ASSIGNED |
|---|--|-----------------|
| Maximum Population Equivalent (P.E.) served (Max 10 pts.) | 1 pt./10,000 PE or major fraction thereof. | 0 |
| Maximum: 10 pt Design Flow (avg. day) or peak month; use greater (Max 10 pts.) | 1 pt. / MGD or major fraction thereof. | 0 |
| EFFLUENT DISCHARGE RECEIVING WATER SENSITIVITY: | | |
| Missouri or Mississippi River | 0 | |
| All other stream discharges except to losing streams and stream reaches supporting whole body contact | 1 | |
| Discharge to lake or reservoir outside of designated whole body contact recreational area | 2 | |
| Discharge to losing stream, or stream, lake or reservoir area supporting whole body contact recreation | 3 | 3 |
| PRELIMINARY TREATMENT - Headworks | | |
| Screening and/or comminution | 3 | 3 |
| Grit removal | 3 | |
| Plant pumping of main flow (lift station at the headworks) | 3 | |
| PRIMARY TREATMENT | | |
| Primary clarifiers | 5 | |
| Combined sedimentation/digestion | 5 | |
| Chemical addition (except chlorine, enzymes) | 4 | |
| REQUIRED LABORATORY CONTROL – performed by plant personnel (highest level only) | | |
| Lab work conducted outside of plant | 0 | 0 |
| Push – button or visual methods for simple test such as pH, Settleable solids | 3 | |
| Additional procedures such as DO, COD, BOD, titrations, solids, volatile content | 5 | |
| More advanced determinations such as BOD seeding procedures, fecal coliform, nutrients, total oils, phenols, etc. | 7 | |
| Highly sophisticated instrumentation, such as atomic absorption and gas chromatograph | 10 | |
| ALTERNATIVE FATE OF EFFLUENT | | |
| Direct reuse or recycle of effluent | 6 | |
| Land Disposal – low rate | 3 | |
| High rate | 5 | |
| Overland flow | 4 | |
| Total from page ONE (1) | ---- | 6 |

APPENDIX # - CLASSIFICATION WORKSHEET (CONTINUED):

| ITEM | POINTS POSSIBLE | POINTS ASSIGNED |
|--|-----------------|-----------------|
| VARIATION IN RAW WASTE (highest level only) (DMR exceedances and Design Flow exceedances) | | |
| Variation do not exceed those normally or typically expected | 0 | |
| Recurring deviations or excessive variations of 100 to 200 % in strength and/or flow | 2 | 2 |
| Recurring deviations or excessive variations of more than 200 % in strength and/or flow | 4 | |
| Raw wastes subject to toxic waste discharge | 6 | |
| SECONDARY TREATMENT | | |
| Trickling filter and other fixed film media with secondary clarifiers | 10 | |
| Activated sludge with secondary clarifiers (including extended aeration and oxidation ditches) | 15 | 15 |
| Stabilization ponds without aeration | 5 | |
| Aerated lagoon | 8 | |
| Advanced Waste Treatment Polishing Pond | 2 | |
| Chemical/physical – without secondary | 15 | |
| Chemical/physical – following secondary (Sock Filters) | 10 | 10 |
| Biological or chemical/biological | 12 | |
| Carbon regeneration | 4 | |
| DISINFECTION | | |
| Chlorination or comparable | 5 | 5 |
| Dechlorination | 2 | 2 |
| On-site generation of disinfectant (except UV light) | 5 | |
| UV light | 4 | |
| SOLIDS HANDLING - SLUDGE | | |
| Solids Handling Thickening | 5 | |
| Anaerobic digestion | 10 | |
| Aerobic digestion | 6 | 6 |
| Evaporative sludge drying | 2 | |
| Mechanical dewatering | 8 | |
| Solids reduction (incineration, wet oxidation) | 12 | |
| Land application | 6 | 6 |
| Total from page TWO (2) | ---- | 46 |
| Total from page ONE (1) | --- | 6 |
| Grand Total | --- | 52 |

- A: 71 points and greater
- B: 51 points – 70 points
- C: 26 points – 50 points
- D: 0 points – 25 points