

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES

MISSOURI CLEAN WATER COMMISSION



MISSOURI STATE OPERATING PERMIT

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92nd Congress) as amended,

Permit No. MO-0123021

Owner: Wainwright Industries, Incorporated
Address: 17 Cermak Boulevard, St. Peters, MO 63376

Continuing Authority: Same as above
Address: Same as above

Facility Name: Valley Park TCE Site - Wainwright Operable Unit
Facility Address: 224 Benton Street, Valley Park, MO 63088

Legal Description: Land Grant 2999, St. Louis County
UTM Coordinates: X= 718875, Y= 4269981

Receiving Stream: Meramec River (P)
First Classified Stream and ID: Meramec River (P) (2183) 303(d) List
USGS Basin & Sub-watershed No.: 07140102-1002

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

FACILITY DESCRIPTION

Outfall #001 Groundwater Remediation Treatment Unit - SIC #3499 - Certified Operator Not Required
Design flow is 165 gallons per minute (237,600 gallons per day)
Actual flow is 20,000 gallons per day

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Sections 640.013, 621.250, and 644.051.6 of the Law.

March 1, 2014
Effective Date

Sara Parker Pauley, Director, Department of Natural Resources

June 30, 2018
Expiration Date

John Madros, Director, Water Protection Program

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS					PAGE NUMBER 2 of 3	
					PERMIT NUMBER MO-0123021	
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective upon issuance and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
Outfall #001						
Flow	MGD	*		*	Once/week	24 hr. total.
Trichloroethylene (TCE)	µg/L	56		28	once/month	grab
Tetrachloroethylene (Perchloroethylene)(PCE)	µg/L	*		*	once/month	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>QUARTERLY</u> ; THE FIRST REPORT IS DUE <u>JULY 28, 2014</u> .						

* Monitoring requirement only.

B. STANDARD CONDITIONS

In addition to specified conditions stated herein, this permit is subject to the attached Part I standard conditions dated November 1, 2013, and hereby incorporated as though fully set forth herein.

C. SPECIAL CONDITIONS

1. This permit may be reopened and modified, or alternatively revoked and reissued, to:
 - (a) Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a) (2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
 - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
 - (2) controls any pollutant not limited in the permit.
 - (b) Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri's Water Quality Standards.
 - (c) Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri's list of waters of the state not fully achieving the state's water quality standards, also called the 303(d) list.

The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.

2. All outfalls must be clearly marked in the field.

3. Water Quality Standards

- (a) To the extent required by law, discharges to waters of the state shall not cause a violation of water quality standards rule under 10 CSR 20-7.031, including both specific and general criteria.
- (b) General Criteria. The following general water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:
 - (1) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
 - (2) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
 - (3) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
 - (4) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
 - (5) There shall be no significant human health hazard from incidental contact with the water;
 - (6) There shall be no acute toxicity to livestock or wildlife watering;
 - (7) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
 - (8) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.

4. Changes in Discharges of Toxic Substances

The permittee shall notify the Director as soon as it knows or has reason to believe:

- (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:"
 - (1) One hundred micrograms per liter (100 µg/L);
 - (2) Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,5 dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
 - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;
 - (4) The level established in Part A of the permit by the Director.
- (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.

5. Report as no-discharge when a discharge does not occur during the report period.

6. It is a violation of the Missouri Clean Water Law to fail to pay fees associated with this permit (644.055 RSMo).

MISSOURI DEPARTMENT OF NATURAL RESOURCES
FACT SHEET
FOR THE PURPOSE OF RENEWAL
OF
MO-0123021
VALLEY PARK TCE SITE-WAINWRIGHT OPERABLE UNIT

The Federal Water Pollution Control Act ("Clean Water Act" Section 402 Public Law 92-500 as amended) established the National Pollution Discharge Elimination System (NPDES) permit program. This program regulates the discharge of pollutants from point sources into the waters of the United States, and the release of storm water from certain point sources. All such discharges are unlawful without a permit (Section 301 of the "Clean Water Act"). After a permit is obtained, a discharge not in compliance with all permit terms and conditions is unlawful. Missouri State Operating Permits (MSOPs) are issued by the Director of the Missouri Department of Natural Resources (Department) under an approved program, operating in accordance with federal and state laws (Federal "Clean Water Act" and "Missouri Clean Water Law" Section 644 as amended). MSOPs are issued for a period of five (5) years unless otherwise specified.

As per [40 CFR Part 124.8(a)] and [10 CSR 20-6.020(1)2.] a Factsheet shall be prepared to give pertinent information regarding the applicable regulations, rationale for the development of effluent limitations and conditions, and the public participation process for the Missouri State Operating Permit (operating permit) listed below.

A Factsheet is not an enforceable part of an operating permit.

This Factsheet is for an Industrial Facility.

Part I – Facility Information

Facility Type: Industrial
Facility SIC Code(s): 3499

Facility Description:

The Wainwright Operable Unit is a groundwater remediation treatment unit located on the property at 224 Benton Avenue in Valley Park MO. The site was former location of Wainwright Industries Inc., which operated a metal stamping, tool and die shop onsite from 1947-1979. Trichloroethylene (TCE) and Tetrachloroethylene also known as Perchloroethylene (PCE) were used in a solvent degreasing system. Soil and groundwater became contaminated with TCE due to spills. A Groundwater Extraction Treatment System (GETS) is currently operated onsite to treat contaminated groundwater. Groundwater is pumped from a well on the north side of the building into the treatment system. A new well was drilled in 2010 due to the previous well not producing. VOC's are stripped from the water and sent to two 10,000 lb. activated carbon tanks. The design flow for the treatment unit is 165 gallons per minute or 237,600 gallons per day. The receiving stream for this facility is the Meramec River. The facility is operating under the supervision of the Department's Hazardous Waste Program.

Have any changes occurred at this facility or in the receiving water body that effects effluent limit derivation?

- No.

Application Date: 4/1/2013
Expiration Date: 10/23/2013
Last Inspection: 5/1/2013 In Compliance ; Non-Compliance

OUTFALL(S) TABLE:

OUTFALL	DESIGN FLOW (CFS)	TREATMENT LEVEL	EFFLUENT TYPE
#001	0.37	Physical	Remediated Groundwater

Facility Performance History & Comments:

The discharges Monitoring Reports (DMR's) were reviewed and the facility is in compliance with its discharge limits.

Part II – Receiving Stream Information

APPLICABLE DESIGNATIONS OF WATERS OF THE STATE:

As per Missouri’s Effluent Regulations [10 CSR 20-7.015], the waters of the state are divided into the below listed seven (7) categories. Each category lists effluent limitations for specific parameters, which are presented in each outfall’s Effluent Limitation Table and further discussed in the Derivation & Discussion of Limits section.

- Missouri or Mississippi River [10 CSR 20-7.015(2)]:
- Lake or Reservoir [10 CSR 20-7.015(3)]:
- Losing [10 CSR 20-7.015(4)]:
- Metropolitan No-Discharge [10 CSR 20-7.015(5)]:
- Special Stream [10 CSR 20-7.015(6)]:
- Subsurface Water [10 CSR 20-7.015(7)]:
- All Other Waters [10 CSR 20-7.015(8)]:

10 CSR 20-7.031 Missouri Water Quality Standards, the Department defines the Clean Water Commission water quality objectives in terms of "water uses to be maintained and the criteria to protect those uses." The receiving stream and 1st classified receiving stream’s beneficial water uses to be maintained are located in the Receiving Stream Table located below in accordance with [10 CSR 20-7.031(3)].

RECEIVING STREAM(S) TABLE:

WATERBODY NAME	CLASS	WBID	DESIGNATED USES*	DISTANCE TO CLASSIFIED SEGMENT	12-DIGIT HUC**
Meramec River	P	2183	LWW,AQL,CLF,WBC-A, SCR, DWS &IND.	0.0	07140102-1002

* - Irrigation (IRR), Livestock & Wildlife Watering (LWW), Protection of Warm Water Aquatic Life and Human Health-Fish Consumption (AQL), Cool Water Fishery(CLF), Cold Water Fishery (CDF), Whole Body Contact Recreation (WBC), Secondary Contact Recreation (SCR), Drinking Water Supply (DWS), Industrial (IND), Groundwater (GRW). ** - Hydrologic Unit Code

RECEIVING STREAM(S) LOW-FLOW VALUES TABLE:

RECEIVING STREAM (U, C, P)	LOW-FLOW VALUES (CFS)		
	1Q10	7Q10	30Q10
Meramec River (P)	322	337	372

MIXING CONSIDERATIONS TABLE:

MIXING ZONE (CFS) [10 CSR 20-7.031(4)(A)4.B.(III)(a)]		ZONE OF INITIAL DILUTION (CFS) [10 CSR 20-7.031(4)(A)4.B.(III)(b)]	
7Q10	30Q10	1Q10	7Q10
81	84	3.7	3.7

RECEIVING STREAM MONITORING REQUIREMENTS:

No receiving water monitoring requirements recommended at this time.

Part III – Rationale and Derivation of Effluent Limitations & Permit Conditions

ALTERNATIVE EVALUATIONS FOR NEW FACILITIES:

As per [10 CSR 20-7.015(4)(A)], discharges to losing streams shall be permitted only after other alternatives including land application, discharges to a gaining stream and connection to a regional wastewater treatment facility have been evaluated and determined to be unacceptable for environmental and/or economic reasons.

Not Applicable; The facility does not discharge to a Losing Stream as defined by [10 CSR 20-2.010(36)] & [10 CSR 20-7.031(1)(N)], or is an existing facility.

ANTI-BACKSLIDING:

A provision in the Federal Regulations [CWA §303(d)(4); CWA §402(c); 40 CFR Part 122.44(I)] that requires a reissued permit to be as stringent as the previous permit with some exceptions.

- All limits in this operating permit are at least as protective as those previously established; therefore, backsliding does not apply.

ANTIDegradation:

In accordance with Missouri's Water Quality Standard [10 CSR 20-7.031(2)], the Department is to document by means of Antidegradation Review that the use of a water body's available assimilative capacity is justified. Degradation is justified by documenting the socio-economic importance of a discharging activity after determining the necessity of the discharge.

- Renewal no degradation proposed and no further review necessary.

BIOSOLIDS & SEWAGE SLUDGE:

Biosolids are solid materials resulting from domestic wastewater treatment that meet federal and state criteria for beneficial uses (i.e. fertilizer). Sewage sludge is solids, semi-solids, or liquid residue generated during the treatment of domestic sewage in a treatment works; including but not limited to, domestic septage; scum or solids removed in primary, secondary, or advanced wastewater treatment process; and a material derived from sewage sludge. Sewage sludge does not include ash generated during the firing of sewage sludge in a sewage sludge incinerator or grit and screening generated during preliminary treatment of domestic sewage in a treatment works. Additional information regarding biosolids and sludge is located at the following web address:

<http://dnr.mo.gov/env/wpp/pub/index.html>, items WQ422 through WQ449.

Not applicable; this condition is not applicable to the permittee for this facility.

COMPLIANCE AND ENFORCEMENT:

Enforcement is the action taken by the Water Protection Program (WPP) to bring an entity into compliance with the Missouri Clean Water Law, its implementing regulations, and/or any terms and conditions of an operating permit. The primary purpose of the enforcement activity in the WPP is to resolve violations and return the entity to compliance.

Not Applicable; the permittee/facility is not currently under Water Protection Program enforcement action.

REASONABLE POTENTIAL ANALYSIS (RPA):

Federal regulation [40 CFR Part 122.44(d)(1)(i)] requires effluent limitations for all pollutants that are or may be discharged at a level that will cause or have the reasonable potential to cause or contribute to an in-stream excursion above narrative or numeric water quality standard.

In accordance with [40 CFR Part 122.44(d)(iii)] if the permit writer determines that any give pollutant has the reasonable potential to cause, or contribute to an in-stream excursion above the WQS, the permit must contain effluent limits for that pollutant.

Not Applicable; A RPA was not conducted for this facility. No reasonable potential to exceed Water Quality Limits since the Discharge Monitoring Reports (DMRs) for the last 5 years had reported zero values for Trichloroethylene (TCE) and Tetrachloroethylene (PCE).

SCHEDULE OF COMPLIANCE (SOC):

A schedule of remedial measures included in a permit, including an enforceable sequence of interim requirements (actions, operations, or milestone events) leading to compliance with the Missouri Clean Water Law, its implementing regulations, and/or the terms and conditions of an operating permit.

Not Applicable; this permit does not contain a SOC.

STORM WATER POLLUTION PREVENTION PLAN (SWPPP):

In accordance with 40 CFR 122.44(k) *Best Management Practices (BMPs)* to control or abate the discharge of pollutants when: (1) Authorized under section 304(e) of the Clean Water Act (CWA) for the control of toxic pollutants and hazardous substances from ancillary industrial activities; (2) Authorized under section 402(p) of the CWA for the control of storm water discharges; (3) Numeric effluent limitations are infeasible; or (4) the practices are reasonably necessary to achieve effluent limitations and standards or to carry out the purposes and intent of the CWA.

Not Applicable; at this time, the permittee is not required to develop and implement a SWPPP.

SPILL REPORTING:

Per 10 CSR 24-3.010, any emergency involving a hazardous substance must be reported to the department's 24 hour Environmental Emergency Response hotline at (573) 634-2436 at the earliest practicable moment after discovery. The department may require the submittal of a written report detailing measures taken to clean up a spill. These reporting requirements apply whether or not the spill results in chemicals or materials leaving the permitted property or reaching waters of the state. This requirement is in addition to the Noncompliance Reporting requirement found in Standard Conditions Part I.

VARIANCE:

As per the Missouri Clean Water Law § 644.061.4, variances shall be granted for such period of time and under such terms and conditions as shall be specified by the commission in its order. The variance may be extended by affirmative action of the commission. In no event shall the variance be granted for a period of time greater than is reasonably necessary for complying with the Missouri Clean Water Law §§644.006 to 644.141 or any standard, rule or regulation promulgated pursuant to Missouri Clean Water Law §§644.006 to 644.141.

Not Applicable; This operating permit is not drafted under premises of a petition for variance.

WASTELOAD ALLOCATIONS (WLA) FOR LIMITS:

As per [10 CSR 20-2.010(78)], the amount of pollutant each discharger is allowed by the Department to release into a given stream after the Department has determined total amount of pollutant that may be discharged into that stream without endangering its water quality.

Not Applicable; Wasteload allocations were not calculated.

WLA MODELING:

There are two general types of effluent limitations, technology-based effluent limits (TBELs) and water quality based effluent limits (WQBELs). If TBELs do not provide adequate protection for the receiving waters, then WQBEL must be used.

Not Applicable; A WLA study was either not submitted or determined not applicable by Department staff.

WATER QUALITY STANDARDS:

Per [10 CSR 20-7.031(3)], General Criteria shall be applicable to all waters of the state at all times including mixing zones. Additionally, [40 CFR 122.44(d)(1)] directs the Department to establish in each NPDES permit to include conditions to achieve water quality established under Section 303 of the Clean Water Act, including State narrative criteria for water quality.

WHOLE EFFLUENT TOXICITY (WET) TEST:

A WET test is a quantifiable method of determining if a discharge from a facility may be causing toxicity to aquatic life by itself, in combination with or through synergistic responses when mixed with receiving stream water.

Not Applicable; at this time, the permittee is not required to conduct WET test for this facility.

303(d) LIST & TOTAL MAXIMUM DAILY LOAD (TMDL):

Section 303(d) of the federal Clean Water Act requires that each state identify waters that are not meeting water quality standards and for which adequate water pollution controls have not been required. Water quality standards protect such beneficial uses of water as whole body contact (such as swimming), maintaining fish and other aquatic life, and providing drinking water for people, livestock and wildlife. The 303(d) list helps state and federal agencies keep track of waters that are impaired but not addressed by normal water pollution control programs.

A TMDL is a calculation of the maximum amount of a given pollutant that a body of water can absorb before its water quality is affected. If a water body is determined to be impaired as listed on the 303(d) list, then a watershed management plan will be developed that shall include the TMDL calculation

Applicable; the Meramec River is listed on the 2008 Missouri 303(d) List for Lead. This facility is not a Lead contributor.

Part IV – Effluent Limits Determination

Outfall #001 – Main Facility Outfall

Effluent limitations derived and established in the below Effluent Limitations Table are based on current operations of the facility. Future permit action due to facility modification may contain new operating permit terms and conditions that supersede the terms and conditions, including effluent limitations, of this operating permit.

EFFLUENT LIMITATIONS TABLE:

Outfall #001 – Main Facility Outfall

EFFLUENT LIMITATIONS TABLE:

PARAMETER	UNIT	BASIS FOR LIMITS	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MODIFIED	PREVIOUS PERMIT LIMITATIONS
FLOW	MGD	1	*			NO	SAME
TRICHLOROETHYLENE (TCE)	µg/L	1/3/9	56		28	YES	SAME
TETRACHLOROETHYLENE (PCE)	µg/L	1/3/9	*		*	NO	SAME
MONITORING FREQUENCY	Please see Minimum Sampling and Reporting Frequency Requirements in the Derivation and Discussion Section below.						

* - Monitoring requirement only.

** - For DO the Daily Maximum is a Daily Minimum and the Monthly Average is a Monthly Average Minimum.

*** - # of colonies/100mL; the Monthly Average for *E. coli* is a geometric mean.

**** - Parameter not previously established in previous state operating permit.

Basis for Limitations Codes:

- | | |
|--|------------------------------------|
| 1. State or Federal Regulation/Law | 7. Antidegradation Policy |
| 2. Water Quality Standard (includes RPA) | 8. Water Quality Model |
| 3. Water Quality Based Effluent Limits | 9. Best Professional Judgment |
| 4. Lagoon Policy | 10. TMDL or Permit in lieu of TMDL |
| 5. Ammonia Policy | 11. WET Test Policy |
| 6. Dissolved Oxygen Policy | |

OUTFALL #001 – DERIVATION AND DISCUSSION OF LIMITS:

- Flow.** In accordance with [40 CFR Part 122.44(i)(1)(ii)] the volume of effluent discharged from each outfall is needed to assure compliance with permitted effluent limitations. If the permittee is unable to obtain effluent flow, then it is the responsibility of the permittee to inform the department, which may require the submittal of an operating permit modification.
- Trichloroethylene (TCE).** Protection of Drinking Water CCC = 5 µg/L, CMC = 5 µg/L, Background TCE = 0 µg/L

Chronic WLA: $C_e = ((.37 + 84)5 - (0.0 * 84))/.37$
 $C_e = 1140 \mu\text{g/L}$

Acute WLA: $C_e = ((.37 + 3.7)5 - (0.0 * 3.7))/.37$
 $C_e = 55 \mu\text{g/L}$

$LTA_c = 1140 (0.527) = 601 \mu\text{g/L}$
 $LTA_a = 55 (0.321) = 18 \mu\text{g/L}$

[CV = 0.6, 99th Percentile]
 [CV = 0.6, 99th Percentile]

Use most protective number of LTA_c or LTA_a .

$MDL = 18 (3.11) = 56 \mu\text{g/L}$
 $AML = 18 (1.55) = 28 \mu\text{g/L}$

[CV = 0.6, 99th Percentile]
 [CV = 0.6, 95th Percentile, n = 4]

- **Tetrachloroethene (PCE)**. Monitoring only.

The Wainwright Operable unit is being remediated under the supervision of the department's Hazardous Waste Program. As PCE is listed as a Contaminant of Concern, even though there is no reasonable potential the parameter will be retained for monitoring only. Best professional judgment.

- **Minimum Sampling and Reporting Frequency Requirements**.

PARAMETER	SAMPLING FREQUENCY	REPORTING FREQUENCY
FLOW	ONCE/WEEK	ONCE/MONTH
TRICHLOROETHYLENE (TCE)	ONCE/MONTH	ONCE/MONTH
TETRACHLOROETHYLENE (PCE)	ONCE/MONTH	ONCE/MONTH

Part V – Administrative Requirements

On the basis of preliminary staff review and the application of applicable standards and regulations, the Department, as administrative agent for the Missouri Clean Water Commission, proposes to issue a permit(s) subject to certain effluent limitations, schedules, and special conditions contained herein and within the operating permit. The proposed determinations are tentative pending public comment.

PERMIT SYNCHRONIZATION:

The Department of Natural Resources is currently undergoing a synchronization process for operating permits. Permits are normally issued on a five-year term, but to achieve synchronization many permits will need to be issued for less than the full five years allowed by regulation. The intent is that all permits within a watershed will move through the Watershed Based Management (WBM) cycle together will all expire in the same fiscal year. This will allow further streamlining by placing multiple permits within a smaller geographic area on public notice simultaneously, thereby reducing repeated administrative efforts. This will also allow the department to explore a watershed based permitting effort at some point in the future. Renewal applications must continue to be submitted within 180 days of expiration, however, in instances where effluent data from the previous renewal is less than three years old, that data may be re-submitted to meet the requirements of the renewal application. If the permit provides a schedule of compliance for meeting new water quality based effluent limits beyond the expiration date of the permit, the time remaining in the schedule of compliance will be allotted in the renewed permit.

PUBLIC NOTICE:

The Department shall give public notice that a draft permit has been prepared and its issuance is pending. Additionally, public notice will be issued if a public hearing is to be held because of a significant degree of interest in and water quality concerns related to a draft permit. No public notice is required when a request for a permit modification or termination is denied; however, the requester and permittee must be notified of the denial in writing.

The Department must issue public notice of a pending operating permit or of a new or reissued statewide general permit. The public comment period is the length of time not less than 30 days following the date of the public notice which interested persons may submit written comments about the proposed permit.

For persons wanting to submit comments regarding this proposed operating permit, then please refer to the Public Notice page located at the front of this draft operating permit. The Public Notice page gives direction on how and where to submit appropriate comments.

- The Public Notice period for this operating permit was from December 6, 2013 to January 6, 2014. No responses were received during the formal public notice period.

DATE OF FACT SHEET: OCTOBER 2, 2013

COMPLETED BY:

Thabit. H. Hamoud, P.E, EE III
Missouri Department of Natural Resources
Water Protection Section
7545 S. Lindbergh, Suite 210, St. Louis, Missouri 63125
(314) 416-2453
thabit.hamoud@dnr.mo.gov



STANDARD CONDITIONS FOR NPDES PERMITS
ISSUED BY
THE MISSOURI DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION
REVISED
NOVEMBER 1, 2013

These Standard Conditions incorporate permit conditions as required by 40 CFR 122.41 or other applicable state statutes or regulations. These minimum conditions apply unless superseded by requirements specified in the permit.

Part I – General Conditions

Section A – Sampling, Monitoring, and Recording

1. **Sampling Requirements.**
 - a. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
 - b. All samples shall be taken at the outfall(s) or Missouri Department of Natural Resources (Department) approved sampling location(s), and unless specified, before the effluent joins or is diluted by any other body of water or substance.
2. **Monitoring Requirements.**
 - a. Records of monitoring information shall include:
 - i. The date, exact place, and time of sampling or measurements;
 - ii. The individual(s) who performed the sampling or measurements;
 - iii. The date(s) analyses were performed;
 - iv. The individual(s) who performed the analyses;
 - v. The analytical techniques or methods used; and
 - vi. The results of such analyses.
 - b. If the permittee monitors any pollutant more frequently than required by the permit at the location specified in the permit using test procedures approved under 40 CFR Part 136, or another method required for an industry-specific waste stream under 40 CFR subchapters N or O, the results of such monitoring shall be included in the calculation and reported to the Department with the discharge monitoring report data (DMR) submitted to the Department pursuant to Section B, paragraph 7.
3. **Sample and Monitoring Calculations.** Calculations for all sample and monitoring results which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified in the permit.
4. **Test Procedures.** The analytical and sampling methods used shall conform to the reference methods listed in 10 CSR 20-7.015 unless alternates are approved by the Department. The facility shall use sufficiently sensitive analytical methods for detecting, identifying, and measuring the concentrations of pollutants. The facility shall ensure that the selected methods are able to quantify the presence of pollutants in a given discharge at concentrations that are low enough to determine compliance with Water Quality Standards in 10 CSR 20-7.031 or effluent limitations unless provisions in the permit allow for other alternatives. A method is “sufficiently sensitive” when; 1) the method minimum level is at or below the level of the applicable water quality criterion for the pollutant or, 2) the method minimum level is above the applicable water quality criterion, but the amount of pollutant in a facility’s discharge is high enough that the method detects and quantifies the level of pollutant in the discharge, or 3) the method has the lowest minimum level of the analytical methods approved under 10 CSR 20-7.015. These methods are also required for parameters that are listed as monitoring only, as the data collected may be used to determine if limitations need to be established. A permittee is responsible for working with their contractors to ensure that the analysis performed is sufficiently sensitive.
5. **Record Retention.** Except for records of monitoring information required by the permit related to the permittee’s sewage sludge use and disposal activities, which shall be retained for a period of at least five (5) years (or longer as required by 40 CFR part 503), the permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by the permit, and records of all data used to complete the application for the permit, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Department at any time.

6. **Illegal Activities.**
 - a. The Federal Clean Water Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under the permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than two (2) years, or both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than four (4) years, or both.
 - b. The Missouri Clean Water Law provides that any person or who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained pursuant to sections 644.006 to 644.141 shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than six (6) months, or by both. Second and successive convictions for violation under this paragraph by any person shall be punished by a fine of not more than \$50,000 per day of violation, or by imprisonment for not more than two (2) years, or both.

Section B – Reporting Requirements

1. **Planned Changes.**
 - a. The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility when:
 - i. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR 122.29(b); or
 - ii. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in the permit, nor to notification requirements under 40 CFR 122.42(a)(1);
 - iii. The alteration or addition results in a significant change in the permittee’s sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan;
 - iv. Any facility expansions, production increases, or process modifications which will result in a new or substantially different discharge or sludge characteristics must be reported to the Department 60 days before the facility or process modification begins. Notification may be accomplished by application for a new permit. If the discharge does not violate effluent limitations specified in the permit, the facility is to submit a notice to the Department of the changed discharge at least 30 days before such changes. The Department may require a construction permit and/or permit modification as a result of the proposed changes at the facility.
2. **Twenty-Four Hour Reporting.**
 - a. The permittee shall report any noncompliance which may endanger health or the environment. Relevant information shall be provided orally or via the current electronic method approved by the Department, within 24 hours from the time the permittee becomes aware of the circumstances, and shall be reported to the appropriate Regional Office during normal business hours or the Environmental Emergency Response hotline at 573-634-2436 outside of normal business hours. A written submission shall also be provided within five (5) business days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.



STANDARD CONDITIONS FOR NPDES PERMITS
ISSUED BY
THE MISSOURI DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION
REVISED
NOVEMBER 1, 2013

- b. The following shall be included as information which must be reported within 24 hours under this paragraph.
 - i. Any unanticipated bypass which exceeds any effluent limitation in the permit.
 - ii. Any upset which exceeds any effluent limitation in the permit.
 - iii. Violation of a maximum daily discharge limitation for any of the pollutants listed by the Department in the permit required to be reported within 24 hours.
 - c. The Department may waive the written report on a case-by-case basis for reports under paragraph 2. b. of this section if the oral report has been received within 24 hours.
3. **Sanitary Sewer Overflow Reporting.** The following requirements solely reflect reporting obligations, and reporting does not necessarily reflect noncompliance, which may depend on the circumstances of the incident reported.
- a. **Twenty-Four Hour (24-Hour) Reporting.** The permittee or owner shall report any incident in which wastewater escapes the collection system such that it reaches waters of the state or it may pose an imminent or substantial endangerment to the health or welfare of persons. Relevant information shall be provided orally or via the current electronic method approved by the Department within 24 hours from the time the permittee becomes aware of the incident. A written submission shall also be provided within five (5) business days of the time the permittee or owner becomes aware of the incident. The Department may waive the written report on a case-by-case basis if the oral report has been received within 24 hours. The five (5) day reports may be provided via the current electronic method approved by the Department.
 - b. **Incidents Reported via Discharge Monitoring Reports (DMRs).** The permittee or owner shall report any event in which wastewater escapes the collection system, which does not enter waters of the state and is not expected to pose an imminent or substantial endangerment to the health or welfare of persons, which occur typically during wet weather events. Relevant information shall be provided with the permittee's or owner's DMRs.
4. **Anticipated Noncompliance.** The permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements. The notice shall be submitted to the Department 60 days prior to such changes or activity.
5. **Compliance Schedules.** Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of the permit shall be submitted no later than 14 days following each schedule date. The report shall provide an explanation for the instance of noncompliance and a proposed schedule or anticipated date, for achieving compliance with the compliance schedule requirement.
6. **Other Noncompliance.** The permittee shall report all instances of noncompliance not reported under paragraphs 2, 3, 4, and 7 of this section, at the time monitoring reports are submitted. The reports shall contain the information listed in paragraph 2. a. of this section.
7. **Other Information.** Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or information.
8. **Discharge Monitoring Reports.**
- a. Monitoring results shall be reported at the intervals specified in the permit.
 - b. Monitoring results must be reported to the Department via the current method approved by the Department, unless the permittee has been granted a waiver from using the method. If the permittee has been granted a waiver, the permittee must use forms provided by the Department.
 - c. Monitoring results shall be reported to the Department no later than the 28th day of the month following the end of the reporting period.

Section C – Bypass/Upset Requirements

1. **Definitions.**
 - a. *Bypass*: the intentional diversion of waste streams from any portion of a treatment facility.
 - b. *Severe Property Damage*: substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
 - c. *Upset*: an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
2. **Bypass Requirements.**
 - a. Bypass not exceeding limitations. The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs 2. b. and 2. c. of this section.
 - b. Notice.
 - i. Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least 10 days before the date of the bypass.
 - ii. Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in Section B – Reporting Requirements, paragraph 5 (24-hour notice).
 - c. Prohibition of bypass.
 - i. Bypass is prohibited, and the Department may take enforcement action against a permittee for bypass, unless:
 1. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 2. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 3. The permittee submitted notices as required under paragraph 2. b. of this section.
 - ii. The Department may approve an anticipated bypass, after considering its adverse effects, if the Department determines that it will meet the three (3) conditions listed above in paragraph 2. c. i. of this section.
3. **Upset Requirements.**
 - a. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of paragraph 3. b. of this section are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
 - b. Conditions necessary for a demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - i. An upset occurred and that the permittee can identify the cause(s) of the upset;
 - ii. The permitted facility was at the time being properly operated; and
 - iii. The permittee submitted notice of the upset as required in Section B – Reporting Requirements, paragraph 2. b. ii. (24-hour notice).
 - iv. The permittee complied with any remedial measures required under Section D – Administrative Requirements, paragraph 4.
 - c. Burden of proof. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.



STANDARD CONDITIONS FOR NPDES PERMITS
ISSUED BY
THE MISSOURI DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION
REVISED
NOVEMBER 1, 2013

Section D – Administrative Requirements


1. **Duty to Comply.** The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Missouri Clean Water Law and Federal Clean Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application.
 - a. The permittee shall comply with effluent standards or prohibitions established under section 307(a) of the Federal Clean Water Act for toxic pollutants and with standards for sewage sludge use or disposal established under section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions or standards for sewage sludge use or disposal, even if the permit has not yet been modified to incorporate the requirement.
 - b. The Federal Clean Water Act provides that any person who violates section 301, 302, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any such sections in a permit issued under section 402, or any requirement imposed in a pretreatment program approved under sections 402(a)(3) or 402(b)(8) of the Act, is subject to a civil penalty not to exceed \$25,000 per day for each violation. The Federal Clean Water Act provides that any person who negligently violates sections 301, 302, 306, 307, 308, 318, or 405 of the Act, or any condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, or any requirement imposed in a pretreatment program approved under section 402(a)(3) or 402(b)(8) of the Act, is subject to criminal penalties of \$2,500 to \$25,000 per day of violation, or imprisonment of not more than one (1) year, or both. In the case of a second or subsequent conviction for a negligent violation, a person shall be subject to criminal penalties of not more than \$50,000 per day of violation, or by imprisonment of not more than two (2) years, or both. Any person who knowingly violates such sections, or such conditions or limitations is subject to criminal penalties of \$5,000 to \$50,000 per day of violation, or imprisonment for not more than three (3) years, or both. In the case of a second or subsequent conviction for a knowing violation, a person shall be subject to criminal penalties of not more than \$100,000 per day of violation, or imprisonment of not more than six (6) years, or both. Any person who knowingly violates section 301, 302, 303, 306, 307, 308, 318 or 405 of the Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of the Act, and who knows at that time that he thereby places another person in imminent danger of death or serious bodily injury, shall, upon conviction, be subject to a fine of not more than \$250,000 or imprisonment of not more than 15 years, or both. In the case of a second or subsequent conviction for a knowing endangerment violation, a person shall be subject to a fine of not more than \$500,000 or by imprisonment of not more than 30 years, or both. An organization, as defined in section 309(c)(3)(B)(iii) of the CWA, shall, upon conviction of violating the imminent danger provision, be subject to a fine of not more than \$1,000,000 and can be fined up to \$2,000,000 for second or subsequent convictions.
 - c. Any person may be assessed an administrative penalty by the EPA Director for violating section 301, 302, 306, 307, 308, 318 or 405 of this Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of this Act. Administrative penalties for Class I violations are not to exceed \$10,000 per violation, with the maximum amount of any Class I penalty assessed not to exceed \$25,000. Penalties for Class II violations are not to exceed \$10,000 per day for each day during which the violation continues, with the maximum amount of any Class II penalty not to exceed \$125,000.
 - d. It is unlawful for any person to cause or permit any discharge of water contaminants from any water contaminant or point source located in Missouri in violation of sections 644.006 to 644.141 of the Missouri Clean Water Law, or any standard, rule or regulation promulgated by the commission. In the event the commission or the director determines that any provision of sections 644.006 to 644.141 of the Missouri Clean Water Law or standard, rules, limitations or regulations promulgated pursuant thereto, or permits issued by, or any final abatement order, other order, or determination made by the commission or the director, or any filing requirement pursuant to sections 644.006 to 644.141 of the Missouri Clean Water Law or any other provision which this state is required to enforce pursuant to any federal water pollution control act, is being, was, or is in imminent danger of being violated, the commission or director may cause to have instituted a civil action in any court of competent jurisdiction for the injunctive relief to prevent any such violation or further violation or for the assessment of a penalty not to exceed \$10,000 per day for each day, or part thereof, the violation occurred and continues to occur, or both, as the court deems proper. Any person who willfully or negligently commits any violation in this paragraph shall, upon conviction, be punished by a fine of not less than \$2,500 nor more than \$25,000 per day of violation, or by imprisonment for not more than one year, or both. Second and successive convictions for violation of the same provision of this paragraph by any person shall be punished by a fine of not more than \$50,000 per day of violation, or by imprisonment for not more than two (2) years, or both.
2. **Duty to Reapply.**
 - a. If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit.
 - b. A permittee with a currently effective site-specific permit shall submit an application for renewal at least 180 days before the expiration date of the existing permit, unless permission for a later date has been granted by the Department. (The Department shall not grant permission for applications to be submitted later than the expiration date of the existing permit.)
 - c. A permittees with currently effective general permit shall submit an application for renewal at least 30 days before the existing permit expires, unless the permittee has been notified by the Department that an earlier application must be made. The Department may grant permission for a later submission date. (The Department shall not grant permission for applications to be submitted later than the expiration date of the existing permit.)
3. **Need to Halt or Reduce Activity Not a Defense.** It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.
4. **Duty to Mitigate.** The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.
5. **Proper Operation and Maintenance.** The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit.
6. **Permit Actions.**
 - a. Subject to compliance with statutory requirements of the Law and Regulations and applicable Court Order, this permit may be modified, suspended, or revoked in whole or in part during its term for cause including, but not limited to, the following:
 - i. Violations of any terms or conditions of this permit or the law;
 - ii. Having obtained this permit by misrepresentation or failure to disclose fully any relevant facts;
 - iii. A change in any circumstances or conditions that requires either a temporary or permanent reduction or elimination of the authorized discharge; or
 - iv. Any reason set forth in the Law or Regulations.
 - b. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.



STANDARD CONDITIONS FOR NPDES PERMITS
ISSUED BY
THE MISSOURI DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION
REVISED
NOVEMBER 1, 2013

7. **Permit Transfer.**
- Subject to 10 CSR 20-6.010, an operating permit may be transferred upon submission to the Department of an application to transfer signed by the existing owner and the new owner, unless prohibited by the terms of the permit. Until such time the permit is officially transferred, the original permittee remains responsible for complying with the terms and conditions of the existing permit.
 - The Department may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under the Missouri Clean Water Law or the Federal Clean Water Act.
 - The Department, within 30 days of receipt of the application, shall notify the new permittee of its intent to revoke or reissue or transfer the permit.
8. **Toxic Pollutants.** The permittee shall comply with effluent standards or prohibitions established under section 307(a) of the Federal Clean Water Act for toxic pollutants and with standards for sewage sludge use or disposal established under section 405(d) of the Federal Clean Water Act within the time provided in the regulations that establish these standards or prohibitions or standards for sewage sludge use or disposal, even if the permit has not yet been modified to incorporate the requirement.
9. **Property Rights.** This permit does not convey any property rights of any sort, or any exclusive privilege.
10. **Duty to Provide Information.** The permittee shall furnish to the Department, within a reasonable time, any information which the Department may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. The permittee shall also furnish to the Department upon request, copies of records required to be kept by this permit.
11. **Inspection and Entry.** The permittee shall allow the Department, or an authorized representative (including an authorized contractor acting as a representative of the Department), upon presentation of credentials and other documents as may be required by law, to:
- Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of the permit;
 - Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
 - Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
 - Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Federal Clean Water Act or Missouri Clean Water Law, any substances or parameters at any location.
12. **Closure of Treatment Facilities.**
- Persons who cease operation or plan to cease operation of waste, wastewater, and sludge handling and treatment facilities shall close the facilities in accordance with a closure plan approved by the Department.
 - Operating Permits under 10 CSR 20-6.010 or under 10 CSR 20-6.015 are required until all waste, wastewater, and sludges have been disposed of in accordance with the closure plan approved by the Department and any disturbed areas have been properly stabilized. Disturbed areas will be considered stabilized when perennial vegetation, pavement, or structures using permanent materials cover all areas that have been disturbed. Vegetative cover, if used, shall be at least 70% plant density over 100% of the disturbed area.
13. **Signatory Requirement.**
- All permit applications, reports required by the permit, or information requested by the Department shall be signed and certified. (See 40 CFR 122.22 and 10 CSR 20-6.010)
 - The Federal Clean Water Act provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or non-compliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than six (6) months per violation, or by both.
14. **Severability.** The provisions of the permit are severable, and if any provision of the permit, or the application of any provision of the permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of the permit, shall not be affected thereby.

C 11295
AP 15109



MISSOURI DEPARTMENT OF NATURAL RESOURCES
WATER PROTECTION PROGRAM, WATER POLLUTION CONTROL BRANCH
**FORM A - APPLICATION FOR CONSTRUCTION OR OPERATING PERMIT
UNDER MISSOURI CLEAN WATER LAW**

FOR AGENCY USE ONLY	
CHECK NUMBER	
DATE RECEIVED 4/11/13	FEE SUBMITTED OCB

Note ▶ PLEASE READ THE ACCOMPANYING INSTRUCTIONS BEFORE COMPLETING THIS FORM.

1. This application is for:
- An operating permit and antidegradation review public notice
 - A construction permit following an appropriate operating permit and antidegradation review public notice
 - A construction permit and concurrent operating permit and antidegradation review public notice
 - A construction permit (submitted before Aug. 30, 2008 or antidegradation review is not required)
 - An operating permit for a new or unpermitted facility Construction Permit # _____
 - An operating permit renewal: permit # MO- MO-0123021 Expiration Date October 23, 2013
 - An operating permit modification: permit # MO- _____ Reason: _____

1.1 Is the appropriate fee included with the application? (See instructions for appropriate fee) YES NO

2. FACILITY

NAME Valley Park TCE Site - Wainwright Operable Unit		TELEPHONE WITH AREA CODE (636) 278-5850	
		FAX (636) 278-8806	
ADDRESS (PHYSICAL) 224 Benton Avenue,	CITY Valley Park	STATE MO	ZIP CODE 63088

3. OWNER

NAME Wainwright industries, Inc.		E-MAIL ADDRESS gwilson@wainent.co	TELEPHONE WITH AREA CODE (636) 278-5850
			FAX (636) 278-8806
ADDRESS (MAILING) 17 Cermak Blvd.	CITY St. Peters	STATE MO	ZIP CODE 63376

3.1 Request review of draft permit prior to public notice? YES NO

4. CONTINUING AUTHORITY

NAME Wainwright Industries, Inc.		TELEPHONE WITH AREA CODE (636) 278-8806	
		FAX (636) 278-8806	
ADDRESS (MAILING) 17 Cermak Blvd.	CITY St. Peters	STATE MO	ZIP CODE 63376

5. OPERATOR

NAME Gregg Wilson		CERTIFICATE NUMBER Not Applicable	TELEPHONE WITH AREA CODE (636) 387-5410
			FAX (636) 278-8806
ADDRESS (MAILING) 17 Cermak Blvd.	CITY St. Peters	STATE MO	ZIP CODE 63376

6. FACILITY CONTACT

NAME Gregg Wilson		TITLE Engineering Manager	TELEPHONE WITH AREA CODE (636) 387-5410
			FAX (636) 278-8806

7. ADDITIONAL FACILITY INFORMATION

7.1 Legal Description of Outfalls. (Attach additional sheets if necessary.)

001 NW ¼ SW ¼ Sec 17 T 44N R 5E St. Lo County
 UTM Coordinates Easting (X): +3833054 Northing (Y): -09029114
For Universal Transverse Mercator (UTM), Zone 15 North referenced to North American Datum 1983 (NAD83)

002 ¼ T R County
 UTM Coordinates Easting (X): _____ Northing (Y): _____

003 ¼ T R County
 UTM Coordinates Easting (X): _____ Northing (Y): _____

004 ¼ T R County
 UTM Coordinates Easting (X): _____ Northing (Y): _____

7.2 Primary Standard Industrial Classification (SIC) and Facility North American Industrial Classification System (NAICS) Codes.

001 - SIC 3499 and NAICS _____ 002 - SIC _____ and NAICS _____
 003 - SIC _____ and NAICS _____ 004 - SIC _____ and NAICS _____

RECEIVED

APR 11 2013

8. ADDITIONAL FORMS AND MAPS NECESSARY TO COMPLETE THIS APPLICATION
(Complete all forms that are applicable.)


- A. Is your facility a manufacturing, commercial, mining or silviculture waste treatment facility? YES NO
 If yes, complete Form C (unless storm water only, then complete U.S. Environmental Protection Agency Form 2F per Item C below).
- B. Is your facility considered a "Primary Industry" under EPA guidelines: YES NO
 If yes, complete Forms C and D.
- C. Is application for storm water discharges only? YES NO
 If yes, complete EPA Form 2F.
- D. Attach a map showing all outfalls and the receiving stream at 1" = 2,000' scale.
- E. Is wastewater land applied? If yes, complete Form I. YES NO
- F. Is sludge, biosolids, ash or residuals generated, treated, stored or land applied? YES NO
 If yes, complete Form R.

9. DOWNSTREAM LANDOWNER(S) Attach additional sheets as necessary. See Instructions.
(PLEASE SHOW LOCATION ON MAP. SEE 8.D ABOVE).

NAME
 NOT APPLICABLE.

ADDRESS	CITY	STATE	ZIP CODE

10. I certify that I am familiar with the information contained in the application, that to the best of my knowledge and belief such information is true, complete and accurate, and if granted this permit, I agree to abide by the Missouri Clean Water Law and all rules, regulations, orders and decisions, subject to any legitimate appeal available to applicant under the Missouri Clean Water Law to the Missouri Clean Water Commission.

NAME AND OFFICIAL TITLE (TYPE OR PRINT) Gregg Wilson Engineering Manager	TELEPHONE WITH AREA CODE (636) 387-5410
SIGNATURE 	DATE SIGNED 3/28/2013

MO 780-1479 (01-09)

BEFORE MAILING, PLEASE ENSURE ALL SECTIONS ARE COMPLETED AND ADDITIONAL FORMS, IF APPLICABLE, ARE INCLUDED.
 Submittal of an incomplete application may result in the application being returned.

HAVE YOU INCLUDED:

- Appropriate Fees?
- Map at 1" = 2000' scale?
- Signature?
- Form C, if applicable?
- Form D, if applicable?
- Form 2F, if applicable?
- Form I (Irrigation), if applicable?
- Form R (Sludge), if applicable?


Wainwright Operable Unit 224 Benton Avenue, Valley Park, MO.

1" = 2000' scale map.


WOU. 224 Benton Street.

Outfall 001. Treated water discharge to Storm Sewer. Beckett Memorial Drive.

Downstream discharge Property Owners: N/A



Receiving Stream. Meramec River, at Valley Park, MO



MISSOURI DEPARTMENT OF NATURAL RESOURCES
 WATER PROTECTION PROGRAM, WATER POLLUTION BRANCH
FORM C – APPLICATION FOR DISCHARGE PERMIT –
MANUFACTURING, COMMERCIAL, MINING,
SILVICULTURE OPERATIONS, PROCESS & STORM WATER

FOR AGENCY USE ONLY	
CHECK NO.	
DATE RECEIVED	FEE SUBMITTED

TE: DO NOT ATTEMPT TO COMPLETE THIS FORM BEFORE READING THE ACCOMPANYING INSTRUCTIONS

1.00 NAME OF FACILITY
 Valley park TCE Site - Wainwright Operable Unit

1.10 THIS FACILITY IS NOW IN OPERATION UNDER MISSOURI OPERATING PERMIT NUMBER
 MO-0123021 Effective date: October 24, 2008

1.20 THIS IS A NEW FACILITY AND WAS CONSTRUCTED UNDER MISSOURI CONSTRUCTION PERMIT NUMBER (COMPLETE ONLY IF THIS FACILITY DOES NOT HAVE AN OPERATING PERMIT).

2.00 LIST THE STANDARD INDUSTRIAL CLASSIFICATION (SIC) CODES APPLICABLE TO YOUR FACILITY (FOUR DIGIT CODE)

A. FIRST 3499 B. SECOND _____

C. T State Copy D. FOURTH _____

Form C

2.10 FOR EACH O
 OUT 1/4 SEC 17 T 44N R 5E ST. LOUIS COUNTY

2.20 FOR EACH OUTFALL LIST THE NAME OF THE RECEIVING WATER

OUTFALL NUMBER (LIST)	RECEIVING WATER
OO1 Ground water remediation treatment unit.	Meramec River (P) (#02183)

2.30 BRIEFLY DESCRIBE THE NATURE OF YOUR BUSINESS

The property at 224 Benton Street, Valley Park, MO. is currently unoccupied and listed for sale. The last business operated as Rays Tree Service. On site remedial clean-up is the responsibility of Wainwright. An on site groundwater extraction well is pumping water through a STAT-400 Low Profile Air Stripper for treatment and removal of VOC compounds. Treated water is discharged through a pipe to a storm water drain for discharge into the Meramec River.

RECEIVED

APR 11 2013

2.40 CONTINUED

C. EXCEPT FOR STORM RUNOFF, LEAKS OR SPILLS, ARE ANY OF THE DISCHARGES DESCRIBED IN ITEMS A OR B INTERMITTENT OR SEASONAL?

YES (COMPLETE THE FOLLOWING TABLE) NO (GO TO SECTION 2.50)

1. OUTFALL NUMBER <i>(list)</i>	2. OPERATION(S) CONTRIBUTING FLOW <i>(list)</i>	3. FREQUENCY		4. FLOW				C. DURATION <i>(in days)</i>
				A. FLOW RATE <i>(in mgd)</i>		B. TOTAL VOLUME <i>(specify with units)</i>		
		A. DAYS PER WEEK <i>(specify average)</i>	B. MONTHS PER YEAR <i>(specify average)</i>	1. LONG TERM AVERAGE	2. MAXIMUM DAILY	4. LONG TERM DAILY	3. MAXIMUM AVERAGE	

2.50 MAXIMUM PRODUCTION

A. DOES AN EFFLUENT GUIDELINE LIMITATION PROMULGATED BY EPA UNDER SECTION 304 OF THE CLEAN WATER ACT APPLY TO YOUR FACILITY?

YES (COMPLETE B.) NO (GO TO SECTION 2.60)

B. ARE THE LIMITATIONS IN THE APPLICABLE EFFLUENT GUIDELINES EXPRESSED IN TERMS OF PRODUCTION (OF OTHER MEASURE OF OPERATION)?

YES (COMPLETE c.) NO (GO TO SECTION 2.60)

C. IF YOU ANSWERED "YES" TO B. LIST THE QUANTITY THAT REPRESENTS AN ACTUAL MEASUREMENT OF YOUR MAXIMUM LEVEL OF PRODUCTION, EXPRESSED IN THE TERMS AND UNITS USED IN THE APPLICABLE EFFLUENT GUIDELINE AND INDICATE THE AFFECTED OUTFALLS.

1. MAXIMUM QUANTITY			2. AFFECTED OUTFALLS <i>(list outfall numbers)</i>
A. QUANTITY PER DAY	B. UNITS OF MEASURE	C. OPERATION, PRODUCT, MATERIAL, ETC. <i>(specify)</i>	

2.60 IMPROVEMENTS

A. ARE YOU NOW REQUIRED BY ANY FEDERAL, STATE OR LOCAL AUTHORITY TO MEET ANY IMPLEMENTATION SCHEDULE FOR THE CONSTRUCTION, UPGRADING OR OPERATION OF WASTEWATER TREATMENT EQUIPMENT OR PRACTICES OR ANY OTHER ENVIRONMENTAL PROGRAMS THAT MAY AFFECT THE DISCHARGES DESCRIBED IN THIS APPLICATION? THIS INCLUDES, BUT IS NOT LIMITED TO, PERMIT CONDITIONS, ADMINISTRATIVE OR ENFORCEMENT ORDERS, ENFORCEMENT COMPLIANCE SCHEDULE LETTERS, STIPULATIONS, COURT ORDERS AND GRANT OR LOAN CONDITIONS.

YES (COMPLETE THE FOLLOWING TABLE) NO (GO TO 3.00)

1. IDENTIFICATION OF CONDITION AGREEMENT, ETC.	2. AFFECTED OUTFALLS		3. BRIEF DESCRIPTION OF PROJECT	4. FINAL COMPLIANCE DATE	
				A. REQUIRED	B. PROJECTED

B. OPTIONAL: YOU MAY ATTACH ADDITIONAL SHEETS DESCRIBING ANY ADDITIONAL WATER POLLUTION CONTROL PROGRAMS (OR OTHER ENVIRONMENTAL PROJECTS THAT MAY AFFECT YOUR DISCHARGES) YOU NOW HAVE UNDER WAY OR ARE YOU PLANNING. INDICATE WHETHER EACH PROGRAM IS NOW UNDER WAY OR PLANNED, AND INDICATE YOUR ACTUAL OR PLANNED SCHEDULES FOR CONSTRUCTION.

MARK "X" IF DESCRIPTION OF ADDITIONAL CONTROL PROGRAMS IS ATTACHED.

3.10 BIOLOGICAL TOXICITY TESTING DATA

DO YOU HAVE ANY KNOWLEDGE OR REASON TO BELIEVE THAT ANY BIOLOGICAL TEST FOR ACUTE OR CHRONIC TOXICITY HAS BEEN MADE ON ANY OF YOUR DISCHARGES OR ON RECEIVING WATER IN RELATION TO YOUR DISCHARGE WITHIN THE LAST THREE YEARS?

YES (IDENTIFY THE TEST(S) AND DESCRIBE THEIR PURPOSES BELOW.) NO (GO TO 3.20)

3.20 CONTRACT ANALYSIS INFORMATION

WERE ANY OF THE ANALYSES REPORTED PERFORMED BY A CONTRACT LABORATORY OR CONSULTING FIRM?

YES (LIST THE NAME, ADDRESS AND TELEPHONE NUMBER OF AND POLLUTANTS ANALYZED BY EACH SUCH LABORATORY OR FIRM BELOW.) NO (GO TO 3.30)

A. NAME	B. ADDRESS	C. TELEPHONE (area code and number)	D. POLLUTANTS ANALYZED (list)
PDC laboratories, Inc.	3278 N Highway 67 Florissant, MO 63033	314-432-0550	Trichloroethylene (TCE) Tetrachloroethylene (PCE)

3.30 CERTIFICATION

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this application and all attachments and that, based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the information is true, accurate and complete. I am aware there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

NAME AND OFFICIAL TITLE (TYPE OR PRINT) Gregg Wilson	TELEPHONE NUMBER WITH AREA CODE (636) 238-7541
SIGNATURE (SEE INSTRUCTIONS) 	DATE SIGNED 3/28/2013

PLEASE PRINT OR TYPE. You may report some or all of this information on separate sheet instead of completing these pages.
 (Use the same format)
 SEE INSTRUCTIONS

FORM C
 TABLE 1 FOR 3.00 ITEM A AND B

OUTFALL NO.
 001

INTAKE AND EFFLUENT CHARACTERISTICS

PART A – You must provide the results of at least one analysis for every pollutant in this table. Complete one table for each outfall. See instructions for additional details.

1. POLLUTANT	2. EFFLUENT						D. NO. OF ANALYSES	3. UNITS (specify if blank)		4. INTAKE (optional)		
	A. MAXIMUM DAILY VALUE		B. MAXIMUM 30 DAY VALUE (if available)		C. LONG TERM AVRG. VALUE (if available)			A. CONCENTRATION	B. MASS	A. LONG TERM AVRG. VALUE		B. NO. OF ANALYSES
	(1) CONCENTRATION	(2) MASS	(1) CONCENTRATION	(2) MASS	(1) CONCENTRATION	(2) MASS				(1) CONCENTRATION	(2) MASS	
A. Biochemical Oxygen Demand (BOD)												
B. Chemical Oxygen Demand (COD)												
C. Total organic Carbon (TOC)												
D. Total Suspended Solids (TSS)												
E. Ammonia (as N)												
F. Flow	VALUE		VALUE		VALUE					VALUE		
G. Temperature (winter)	VALUE		VALUE		VALUE			°C		VALUE		
H. Temperature (summer)	VALUE		VALUE		VALUE			°C		VALUE		
I. pH	MINIMUM	MAXIMUM	MINIMUM	MAXIMUM				STANDARD UNITS				

PART B – Mark "X" in column 2-a for each pollutant you know or have reason to believe is present. Mark "X" in column 2-b for each pollutant you believe to be absent. If you mark column 2-a for any pollutant, you must provide the results for at least one analysis for that pollutant. Complete one table for each outfall. See the instructions for additional details and requirements.


1. POLLUTANT AND CAS NUMBER (if available)	2. MARK "X"		3. EFFLUENT						D. NO. OF ANALYSES	4. UNITS		5. INTAKE (optional)		
	A. BELIEVED PRESENT	B. BELIEVED ABSENT	A. MAXIMUM DAILY VALUE		B. MAXIMUM 30 DAY VALUE (if available)		C. LONG TERM AVRG. VALUE (if available)			A. CONCENTRATION	B. MASS	A. LONG TERM AVRG. VALUE		B. NO. OF ANALYSES
			(1) CONCENTRATION	(2) MASS	(1) CONCENTRATION	(2) MASS	(1) CONCENTRATION	(2) MASS				(1) CONCENTRATION	(2) MASS	
A. Bromide (24959-67-9)		X												
B. Chlorine Total Residual		X												
C. Color		X												
D. Fecal Coliform		X												
E. Fluoride (16984-48-8)		X												
F. Nitrate—Nitrate (as N)		X												

1. POLLUTANT AND CAS NUMBER <i>(if available)</i>	2. MARK "X"		3. EFFLUENT						4. UNITS		5. INTAKE <i>(optional)</i>			
	A. BELIEVED PRESENT	B. BELIEVED ABSENT	A. MAXIMUM DAILY VALUE		B. MAXIMUM 30 DAY VALUE <i>(if available)</i>		C. LONG TERM AVRG. VALUE <i>(if available)</i>		D. NO. OF ANALYSES	A. CONCENTRATION	B. MASS	A. LONG TERM AVRG. VALUE		B. NO. OF ANALYSES
			(1) CONCENTRATION	(2) MASS	(1) CONCENTRATION	(2) MASS	(1) CONCENTRATION	(2) MASS				(1) CONCENTRATION	(2) MASS	
G. Nitrogen Total Organic <i>(as N)</i>		X												
H. Oil and Grease		X												
I. Phosphorus <i>(as P)</i> Total (7723-14-0)		X												
J. Sulfate <i>(as SO₄²⁻)</i> (14808-79-8)		X												
K. Sulfide <i>(as S)</i>		X												
L. Sulfite <i>(as SO₃²⁻)</i> (14265-45-3)		X												
M. Surfactants		X												
N. Aluminum Total (7429-90-5)		X												
O. Barium Total (7440-39-3)		X												
P. Boron Total (7440-42-8)		X												
Q. Cobalt Total (7440-48-4)		X												
R. Iron Total (7439-89-6)		X												
S. Magnesium Total (7439-95-4)		X												
T. Molybdenum Total (7439-98-7)		X												
U. Manganese Total (7439-96-5)		X												
V. Tin Total (7440-31-5)		X												
W. Titanium Total (7440-32-6)		X												


1. POLLUTANT AND CAS NUMBER <i>(if available)</i>	2. MARK "X"		3. EFFLUENT						4. UNITS		5. INTAKE <i>(optional)</i>			
	A. BELIEVED PRESENT	B. BELIEVED ABSENT	A. MAXIMUM DAILY VALUE		B. MAXIMUM 30 DAY VALUE <i>(if available)</i>		C. LONG TERM AVRG. VALUE <i>(if available)</i>		D. NO. OF ANALYSES	A. CONCENTRATION	B. MASS	A. LONG TERM AVRG. VALUE		B. NO. OF ANALYSES
			(1) CONCENTRATION	(2) MASS	(1) CONCENTRATION	(2) MASS	(1) CONCENTRATION	(2) MASS				(1) CONCENTRATION	(2) MASS	
METALS, AND TOTAL PHENOLS														
1M. Antimony, Total (7440-36-9)		X												
2M. Beryllium, Total (7440-41-7)		X												
3M. Magnesium, Total (7439-95-4)		X												
4M. Molybdenum, Total (7439-98-7)		X												
5M. Tin, Total (7440-31-5)		X												
6M. Titanium, Total (7440-32-6)		X												
7M. Mercury, Total (7439-97-6)		X												
8M. Selenium, Total (7782-49-2)		X												
9M. Thallium, Total (7440-28-0)		X												
10M. Phenols, Total		X												
RADIOACTIVITY														
(1) Alpha Total		X												
(2) Beta Total		X												
(3) Radium Total		X												
(4) Radium 226 Total		X												

Line Drawing Wainwright Operable Unit. 224 Benton Avenue, Valley Park MO.

Permit Form C. (2.4)



WOU 224 Benton Ave, Valley Park, MO
Historical Data





PDC Laboratories, Inc.

3278 N. Highway 67 - Florissant, MO 63033
(314) 432-0550 - (800) 333-FAST (3278) - FAX (314) 432-4977



Wainwright Industries
17 Cermak Blvd
St Peters, MO 63376
Attn: Gregg Wilson

WOU
224 Benton St.
Valley Park, MO

Date Received: 10/08/12 12:36
Report Date: 10/18/12
Customer #: 276581
PO#: G.Wilson

Laboratory Results

Sample No: 2101257-01

Collect Date: 10/05/12 12:43

Matrix: Ground Water

Sample Description: EF-1 (Outfall #004, Treated Discharge water)

Parameters	Result	Qual	Prep Date	Analysis Date	Analyst	Method
<u>Volatile Organics - STL</u>						
1,1,1,2-Tetrachloroethane	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
1,1,1-Trichloroethane	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
1,1,2,2-Tetrachloroethane	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
1,1,2-Trichloro-1,2,2-trifluoroethane (Freon)	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
1,1,2-Trichloroethane	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
1,1-Dichloroethane	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
1,1-Dichloroethene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
1,1-Dichloropropene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
1,2,3-Trichlorobenzene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
1,2,3-Trichloropropane	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
1,2,4-Trichlorobenzene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
1,2,4-Trimethylbenzene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
1,2-Dibromo-3-chloropropane	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
1,2-Dibromoethane	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
1,2-Dichlorobenzene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
1,2-Dichloroethane	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Surrogate: 1,2-Dichloroethane-d4	112 % 59.1-125			10/15/12 14:53	BP	SW 8260B
1,2-Dichloroethene- Total	< 10 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
1,2-Dichloropropane	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
1,3,5-Trimethylbenzene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
1,3-Dichlorobenzene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
1,3-Dichloropropane	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
1,3-Dichloropropene - Total	< 10 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
1,4-Dichlorobenzene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
1,4-Dioxane	< 25 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
2,2-Dichloropropane	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
2-Butanone	< 10 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
2-Chloroethylvinyl ether	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
2-Chlorotoluene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
2-Hexanone	< 10 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B



PDC Laboratories, Inc.

3278 N. Highway 67 - Florissant, MO 63033
(314) 432-0550 - (800) 333-EAST (3278) - FAX (314) 432-4977



Wainwright Industries
17 Cermak Blvd
St Peters, MO 63376
Attn: Gregg Wilson

Date Received: 10/08/12 12:36
Report Date: 10/18/12
Customer #: 276581
PO#: G.Wilson

Laboratory Results

Sample No: 2101257-01

Collect Date: 10/05/12 12:43

Matrix: Ground Water

Sample Description: EF-1

Parameters	Result	Qual	Prep Date	Analysis Date	Analyst	Method
Volatile Organics - STL						
2-Nitropropane	< 10 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
4-Chlorotoluene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
4-Methyl-2-pentanone (MIBK)	< 10 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Acetone	18 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Acetonitrile	< 25 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Acrolein	< 25 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Acrylonitrile	< 10 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Allyl Chloride	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Benzene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Bromobenzene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Bromochloromethane	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Bromodichloromethane	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
<i>Surrogate: Bromofluorobenzene</i>	99 % 64.1-123			10/15/12 14:53	BP	SW 8260B
Bromoform	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Bromomethane	< 10 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Carbon disulfide	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Carbon tetrachloride	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Chlorobenzene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Chloroethane	< 10 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Chloroform	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Chloromethane	< 10 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
cis-1,2-Dichloroethene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
cis-1,3-Dichloropropene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Dibromochloromethane	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Dibromomethane	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Dichlorodifluoromethane	< 10 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Ethyl methacrylate	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Ethylbenzene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Hexachlorobutadiene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Iodomethane	< 10 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Isobutanol	< 25 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B

2101257



PDC Laboratories, Inc.
 3278 N. Highway 67 - Florissant, MO 63033
 (314) 432-0550 - (800) 333-FAST (3278) - FAX (314) 432-4977



Wainwright Industries
 17 Cermak Blvd
 St Peters, MO 63376
 Attn: Gregg Wilson

Date Received: 10/08/12 12:36
 Report Date: 10/18/12
 Customer #: 276581
 PO#: G.Wilson

Laboratory Results

Sample No: **2101257-01**

Collect Date: **10/05/12 12:43**

Matrix: **Ground Water**

Sample Description: EF-1

Parameters	Result	Qual	Prep Date	Analysis Date	Analyst	Method
Volatile Organics - STL						
Isopropylbenzene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
m,p-Xylene	< 10 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Methacrylonitrile	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Methyl methacrylate	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Methylene chloride	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
MTBE	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Naphthalene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
n-Butylbenzene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
n-Propylbenzene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
o-Xylene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
p-Isopropyl toluene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Propionitrile	< 10 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
sec-Butylbenzene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Styrene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
tert-Butylbenzene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Tetrachloroethene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Toluene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Surrogate: Toluene-d8	98 % 65.8-116			10/15/12 14:53	BP	SW 8260B
trans-1,2-Dichloroethene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
trans-1,3-Dichloropropene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
trans-1,4-Dichloro-2-butene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Trichloroethene	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Trichlorofluoromethane	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Vinyl acetate	< 10 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Vinyl chloride	< 5.0 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B
Xylenes- Total	< 15 ug/L		10/15/12 13:10	10/15/12 14:53	BP	SW 8260B

Sample No: **2101257-02**

Collect Date: **10/05/12 13:01**

Matrix: **Ground Water**

Sample Description: RW-1

2101257