

Gravois Arm Sewer District  
141 North Highway 5  
Gravois Mills, MO 65037

Dear Permittee:

Pursuant to the Federal Water Pollution Control Act, under the authority granted to the State of Missouri and in compliance with the Missouri Clean Water Law, we have issued and are enclosing your State Operating Permit to discharge from Gravois Arm Sewer District #1 Wastewater Treatment Facility, Morgan County, Missouri.

Please read your permit and enclosed Standard Conditions. They contain important information on monitoring requirements, effluent limitations, sampling frequencies and reporting requirements.

Monitoring reports required by the special conditions must be submitted on a periodic basis. The required forms are enclosed. Please make copies for your use. Completed forms should be mailed to this office.

**Please note** Special Condition #10 was added to the permit to address that only half of the wastewater treatment facility was built, but it appears that facility design is at capacity according to the number of connections.

This permit is both your Federal Discharge Permit and your new State Operating Permit and replaces all previous State Operating Permits for this facility under this permit number. In all future correspondence regarding this facility, please refer to your State Operating Permit number and facility name as shown on page one of the permit.

If you were affected by this decision, you may appeal to have the matter heard by the administrative hearing commission. To appeal, you must file a petition with the administrative hearing commission within thirty days after the date this decision was mailed or the date it was delivered, whichever date was earlier. If any such petition is sent by registered mail or certified mail, it will be deemed filed on the date it is mailed; if it is sent by any method other than registered mail or certified mail, it will be deemed filed on the date it is received by the administrative hearing commission.

If you have questions concerning this permit please contact Ms. Kristen Pattinson of my staff by calling 417-891-4300 or via mail at Southwest Regional Office, 2040 W. Woodland, Springfield, MO 65807-5912.

Sincerely,

SOUTHWEST REGIONAL OFFICE

Cynthia S. Davies  
Regional Director

CSD/kpl

Enclosures

141.wpcp.GravoisArmSewerDistrict1.mo0131822.x.2007.12.21.fy08.opnew.op5404.krp

STATE OF MISSOURI  
**DEPARTMENT OF NATURAL RESOURCES**  
MISSOURI CLEAN WATER COMMISSION



## MISSOURI STATE OPERATING PERMIT

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92<sup>nd</sup> Congress) as amended,

Permit No. MO0131822

Owner: Gravois Arm Sewer District  
Address: 141 North Hwy 5, Gravois Mills, MO 65037

Continuing Authority: Same as Above  
Address: Same as Above

Facility Name: Gravois Arm Sewer District WWTF #1 **Class C operator needed**  
Facility Address: Troutdale Road, Gravois Mills MO 65037

Legal Description: SW¼, SE¼, Sec. 17, T41N, R17W, Morgan County  
Lat/Long: +3818329 / -09249362

Receiving Stream: Unnamed Tributary to Spring Branch (U)  
First Classified Stream and ID: Spring Branch (P) (01099)  
USGS Basin & Sub-watershed No.: (10290109-050004)

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

### **FACILITY DESCRIPTION**

Outfall #001 - Sewerage Works - SIC #4952

Flow equalization / extended aeration / secondary clarifier / chlorination / dechlorination / reaeration / sludge disposal by contract hauler.

Design organic population equivalent is 290.  
Design average daily flow is 21,318 gallons per day.  
Design sludge production is 5.22 dry tons/year.

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Section 644.051.6 of the Law.

December 21, 2007  
Effective Date

Loyie Childer, Director, Department of Natural Resources  
Executive Secretary, Clean Water Commission

December 20, 2012  
Expiration Date  
MO 780-0041 (10-93)

\_\_\_\_\_  
Cynthia S. Davies, Regional Director, Southwest Regional Office

A. EFFLUENT LIMITATIONS AND MONITORING				PAGE NUMBER 2 of 6		
				PERMIT NUMBER MO0131822		
The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective upon issuance and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:						
OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
<u>Outfall #001</u>						
Flow	GPD	*		*	once/month**	24 hr. total
Biochemical Oxygen Demand <sub>5</sub>	mg/L	40		20	once/month**	grab
Total Suspended Solids	mg/L	40		20	once/month**	grab
pH – Units	SU	***		***	once/month**	grab
Fecal Coliform (Note 1)	#/100 ml	1000		400 (Note 2)	once/month**	grab
Total Residual Chlorine as Cl <sub>2</sub>	mg/L	0.016 (Note 3) (0.13 ML)		0.0082 (Note 3) (0.13ML)	once/month**	grab
Ammonia as N (March – May)	mg/L	6.8		2.6	once/month**	grab
(June – August)		3.2		1.2		
(September – November)		6.8		2.6		
(December – February)		7.5		2.9		
Temperature	°C	*		*	once/month**	grab
MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE <u>FEBRUARY 28, 2008</u> . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.						
<b>B. STANDARD CONDITIONS</b>						
IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED <u>Parts I, II &amp; III</u> STANDARD CONDITIONS DATED <u>October 1, 1980 and August 15, 1994</u> , AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.						

MO 780-0010 (8/91)

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

- \* Monitoring requirement only.
- \*\* Reports shall be submitted by the 28<sup>th</sup> day of the month following the reporting period, e.g. Reporting period is the month of March (samples collected monthly), report due by April 28<sup>th</sup>.
- \*\*\* pH is measured in pH units and is not to be averaged. The pH for all facilities except lagoons is limited to the range of 6.0-9.0 pH units.

Note 1 - Final limitations and monitoring requirements for Fecal Coliform are applicable only during the recreational season from April 1 through October 31.

Note 2 - Monthly average limit for Fecal Coliform is expressed as a geometric mean. Geometric mean for n samples =  $[a_1 \times a_2 \times a_3 \dots \times a_n]^{1/n}$

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

Note 3 - This permit contains a Total Residual Chlorine (TRC) limit.

- (a) This effluent limit is below the minimum quantification level (ML) of the most common and practical EPA approved CLTRC methods. The department has determined the current acceptable ML for total residual chlorine to be 0.13 mg/L when using the DPD Colorimetric Method #4500 – CL G. from Standard Methods for the Examination of Waters and Wastewater. The permittee will conduct analyses in accordance with this method, or equivalent, and report actual analytical values. Measured values greater than or equal to the minimum quantification level of 0.13 mg/L will be considered violations of the permit and values less than the minimum quantification level of 0.13 mg/L will be considered to be in compliance with the permit limitation. The minimum quantification level does not authorize the discharge of chlorine in excess of the effluent limits stated in the permit.
- (b) Disinfection is required year-round unless the permit specifically states that “Final limitations and monitoring requirements for Fecal Coliform are applicable only during the recreational season from April 1 through October 31.” If your permit does not require disinfection during the non-recreational months, do not chlorinate in those months.
- (c) Do not chemically dechlorinate **if it is not needed to meet the limits in your permit.**
- (d) If no chlorine was used in a given sampling period, an actual analysis is not necessary. Simply report as “0 mg/L” TRC.

C. INFLUENT MONITORING REQUIREMENTS			
The facility is required to meet a removal efficiency of /85% or more. The monitoring requirements shall become effective upon issuance and remain in effect until expiration of the permit. To determine removal efficiencies, the influent wastewater shall be monitored by the permittee as specified below:			
SAMPLING LOCATION AND PARAMETER(S)	UNITS	MONITORING REQUIREMENTS	
		MEASUREMENT FREQUENCY	SAMPLE TYPE
<u>Influent</u>			
Biochemical Oxygen Demand <sub>5</sub>	mg/L	once / month**	Grab
Total Suspended Solids	mg/L	once /month**	Grab
MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE <u>FEBRUARY 28, 2008.</u>			

MO 780-0010 (8/91)

C. INFLUENT MONITORING REQUIREMENTS (continued)

\*\* Reports shall be submitted by the 28<sup>th</sup> day of the month following the reporting period, e.g. Reporting period is the month of March (samples collected monthly), report due by April 28<sup>th</sup>.

D. SPECIAL CONDITIONS

- 1. This permit may be reopened and modified, or alternatively revoked and reissued, to:
  - (a) Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a) (2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
    - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
    - (2) controls any pollutant not limited in the permit.

D. SPECIAL CONDITIONS (continued)

- (b) Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri's Water Quality Standards.
- (c) Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri's list of waters of the state not fully achieving the state's water quality standards, also called the 303(d) list.

The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.

- 2. All outfalls must be clearly marked in the field.
- 3. Permittee will cease discharge by connection to areawide wastewater treatment system within 90 days of notice of its availability.
- 4. Changes in Discharges of Toxic Substances

The permittee shall notify the Director as soon as it knows or has reason to believe:

- (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:"
  - (1) One hundred micrograms per liter (100 µg/L);
  - (2) Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,5 dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
  - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;
  - (4) The level established in Part A of the permit by the Director.
- (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.

- 5. Report as no-discharge when a discharge does not occur during the report period.

6. Water Quality Standards

- (a) Discharges to waters of the state shall not cause a violation of water quality standards rule under 10 CSR 20-7.031, including both specific and general criteria.
- (b) General Criteria. The following general water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:
  - (1) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
  - (2) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
  - (3) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
  - (4) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
  - (5) There shall be no significant human health hazard from incidental contact with the water;

D. SPECIAL CONDITIONS (continued)

- (6) There shall be no acute toxicity to livestock or wildlife watering;
  - (7) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
  - (8) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.
7. Sludge and Biosolids Use For Domestic Wastewater Treatment Facilities
- (a) Permittee shall comply with the pollutant limitations, monitoring, reporting, and other requirements in accordance with the attached permit Standard Conditions.
  - (b) If sludge is not removed by a contract hauler, permittee is authorized to land apply biosolids. Permit Standard Conditions, Part III shall apply to the land application of biosolids. Permittee shall notify the department at least 180 days prior to the planned removal of biosolids. The department may require submittal of a biosolids management plan for department review and approval as determined appropriate on a case-by-case basis.
8. The permittee shall develop and implement a program for maintenance and repair of the collection system in accordance with the US EPA's Guide For Evaluating Capacity, Management, Operation, And Maintenance (CMOM) Programs At Sanitary Sewer Collection Systems (Document number EPA 305-B-05-002). The permittee shall submit a report semi-annually in **April and October** with the Discharge and Monitoring reports which address measures taken to locate and eliminate sources of infiltration and inflow into the City's collection system.
9. The permittee shall comply with any applicable requirements listed in 10 CSR 20-8 and 10 CSR 20-9. The monitoring frequencies contained in this permit shall not be construed by the permittee as a modification of the monitoring frequencies listed in 10 CSR 20-9. If a modification of the monitoring frequencies listed in 10 CSR 20-9 is needed, the permittee shall submit a written request to the department for review and, if deemed necessary, approval.
10. The facility must apply for a construction permit when the actual flow approaches 21,318 gallons per day.

E. SCHEDULE OF COMPLIANCE

Please note that the engineering design includes technology not addressed in Missouri Clean Water Commission Regulations 10 CSR 20-Chapter 8 design standards. To assess the effectiveness of the new technology at this facility, the following schedule of compliance must be followed.

1. The permittee acting under the supervision of a professional engineer registered in Missouri shall at a minimum, collect and test samples of wastewater treatment facility effluent as outlined in this permit, measure flow as outlined in this permit, and shall record all maintenance and operational problems experienced with the wastewater treatment facility during the first 34 months of operation. Other sample collection and testing including influent samples, and samples before and after each unit operation or group of unit operations, and other record keeping shall be done at the discretion of the professional engineer as needed to assess the new technology.
2. Within one (1) year of the date of issuance of this permit, the permittee shall submit a preliminary engineering report prepared by the professional engineer to the Southwest Regional Office evaluating the new technology for the first ten (10) months of operation. At the minimum, this evaluation shall include:
  - (a) Calculation of the mean (average) test results for all wastewater treatment facility effluent sample results collected under this permit for all parameters that have a maximum average monthly permit limit except pH.

E. SCHEDULE OF COMPLIANCE (continued)

(b) Calculation of the standard deviation of all test results noted above based on the following:

$$\text{Standard deviation} = \left[ \frac{(R_1 - \text{mean})^2 + (R_2 - \text{mean})^2 + (R_3 - \text{mean})^2 + \dots + (R_n - \text{mean})^2}{n - 1} \right]^{1/2}$$

where  $R_1, R_2, R_3$ , etc. are the individual sample results  
 $n$  is the total number of samples

(c) Calculation of the Coefficient of Variation (cv) for all test results noted above based on the following:

$$cv = \left[ \frac{\text{Standard Deviation}}{\text{Mean}} \right]$$

(d) Calculation of the Standard Deviation of Logarithms ( $\sigma$ ) for all test results noted above based on the following:

$$\sigma = \left[ \ln \left[ \frac{cv^2 + 1}{4} \right] \right]^{1/2}$$

where  $\ln$  is the natural logarithm to base  $e$   
 $e$  is 2.718281828

(e) Calculation of the Performance Standard (P) for 95<sup>th</sup> percentile probability for all test results noted above based on the following:

$$P = (\text{mean})e^{(z\sigma - 0.5\sigma^2)}$$

where  $z$  is 1.645 for 95 percentile probability

(f) The new technology will be deemed successful if the performance standard for 95<sup>th</sup> percentile probability is less than or equal to the permit maximum monthly average limit for each parameter.

(g) The preliminary engineering report shall also assess any operational or maintenance problems experienced during the initial ten (10) months of operation and shall describe all measures taken to overcome these problems. The engineer shall provide an assessment of whether operation or maintenance problems are sufficiently serious to require replacement of the new technology.

3. Within three (3) years of the date of issuance of this permit, the permittee shall submit a final engineering report prepared by the professional engineer to the Southwest Regional Office evaluating the new technology for the first 34 months of operation including all of the items described in the initial ten (10) month evaluation. Again, the new technology will be deemed successful if the performance standard for 95<sup>th</sup> percentile probability is less than or equal to the permit maximum monthly average limit for each parameter.

4. If the new technology fails to meet the 95<sup>th</sup> percentile probability performance standard for any parameter, or if the engineer assesses the operation and maintenance problems to be sufficiently serious to require replacement of the new technology, the permittee shall submit engineering report, plans, specifications prepared by a professional engineer registered in Missouri along with construction permit application forms, filing fee to Southwest Regional Office within one hundred twenty (120) calendar days of the date of submittal of the preliminary or final engineering report evaluation that identified the failure.

These documents shall outline replacement of the failed new technology with standard technology listed in Missouri Clean Water Commission Regulation 10 CSR 20-Chapter 8.

5. Within one hundred eighty (180) calendar days of receiving the construction permit, the permittee shall construct the replacement facilities and submit the Statement of Work Complete prepared by the professional engineer to Southwest Regional Office.

**Missouri Department of Natural Resources  
Statement of Basis  
Gravois Arm Sewer District WWTF #1  
NPDES #: MO-0131822  
Morgan County**

A Statement of Basis (Statement) gives pertinent information regarding the applicable regulations and rational for the development of the NPDES Missouri State Operating Permit (operating permit). This Statement includes Wasteload Allocations, Water Quality Based Effluent Limitations, and Reasonable Potential Analysis calculations as well as any other calculations that effect the effluent limitations of this operating permit. This Statement does not pertain to operating permits that include sewage sludge land application plans and variance procedures, and does not include the public comment process for this operating permit.

A Statement is not an enforceable part of an operating permit.

**Facility Information**

Facility Type: Sewerage Works  
Facility SIC Code(s): 4952

Facility Description:

**OUTFALL(S) TABLE:**

OUTFALL	DESIGN FLOW (CFS)	TREATMENT LEVEL	EFFLUENT TYPE	DISTANCE TO CLASSIFIED SEGMENT (MI)
001	0.033	Secondary	domestic, industrial (POTW)	0.2

Water Quality History: None, new facility

Comments: None. New facility

**Receiving Stream Information**

**APPLICABLE DESIGNATIONS OF WATERS OF THE STATE:**

As per Missouri's Effluent Regulations [10 CSR 20-7.015], the waters of the state are divided into the below listed seven (7) categories. Each category list effluent limitations for specific parameters, which are presented in each outfall's Effluent Limitation Table and further discussed in the Derivation & Discussion of Limits section.

Please mark the correct designated waters of the state categories of the receiving stream.

- Missouri or Mississippi River [10 CSR 20-7.015(2)]: Yes ; No
- Lake or Reservoir [10 CSR 20-7.015(3)]: Yes ; No
- Losing [10 CSR 20-7.015(4)]: Yes ; No
- Metropolitan No-Discharge [10 CSR 20-7.015(5)]: Yes ; No
- Special Stream [10 CSR 20-7.015(6)]: Yes ; No
- Subsurface Water [10 CSR 20-7.015(7)]: Yes ; No
- All Other Waters [10 CSR 20-7.015(8)]: Yes ; No

10 CSR 20-7.031 Missouri Water Quality Standards, the department defines the Clean Water Commission water quality objectives in terms of "water uses to be maintained and the criteria to protect those uses." The receiving stream and/or 1<sup>st</sup> classified receiving stream's beneficial water uses to be maintained are located in the Receiving Stream Table located below in accordance with [10 CSR 20-7.031(3)].

**RECEIVING STREAM(S) TABLE:**

WATERBODY NAME	CLASS	WBID	DESIGNATED USES*	8-DIGIT HUC	EDU**
Unnamed Tributary to Lake of the Ozarks	U	N/A	LWW, AQL, SCR, WBC (within 0.5 miles of the lake)	10290109	Ozark / Osage

\* - Irrigation (IRR), Livestock & Wildlife Watering (LWW), Protection of Warm Water Aquatic Life and Human Health-Fish Consumption (AQL), Cool Water Fishery (CLF), Cold Water Fishery (CDF), Whole Body Contact Recreation (WBC), Secondary Contact Recreation (SCR), Drinking Water Supply (DWS), Industrial (IND).

\*\* - Ecological Drainage Unit

**RECEIVING STREAM(S) LOW-FLOW VALUES TABLE:**

RECEIVING STREAM (U, C, P)	LOW-FLOW VALUES (CFS)		
	1Q10	7Q10	30Q10
Unnamed Tributary to Lake of the Ozarks	0	0	0

Mixing Zone: Not Allowed [10 CSR 20-7.031(4)(A)4.B.(I)(a)].

Zone of Initial Dilution: Not Allowed [10 CSR 20-7.031(4)(A)4.B.(I)(b)].

**Rationale and Derivation of Effluent Limitations & Permit Conditions****ALTERNATIVE EVALUATIONS FOR NEW FACILITIES:**

As per [10 CSR 20-7.015(4)(A)], discharges to losing streams shall be permitted only after other alternatives including land application, discharges to a gaining stream and connection to a regional wastewater treatment facility have been evaluated and determined to be unacceptable for environmental and/or economic reasons.

Not Applicable ;

The facility does not discharge to a Losing Stream as defined by [10 CSR 20-2.010(36)] & [10 CSR 20-7.031(1)(N)], or is an existing facility.

**ANTI-BACKSLIDING:**

A provision in the Federal Regulations [CWA §303(d)(4); CWA §402(c); CFR §122.44(I)] that requires a reissued permit to be as stringent as the previous permit with some exceptions.

- New facility.

**ANTIDegradation:**

Policies which ensure protection of water quality for a particular water body where the water quality exceeds levels necessary to protect fish and wildlife propagation and recreation on and in the water. This also includes special protection of waters designated as outstanding natural resource waters. Antidegradation requirements are consistent with 40 CFR 131.12 that outlines methods used to assess activities that may impact the integrity of a water and protect existing uses. This policy may compel the state to maintain a level of water quality above those mandated by criteria.

Applicable, but deferred ;

As per [10 CSR 20-7.031(2)(D)], the three (3) levels of protection provided by the antidegradation policy in subsections (A), (B), and (C) of this section shall be implemented according to procedures developed by the department. On April 20, 2007, the Missouri Clean Water Commission approved *Missouri Antidegradation Rule and Implementation Procedure* (Antidegradation Rule), which is applicable to new or upgraded/expanded facilities.

The implementation of the Antidegradation Rule will be implemented upon promulgation, which is tentatively scheduled for August 2008.

**APPLICABLE PERMIT PARAMETERS:**

Effluent parameters for conventional, non-conventional, and toxic pollutants have been obtained from the technology based effluent limits, water quality based limits, and from appropriate sections of the application.

**COMPLIANCE AND ENFORCEMENT:**

Action taken by the department to resolve violations of the Missouri Clean Water Law, its implementing regulations, and/or any terms and condition of an operating permit.

Not Applicable ;

The permittee/facility is not under enforcement action and is considered to be in compliance with the Missouri Clean Water Law, its implementing regulations, and/or any terms and condition of an operating permit.

**PRETREATMENT PROGRAM:**

The reduction of the amount of pollutants, the elimination of pollutants, or the alteration of the nature of pollutant properties in wastewater prior to or in lieu of discharging or otherwise introducing such pollutants into a Publicly Owned Treatment Works [40 CFR §403.3(q)].

Not Applicable ;

At this time, the permittee is not required to implement and enforce a Pretreatment Program.

**REASONABLE POTENTIAL ANALYSIS (RPA):**

Limitations must control all pollutants or pollutant parameters that are or may be discharged at a level which will cause, have reasonable potential to cause, or contribute to an excursion above the Missouri Water Quality Standards.

Not Applicable ;

A RPA was not conducted for this facility.

**REMOVAL EFFICIENCY:**

Removal efficiency is a method by which the Federal Regulations define Secondary Treatment and Equivalent to Secondary Treatment, which applies to Biochemical Oxygen Demand 5-day (BOD<sub>5</sub>) and Total Suspended Solids (TSS) for Publicly Owned Treatment Works (POTWs). Please see the United States Environmental Protection Agency's (EPA) website for interpretation of percent removal requirements for National Pollutant Discharge Elimination System Permit Application Requirements for Publicly Owned Treatment Works and Other Treatment Works Treating Domestic Sewage @ [www.epa.gov/fedrgstr/EPA-WATER/1999/August/Day-04/w18866.htm](http://www.epa.gov/fedrgstr/EPA-WATER/1999/August/Day-04/w18866.htm)

Applicable ;

Secondary Treatment is 85% removal [40 CFR Part 133.102(a)(3) & (b)(3)].

**SANITARY SEWER OVERFLOWS (SSOs), AND INFLOW & INFILTRATION (I&I):**

Collection systems are a critical element in the successful performance of the wastewater treatment process. Under certain conditions, poorly designed, built, managed, operated, and/or maintained systems can pose risks to public health, the environment, or both. Causes of SSOs include, but are not limited to, the following: high levels of I&I during wet weather; blockages; structural, mechanical, or electrical failures; collapsed or broken sewer pipes; insufficient conveyance capacity; and vandalism. Effective and continuous management, operation, and maintenance, as well as ensuring adequate capacity and rehabilitation when necessary are critical to maintaining collection system capacity and performance while extending the life of the system.

Applicable ;

The permittee is required to develop or implement a program for maintenance and repair of the collection system and shall be required in this operating permit by either means of a Special Condition or Schedule of Compliance.

**SCHEDULE OF COMPLIANCE (SOC):**

A schedule of remedial measures included in a permit, including an enforceable sequence of interim requirements (actions, operations, or milestone events) leading to compliance with the Missouri Clean Water Law, its implementing regulations, and/or the terms and conditions of an operating permit.

Applicable ;

This facility is using nonstandard technology. Therefore a schedule of compliance is being added. The nonstandard technology is for the extended aeration, clarifier, chlorination, and the reaeration.

**STORM WATER POLLUTION PREVENTION PLAN (SWPPP):**

A plan to schedule activities, prohibitions of practices, maintenance procedures, and other management practices to prevent or reduce the pollution of waters of the state. The plan may include, but is not limited to, treatment requirements, operating procedures, and practices to control facility site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage.

Not Applicable ;

At this time, the permittee is not required to develop and implement a SWPPP.

**WASTELOAD ALLOCATIONS (WLA) FOR LIMITS:**

As per [10 CSR 20-2.010(78)], the amount of pollutant each discharger is allowed by the department to release into a given stream after the department has determined to total amount of pollutant that may be discharged into that stream without endangering its water quality.

Applicable ;

Wasteload allocations were calculated where applicable using water quality criteria or water quality model results and the dilution equation below:

$$C = \frac{(C_s \times Q_s) + (C_e \times Q_e)}{(Q_e + Q_s)} \quad (\text{EPA/505/2-90-001, Section 4.5.5})$$

Where C = downstream concentration  
Cs = upstream concentration  
Qs = upstream flow  
Ce = effluent concentration  
Qe = effluent flow

Chronic wasteload allocations were determined using applicable chronic water quality criteria (CCC: criteria continuous concentration) and stream volume of flow at the edge of the mixing zone (MZ). Acute wasteload allocations were determined using applicable water quality criteria (CMC: criteria maximum concentration) and stream volume of flow at the edge of the zone of initial dilution (ZID).

Water quality based maximum daily and average monthly effluent limitations were calculated using methods and procedures outlined in USEPA's "Technical Support Document For Water Quality-based Toxics Control" (EPA/505/2-90-001).

**WLA MODELING:**

Not Applicable ;

A WLA study was either not submitted or determined not applicable by department staff.

**WHOLE EFFLUENT TOXICITY (WET) TEST:**

As per [10 CSR 20-7.031(1)(CC)], a toxicity test conducted under specified laboratory conditions on specific indicator organism; and as per [40 CFR §122.2], the aggregate toxic effect of an effluent measured directly by a toxicity test.

Not Applicable ;

At this time, the permittee is not required to conduct WET test for this facility.

**303(d) LIST & TOTAL MAXIMUM DAILY LOAD (TMDL):**

Section 303(d) of the federal Clean Water Act requires that each state identify waters that are not meeting water quality standards and for which adequate water pollution controls have not been required. Water quality standards protect such beneficial uses of water as whole body contact (such as swimming), maintaining fish and other aquatic life, and providing drinking water for people, livestock and wildlife. The 303(d) list helps state and federal agencies keep track of waters that are impaired but not addressed by normal water pollution control programs.

A TMDL is a calculation of the maximum amount of a given pollutant that a body of water can absorb before its water quality is affected. If a water body is determined to be impaired as listed on the 303(d) list, then a watershed management plan will be developed that shall include the TMDL calculation

Applicable ;

Lake of the Ozarks is listed on the 2002 Missouri 303(d) List for Low dissolved oxygen, fish trauma, and gas supersaturation.

– This facility is not considered to be a source of the above listed pollutant(s) or considered to contribute to the impairment of Lake of the Ozarks.

**Outfall #001 – Main Facility Outfall**

**EFFLUENT LIMITATIONS TABLE:**

PARAMETER	UNIT	BASIS FOR LIMITS	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MODIFIED	PREVIOUS PERMIT LIMITATIONS
FLOW	GPD	1	*		*	N/A	N/A
BOD <sub>5</sub> **	MG/L	1	40		20	N/A	N/A
TSS **	MG/L	1	40		20	N/A	N/A
pH (S.U.)	SU	1	6-9		6-9	N/A	N/A
AMMONIA AS N (MARCH - MAY)	MG/L	5	6.8		2.6	N/A	N/A
AMMONIA AS N (JUNE - AUGUST)	MG/L	5	3.2		1.2	N/A	N/A
AMMONIA AS N (SEPTEMBER - NOVEMBER)	MG/L	5	6.8		2.6	N/A	N/A
AMMONIA AS N (DECEMBER - FEBRUARY)	MG/L	5	7.5		2.9	N/A	N/A

FECAL COLIFORM	***	1	1000		400	N/A	N/A
CHLORINE, TOTAL RESIDUAL	MG/L	3	0.016		0.0082	N/A	N/A
TEMPERATURE	°C	5	*		*	N/A	N/A
MONITORING FREQUENCY	Please see Minimum Sampling and Reporting Frequency Requirements in the Derivation and Discussion Section below.						

**\* - Monitoring requirement only**

\*\*\* - # of colonies/100mL; the Monthly Average for Fecal Coliform is a geometric mean.

\*\*\*\* - Parameter not previously established in previous state operating permit.

N/A – Not applicable

S – Same as previous operating permit

**Basis for Limitations Codes:**

- |  |                                   |
|--|-----------------------------------|
| 1. State or Federal Regulation/Law       | 6. Antidegradation Policy         |
| 2. Water Quality Standard (includes RPA) | 7. Water Quality Model            |
| 3. Water Quality Based Effluent Limits   | 8. Best Professional Judgement    |
| 4. Lagoon Policy                         | 9. TMDL or Permit in lieu of TMDL |
| 5. Ammonia Policy                        | 10. WET test Policy               |

**OUTFALL #001 – DERIVATION AND DISCUSSION OF LIMITS:**

**Biochemical Oxygen Demand (BOD<sub>5</sub>).**

- 40 mg/L Daily Maximum and 20 mg/L Monthly Average effluent limitations, as per [10 CSR 20-7.015]. The daily maximum is calculated by  $(20 \times 3.114) / 1.5524 = 40$  mg/L daily maximum.

**Total Suspended Solids (TSS).**

- 40 mg/L Daily Maximum and 20 mg/L Monthly Average effluent limitations, as per [10 CSR 20-7.015]. The daily maximum is calculated by  $(20 \times 3.114) / 1.5524 = 40$  mg/L daily maximum.

**pH.**

- pH is limited to the range of 6.0 – 9.0 pH units, as per [10 CSR 20-7.015]. pH is measured in pH units and is not to be averaged.

**Temperature.** Monitoring requirement due to the toxicity of Ammonia varies by temperature.

**Total Ammonia Nitrogen.** Early Life Stages Present Total Ammonia Nitrogen criteria apply [10 CSR 20-7.031(4)(B)7.C. & Table B3]. Background total ammonia nitrogen = 0.01 mg/L. The facility is less than a quarter mile from the lake. Therefore the decay rate would be zero or negligible.

Season	Temp (°C)	pH (SU)	Total Ammonia Nitrogen CCC (mg N/L)	Total Ammonia Nitrogen CMC (mg N/L)
Mar 1 – May 31	16	7.8	2.8	12.1
Jun 1 – Aug 31	28	7.8	1.3	12.1
Sept 1 – Nov 30	16	7.8	2.8	12.1
Dec 1 – Feb 29	6	7.8	3.1	12.1

Spring: Mar 1 – May 31, Summer: Jun 1 – Aug 31, Fall: Sep 1 – Nov 30, Winter: Dec 1 – Feb 29

**Spring** – Chronic WLA = 2.8 mg N/L, Acute WLA = 12.1 mg N/L. No mixing zone is allowed. Discharges to Unclassified Stream.

LTA<sub>c</sub> = 2.8 mg/L (0.780) = 2.2 mg N/L [CV = 0.6, 99<sup>th</sup> Percentile, 30 day average]  
LTA<sub>a</sub> = 12.1 mg/L (0.321) = 3.9 mg N/L [CV = 0.6, 99<sup>th</sup> Percentile]

MDL = 2.2 mg/L \* 3.114 = 6.8 mg N/L [CV = 0.6, 99<sup>th</sup> Percentile]

$$\text{AML} = 2.2 \text{ mg/L} * 1.19 = 2.6 \text{ mg N/L} \quad [\text{CV} = 0.6, 95^{\text{th}} \text{ Percentile}, n = 30]$$

Summer – Chronic WLA = 1.3 mg N/L, Acute WLA = 12.1 mg N/L. No mixing zone is allowed. Discharges to Unclassified Stream.

$$\text{LTA}_c = 1.3 \text{ mg/L} (0.780) = 1.0 \text{ mg N/L} \quad [\text{CV} = 0.6, 99^{\text{th}} \text{ Percentile}, 30 \text{ day average}]$$

$$\text{LTA}_a = 12.1 \text{ mg/L} (0.321) = 3.9 \text{ mg N/L} \quad [\text{CV} = 0.6, 99^{\text{th}} \text{ Percentile}]$$

$$\text{MDL} = 1.0 \text{ mg/L} * 3.114 = 3.2 \text{ mg N/L} \quad [\text{CV} = 0.6, 99^{\text{th}} \text{ Percentile}]$$

$$\text{AML} = 2.2 \text{ mg/L} * 1.19 = 2.6 \text{ mg N/L} \quad [\text{CV} = 0.6, 95^{\text{th}} \text{ Percentile}, n = 30]$$

Fall – Chronic WLA = 2.8 mg N/L, Acute WLA = 12.1 mg N/L. No mixing zone is allowed. Discharges to Unclassified Stream.

$$\text{LTA}_c = 2.8 \text{ mg/L} (0.780) = 2.2 \text{ mg N/L} \quad [\text{CV} = 0.6, 99^{\text{th}} \text{ Percentile}, 30 \text{ day average}]$$

$$\text{LTA}_a = 12.1 \text{ mg/L} (0.321) = 3.9 \text{ mg N/L} \quad [\text{CV} = 0.6, 99^{\text{th}} \text{ Percentile}]$$

$$\text{MDL} = 2.2 \text{ mg/L} * 3.114 = 6.8 \text{ mg N/L} \quad [\text{CV} = 0.6, 99^{\text{th}} \text{ Percentile}]$$

$$\text{AML} = 2.2 \text{ mg/L} * 1.19 = 2.6 \text{ mg N/L} \quad [\text{CV} = 0.6, 95^{\text{th}} \text{ Percentile}, n = 30]$$

Winter – Chronic WLA = 3.1 mg N/L, Acute WLA = 12.1 mg N/L. No mixing zone is allowed. Discharges to Unclassified Stream.

$$\text{LTA}_c = 3.1 \text{ mg/L} (0.780) = 2.4 \text{ mg N/L} \quad [\text{CV} = 0.6, 99^{\text{th}} \text{ Percentile}, 30 \text{ day average}]$$

$$\text{LTA}_a = 12.1 \text{ mg/L} (0.321) = 3.9 \text{ mg N/L} \quad [\text{CV} = 0.6, 99^{\text{th}} \text{ Percentile}]$$

$$\text{MDL} = 2.4 \text{ mg/L} * 3.114 = 7.5 \text{ mg N/L} \quad [\text{CV} = 0.6, 99^{\text{th}} \text{ Percentile}]$$

$$\text{AML} = 2.2 \text{ mg/L} * 1.19 = 2.6 \text{ mg N/L} \quad [\text{CV} = 0.6, 95^{\text{th}} \text{ Percentile}, n = 30]$$

Season	Maximum Daily Limit (mg N/L)	Average Monthly Limit (mg N/L)
Mar 1 – May 31	6.8	2.6
Jun 1 – Aug 31	3.2	1.2
Sept 1 – Nov 30	6.8	2.6
Dec 1 – Feb 29	7.5	2.9

**Fecal Coliform.** Discharge shall not contain more than a monthly geometric mean of 400 colonies/100 mL and a daily maximum of 1000 colonies/100 mL, [10 CSR 20-7.015.]. Future renewals of the facility operating permit will contain effluent limitations for E. coli, which will replace fecal coliform as the applicable bacteria criteria in Missouri's water quality standards

**Total Residual Chlorine (TRC).** Warm-water Protection of Aquatic Life CCC = 10 µg/L, CMC = 19 µg/L [10 CSR 20-7.031, Table A]. Background TRC = 0.0 µg/L.

$$((Q_e + Q_s) * C - (Q_s * C_s)) / Q_e$$

$$\text{Acute: } C_c = ((0.033 + 0) * 0.019 - (0 * 0)) / 0.033 = 0.019$$

$$\text{WLA}_a = 0.019 \text{ mg/L}$$

$$\text{Chronic: } C_c = ((0.033 + 0) * 0.01 - (0 * 0)) / 0.033 = 0.01$$

$$\text{WLA}_c = 0.01 \text{ mg/L}$$

$$\text{LTA}_a = 0.019 (0.321) = 0.0061 \text{ mg/L} \quad [\text{CV} = 0.6, 99^{\text{th}} \text{ Percentile}]$$

$$\text{LTA}_c = 0.01 (0.5274) = \mathbf{0.005274} \text{ mg/L} \quad [\text{CV} = 0.6, 99^{\text{th}} \text{ Percentile}]$$

$$\text{MDL} = 0.005274(3.114) = 0.016 \text{ mg/L} \quad [\text{CV} = 0.6, 99^{\text{th}} \text{ Percentile}]$$

$$\text{AML} = 0.005274(1.55) = 0.0082 \text{ mg/L} \quad [\text{CV} = 0.6, 95^{\text{th}} \text{ Percentile}, n = 4]$$

**Minimum Sampling and Reporting Frequency Requirements.**

PARAMETER	SAMPLING FREQUENCY	REPORTING FREQUENCY
FLOW	MONTHLY	MONTHLY
BOD <sub>5</sub>	MONTHLY	MONTHLY
TSS	MONTHLY	MONTHLY
pH (S.U.)	MONTHLY	MONTHLY
TEMPERATURE (°C)	MONTHLY	MONTHLY
AMMONIA AS N (MARCH - MAY)	MONTHLY	MONTHLY
AMMONIA AS N (JUNE - AUGUST)	MONTHLY	MONTHLY
AMMONIA AS N (SEPTEMBER - NOVEMBER)	MONTHLY	MONTHLY
AMMONIA AS N (DECEMBER - FEBRUARY)	MONTHLY	MONTHLY
FECAL COLIFORM	MONTHLY	MONTHLY
TOTAL RESIDUAL CHLORINE	MONTHLY	MONTHLY

**Administrative Requirements**

On the basis of preliminary staff review and the application of applicable standards and regulations, the Department, as administrative agent for the Missouri Clean Water Commission, proposes to issue a permit(s) subject to certain effluent limitations, schedules, and special conditions contained herein and within the operating permit. The proposed determinations are tentative pending public comment.

**Date of Factsheet:**

Kristen Pattinson  
WP Permitting and Assistance Unit  
(417) 891-4300  
kristen.pattinson@dnr.mo.gov