

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES

MISSOURI CLEAN WATER COMMISSION



MISSOURI STATE OPERATING PERMIT

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92nd Congress) as amended,

Permit No. MO-0133205

Owner: Holtgrewe Farms Sewer Company
Address: 109 North Oak Street, Union, MO 63084

Continuing Authority: Same as above
Address: Same as above

Facility Name: Holtgrewe Farms
Facility Address: Holtgrewe Farms Drive, Washington, MO 63090

Legal Description: SW¹/₄, SE¹/₄, SE¹/₄, Sec. 20, T44N, R1W, Franklin County
UTM Coordinates: X=670081, Y=4268170

Receiving Stream: Unnamed Tributary to St. Johns Creek (U)
First Classified Stream and ID: St. Johns Creek (P) (01678)
USGS Basin & Sub-watershed No.: (10300200-0503)

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

FACILITY DESCRIPTION

Outfall #001 - Private Sewer Company, Subdivision - SIC # 4959
Septic tank/recirculating sand filter/ultraviolet disinfection/sludge disposal by contract hauler.
Design population equivalent is 175.
Design flow is 17,500 gallons per day.
Design sludge production is 1.2 dry tons/year.

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with RSMo Section 644.051.6 and 621.250, 10 CSR 20-6.020, and 10 CSR 20-1.020.

December 9, 2011
Effective Date

Sara Parker Pauley, Director, Department of Natural Resources

December 8, 2016
Expiration Date

Mike Struckhoff, Director, St. Louis Regional Office

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS	PAGE NUMBER 2 of 4
	PERMIT NUMBER MO-0133205

The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective upon issuance and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:

OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
<u>Outfall #001</u>						
Flow	MGD	*		*	once/month	24 hr. estimate
Biochemical Oxygen Demand ₅ **	mg/L		45	30	once/quarter***	grab
Total Suspended Solids**	mg/L		45	30	once/quarter***	grab
pH – Units	SU	****		****	once/quarter***	grab
Ammonia as N (April 1 – Sept. 31) (Oct. 1 – March 30)	mg/L				once/quarter***	grab
		3.7		1.4		
		7.5		2.9		
E. Coli (Note 1)	#/100 ml	1030		206	once/quarter***	grab

MONITORING REPORTS SHALL BE SUBMITTED QUARTERLY; THE FIRST REPORT IS DUE April 28, 2012 . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.

B. STANDARD CONDITIONS

IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED Parts I & III STANDARD CONDITIONS DATED October 1, 1980 and August 15, 1994, AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.

MO 780-0010 (8/91)

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

- * Monitoring requirement only.
- ** This facility is required to meet a removal efficiency of 85% or more.
- *** See table below for quarterly sampling.
- **** pH is measured in pH units and is not to be averaged. The pH is limited to the range of 6.5-9.0 pH units.

Sample discharge at least once for the months of:	Report is due:
January, February, March (1st Quarter)	April 28
April, May, June (2nd Quarter)	July 28
July, August, September (3rd Quarter)	October 28
October, November, December (4th Quarter)	January 28

Note 1 - Final limitations and monitoring requirements for E-Coli. are applicable only during the recreational season from April 1 through October 31. The Monthly Average Limit for E. Coli. is expressed as a geometric mean. The fourth quarter sample for E-Coli. must be collected in October.

D. SPECIAL CONDITIONS

1. This permit may be reopened and modified, or alternatively revoked and reissued, to:
 - (a) Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a) (2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
 - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
 - (2) controls any pollutant not limited in the permit.
 - (b) Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri's Water Quality Standards.
 - (c) Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri's list of waters of the state not fully achieving the state's water quality standards, also called the 303(d) list.

The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.

2. All outfalls must be clearly marked in the field.
3. Permittee will cease discharge by connection to a facility with an area-wide management plan per 10 CSR 20-6.010(3)(B) within 90 days of notice of its availability.
4. Changes in Discharges of Toxic Substances

The permittee shall notify the Director as soon as it knows or has reason to believe:

- (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:"
 - (1) One hundred micrograms per liter (100 µg/L);
 - (2) Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,5 dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
 - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;
 - (4) The level established in Part A of the permit by the Director.
 - (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.
5. Report as no-discharge when a discharge does not occur during the report period.

6. Water Quality Standards

- (a) Discharges to waters of the state shall not cause a violation of water quality standards rule under 10 CSR 20-7.031, including both specific and general criteria.
- (b) General Criteria. The following general water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:
 - (1) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
 - (2) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
 - (3) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
 - (4) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
 - (5) There shall be no significant human health hazard from incidental contact with the water;
 - (6) There shall be no acute toxicity to livestock or wildlife watering;
 - (7) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
 - (8) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.

D. SPECIAL CONDITIONS (continued)

7. The permittee shall comply with any applicable requirements listed in 10 CSR 20-8 and 10 CSR 20-9, unless the facility has received written notification that the Department has approved a modification to the requirements. The monitoring frequencies contained in this permit shall not be construed by the permittee as a modification of the monitoring frequencies listed in 10 CSR 20-9. If a modification of the monitoring frequencies listed in 10 CSR 20-9 is needed, the permittee shall submit a written request to the department for review and, if deemed necessary, approval.

Missouri Department of Natural Resources
FACT SHEET
FOR THE PURPOSE OF NEW FACILITY
MO-0133205
STONEWATER SUBDIVISION

The Federal Water Pollution Control Act ("Clean Water Act" Section 402 Public Law 92-500 as amended) established the National Pollution Discharge Elimination System (NPDES) permit program. This program regulates the discharge of pollutants from point sources into the waters of the United States, and the release of storm water from certain point sources. All such discharges are unlawful without a permit (Section 301 of the "Clean Water Act"). After a permit is obtained, a discharge not in compliance with all permit terms and conditions is unlawful. Missouri State Operating Permits (MSOPs) are issued by the Director of the Missouri Department of Natural Resources (department) under an approved program, operating in accordance with federal and state laws (Federal "Clean Water Act" and "Missouri Clean Water Law" Section 644 as amended). MSOPs are issued for a period of five (5) years unless otherwise specified.

As per [40 CFR Part 124.8(a)] and [10 CSR 20-6.020(1)2.] a Factsheet shall be prepared to give pertinent information regarding the applicable regulations, rationale for the development of effluent limitations and conditions, and the public participation process for the Missouri State Operating Permit (operating permit) listed below.

A Factsheet is not an enforceable part of an operating permit.

This Factsheet is for a Major , Minor , Industrial Facility ; Variance ;
 Master General Permit ; General Permit Covered Facility ; and/or permit with widespread public interest .

Part I – Facility Information

Facility Type: NON-POTW
 Facility SIC Code(s): 4952

Facility Description:

Septic tank/recirculating sand filter/ultraviolet disinfection/sludge disposal by contract hauler.
 Design population equivalent is 175.
 Design flow is 17,500 gallons per day.
 Design sludge production is 1.2 dry tons/year.

Application Date: 7-13-2006
 Expiration Date:
 Last Inspection: NA new proposed facility

OUTFALL(S) TABLE:

OUTFALL	DESIGN FLOW (CFS)	TREATMENT LEVEL	EFFLUENT TYPE	DISTANCE TO CLASSIFIED SEGMENT (MI)
#001	0.027	Secondary	Domestic wastewater	1.2

Outfall #001

Legal Description: SW¼, SE¼, SE¼, Sec. 20, T44N, R1W, Franklin County
 Latitude/Longitude: +3832449/-09102541 (estimated)

Receiving Stream: Unnamed Tributary to St. Johns Creek (U)
 First Classified Stream and ID: St. Johns Creek (P) (01678)
 USGS Basin & Sub-watershed No.: (10300200-110002)

Water Quality History:
none, new facility

Comments:

Mr. Bradley Ferguson, has applied for a construction permit to install a sewage treatment plant with a design flow of 17,500 GPD. For this development, Mr. Ferguson is in a partnership with Mr. Tony Bequette. The proposed treatment plant is a recirculating sand filter followed by ultraviolet disinfection. The treatment plant is to serve Stonewater Subdivision, a proposed new subdivision with 47 single family homes located off Holtgrewe Road. The proposed discharge location is near the southwest corner boundary of Stonewater Subdivision. Effluent limits for the new facility have been established by a Water Quality Review Sheet completed by the Water Pollution Control Branch 1-3-06.

This proposed facility was placed on public notice on 8-31-2006. Comments were received and Mr. Ferguson also explored connection to the City of Washington as well as other subdivision lot densities. Mr. Ferguson desires to pursue the original design with 47 lots. The proposed permit is hereby being placed on public notice again because of minor changes to the original draft permit.

Part II – Operator Certification Requirements

Not Applicable ; This facility is not required to have a certified operator.

Part III – Receiving Stream Information

APPLICABLE DESIGNATIONS OF WATERS OF THE STATE:

As per Missouri’s Effluent Regulations [10 CSR 20-7.015], the waters of the state are divided into the below listed seven (7) categories. Each category lists effluent limitations for specific parameters, which are presented in each outfall’s Effluent Limitation Table and further discussed in the Derivation & Discussion of Limits section.

- Missouri or Mississippi River [10 CSR 20-7.015(2)]:
- Lake or Reservoir [10 CSR 20-7.015(3)]:
- Losing [10 CSR 20-7.015(4)]:
- Metropolitan No-Discharge [10 CSR 20-7.015(5)]:
- Special Stream [10 CSR 20-7.015(6)]:
- Subsurface Water [10 CSR 20-7.015(7)]:
- All Other Waters [10 CSR 20-7.015(8)]:

10 CSR 20-7.031 Missouri Water Quality Standards, the department defines the Clean Water Commission water quality objectives in terms of "water uses to be maintained and the criteria to protect those uses." The receiving stream and/or 1st classified receiving stream’s beneficial water uses to be maintained are located in the Receiving Stream Table located below in accordance with [10 CSR 20-7.031(3)].

RECEIVING STREAM(S) TABLE:

WATERBODY NAME	CLASS	WBID	DESIGNATED USES*	8-DIGIT HUC	EDU**
Unnamed Tributary to St. Johns Creek	U		General Criteria	10300200	Ozark/ Moreau/ Loutre
St. Johns Creek	P	01678	LWW, AQL, WBC***		

* - Irrigation (IRR), Livestock & Wildlife Watering (LWW), Protection of Warm Water Aquatic Life and Human Health-Fish Consumption (AQL), Cool Water Fishery(CLF), Cold Water Fishery (CDF), Whole Body Contact Recreation (WBC), Secondary Contact Recreation (SCR), Drinking Water Supply (DWS), Industrial (IND), Groundwater (GRW).

** - Ecological Drainage Unit

*** - UAA has not been conducted.

RECEIVING STREAM(S) LOW-FLOW VALUES TABLE:

RECEIVING STREAM (U, C, P)	LOW-FLOW VALUES (CFS)		
	1Q10	7Q10	30Q10
Unnamed Tributary to St. Johns Creek (U)	0	0	

Mixing Zone: Not Allowed [10 CSR 20-7.031(4)(A)4.B.(I)(a)].

Zone of Initial Dilution: Not Allowed [10 CSR 20-7.031(4)(A)4.B.(I)(b)].

RECEIVING STREAM MONITORING REQUIREMENTS:

No receiving water monitoring requirements recommended at this time.

Part IV – Rationale and Derivation of Effluent Limitations & Permit Conditions

ALTERNATIVE EVALUATIONS FOR NEW FACILITIES:

As per [10 CSR 20-7.015(4)(A)], discharges to losing streams shall be permitted only after other alternatives including land application, discharges to a gaining stream and connection to a regional wastewater treatment facility have been evaluated and determined to be unacceptable for environmental and/or economic reasons.

Not Applicable ;

The facility does not discharge to a Losing Stream as defined by [10 CSR 20-2.010(36)] & [10 CSR 20-7.031(1)(N)], or is an existing facility.

ANTIDEGRADATION:

In accordance with Missouri's Water Quality Standard [10 CSR 20-7.031(2)], the department is to document by means of Antidegradation Review that the use of a water body's available assimilative capacity is justified. Degradation is justified by documenting the socio-economic importance of a discharging activity after determining the necessity of the discharge.

- As per [10 CSR 20-7.031(2)(D)], the three (3) levels of protection provided by the antidegradation policy in subsections (A), (B), and (C) of this section shall be implemented according to procedures developed by the department. On April 20, 2007, the Missouri Clean Water Commission approved *Missouri Antidegradation Rule and Implementation Procedure* (Antidegradation Rule), which is applicable to new or upgraded/expanded facilities. The implementation of the Antidegradation Rule will be implemented upon promulgation, which occurred on August 31, 2008. This application was received July 13, 2006.

BIO-SOLIDS, SLUDGE, & SEWAGE SLUDGE:

Bio-solids are solid materials resulting from wastewater treatment that meet federal and state criteria for beneficial uses (i.e. fertilizer). Sludge is any solid, semi-solid, or liquid waste generated from a municipal, commercial, or industrial wastewater treatment plant, water supply treatment plant, or air pollution control facility or any other such waste having similar characteristics and effect. Sewage sludge is solids, semi-solids, or liquid residue generated during the treatment of domestic sewage in a treatment works; including but not limited to, domestic septage; scum or solids removed in primary, secondary, or advanced wastewater treatment process; and a material derived from sewage sludge. Sewage sludge does not include ash generated during the firing of sewage sludge in a sewage sludge incinerator or grit and screening generated during preliminary treatment of domestic sewage in a treatment works.

Not Applicable ;

This condition is not applicable to the permittee for this specific facility.

REASONABLE POTENTIAL ANALYSIS (RPA):

Federal regulation [40 CFR Part 122.44(d)(1)(i)] requires effluent limitations for all pollutants that are or may be discharged at a level that will cause or have the reasonable potential to cause or contribute to an in-stream excursion above narrative or numeric water quality standard.

Not Applicable ;

A RPA was not conducted for this facility.

REMOVAL EFFICIENCY:

Removal efficiency is a method by which the Federal Regulations define Secondary Treatment and Equivalent to Secondary Treatment, which applies to Biochemical Oxygen Demand 5-day (BOD₅) and Total Suspended Solids (TSS) for Publicly Owned Treatment Works (POTWs)/municipals. Please see the United States Environmental Protection Agency's (EPA) website for interpretation of percent removal requirements for National Pollutant Discharge Elimination System Permit Application Requirements for Publicly Owned Treatment Works and Other Treatment Works Treating Domestic Sewage @ www.epa.gov/fedrgstr/EPA-WATER/1999/August/Day-04/w18866.htm.

Not Applicable ;

This wastewater treatment facility is not a POTW. Influent monitoring is not being required to determine percent removal.

SANITARY SEWER OVERFLOWS (SSOs), AND INFLOW & INFILTRATION (I&I):

Collection systems are a critical element in the successful performance of the wastewater treatment process. Under certain conditions, poorly designed, built, managed, operated, and/or maintained systems can pose risks to public health, the environment, or both. Causes of SSOs include, but are not limited to, the following: high levels of I&I during wet weather; blockages; structural, mechanical, or electrical failures; collapsed or broken sewer pipes; insufficient conveyance capacity; and vandalism. Effective and continuous management, operation, and maintenance, as well as ensuring adequate capacity and rehabilitation when necessary are critical to maintaining collection system capacity and performance while extending the life of the system.

Not Applicable ;

This facility is not required to develop or implement a program for maintenance and repair of the collection system; however, it is a violation of Missouri State Environmental Laws and Regulations to allow untreated wastewater to discharge to waters of the state.

STORM WATER POLLUTION PREVENTION PLAN (SWPPP):

A plan to schedule activities, prohibitions of practices, maintenance procedures, and other management practices to prevent or reduce the pollution of waters of the state. The plan may include, but is not limited to, treatment requirements, operating procedures, and practices to control facility site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage.

Not Applicable ;

At this time, the permittee is not required to develop and implement a SWPPP.

WASTELOAD ALLOCATIONS (WLA) FOR LIMITS:

As per [10 CSR 20-2.010(78)], the amount of pollutant each discharger is allowed by the department to release into a given stream after the department has determined total amount of pollutant that may be discharged into that stream without endangering its water quality.

Applicable ;

Wasteload allocations were calculated where applicable using water quality criteria or water quality model results and the dilution equation below:

$$C = \frac{(C_s \times Q_s) + (C_e \times Q_e)}{(Q_e + Q_s)} \quad (\text{EPA/505/2-90-001, Section 4.5.5})$$

Where C = downstream concentration

Cs = upstream concentration

Qs = upstream flow

Ce = effluent concentration

Qe = effluent flow

Chronic wasteload allocations were determined using applicable chronic water quality criteria (CCC: criteria continuous concentration) and stream volume of flow at the edge of the mixing zone (MZ). Acute wasteload allocations were determined using applicable water quality criteria (CMC: criteria maximum concentration) and stream volume of flow at the edge of the zone of initial dilution (ZID).

Water quality based maximum daily and average monthly effluent limitations were calculated using methods and procedures outlined in USEPA's "Technical Support Document For Water Quality-based Toxics Control" (EPA/505/2-90-001).

WLA MODELING:

There are two general types of effluent limitations, technology-based effluent limits (TBELs) and water quality based effluent limits (WQBELs). If TBELs do not provide adequate protection for the receiving waters, then WQBEL must be used.

Not Applicable ;

A WLA study was either not submitted or determined not applicable by department staff.

WHOLE EFFLUENT TOXICITY (WET) TEST:

A WET test is a quantifiable method of determining if a discharge from a facility may be causing toxicity to aquatic life by itself, in combination with or through synergistic responses when mixed with receiving stream water.

Not Applicable ;

At this time, the permittee is not required to conduct WET test for this facility.

303(d) LIST & TOTAL MAXIMUM DAILY LOAD (TMDL):

Section 303(d) of the federal Clean Water Act requires that each state identify waters that are not meeting water quality standards and for which adequate water pollution controls have not been required. Water quality standards protect such beneficial uses of water as whole body contact (such as swimming), maintaining fish and other aquatic life, and providing drinking water for people, livestock and wildlife. The 303(d) list helps state and federal agencies keep track of waters that are impaired but not addressed by normal water pollution control programs.

A TMDL is a calculation of the maximum amount of a given pollutant that a body of water can absorb before its water quality is affected. If a water body is determined to be impaired as listed on the 303(d) list, then a watershed management plan will be developed that shall include the TMDL calculation

Not Applicable ;

This facility does not discharge to a 303(d) listed stream.

Part V – Effluent Limits Determination

Outfall #001 – Main Facility Outfall

EFFLUENT LIMITATIONS TABLE:

PARAMETER	UNIT	BASIS FOR LIMITS	DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MODIFIED	PREVIOUS PERMIT LIMITATIONS
FLOW	GPD	1	*		*	NEW PERMIT	NA
BOD ₅	MG/L	1		45	30	“	“
TSS	MG/L	1		45	30	“	“
pH	SU	1	6-9			“	“
TEMPERATURE	°C	1/5	*		*	“	“
AMMONIA AS N (MAY 1 – OCT 31)	MG/L	2/3/5	3.7		1.4	“	“
AMMONIA AS N (NOV 1 – APR 30)	MG/L	2/3/5	7.5		2.9	“	“
ESCHERICHIA COLI	**	1/2	Please see Escherichia Coli (E. coli) in the Derivation and Discussion Section below.				
FECAL COLIFORM	**	1/2	1000		400	“	“
MONITORING FREQUENCY	Please see Minimum Sampling and Reporting Frequency Requirements in the Derivation and Discussion Section below.						

* - Monitoring requirement only

** - # of colonies/100mL; the Monthly Average for Fecal Coliform is a geometric mean.

*** - Parameter not previously established in previous state operating permit.

N/A – Not applicable

Basis for Limitations Codes:

- | | |
|--|------------------------------------|
| 1. State or Federal Regulation/Law | 7. Antidegradation Policy |
| 2. Water Quality Standard (includes RPA) | 8. Water Quality Model |
| 3. Water Quality Based Effluent Limits | 9. Best Professional Judgment |
| 4. Lagoon Policy | 10. TMDL or Permit in lieu of TMDL |
| 5. Ammonia Policy | 11. WET Test Policy |
| 6. Dissolved Oxygen Policy | |

OUTFALL #001 – DERIVATION AND DISCUSSION OF LIMITS:

- **Flow.** In accordance with [40 CFR Part 122.44(i)(1)(ii)] the volume of effluent discharged from each outfall is needed to assure compliance with permitted effluent limitations. If the permittee is unable to obtain effluent flow, then it is the responsibility of the permittee to inform the department, which may require the submittal of an operating permit modification.
- **Biochemical Oxygen Demand (BOD₅).** 45 mg/L as a Weekly Average and 30 mg/L as a Monthly Average. Please see the **APPLICABLE DESIGNATION OF WATERS OF THE STATE** sub-section of the **Receiving Stream Information.**
- **Total Suspended Solids (TSS).** 45 mg/L as a Weekly Average and 30 mg/L as a Monthly Average. Please see the **APPLICABLE DESIGNATION OF WATERS OF THE STATE** sub-section of the **Receiving Stream Information.**
- **pH.** Effluent limitations have been retained from previous state operating permit, please see the **APPLICABLE DESIGNATION OF WATERS OF THE STATE** sub-section of the **Receiving Stream Information.**
- **Temperature.** Monitoring requirement due to the toxicity of Ammonia varies by temperature.

- **Total Ammonia Nitrogen.** Early Life Stages Present Total Ammonia Nitrogen criteria apply [10 CSR 20-7.031(4)(B)7.C. & Table B3]. No mixing considerations allowed; therefore, WLA = appropriate criterion.

Season	Temp (°C)	pH (SU)	Total Ammonia Nitrogen CCC (mg/L)	Total Ammonia Nitrogen CMC (mg/L)
Summer	26	7.8	1.5	12.1
Winter	6	7.8	3.1	12.1

Summer: May 1 – October 31, Winter: November 1 – April 30

Summer

Chronic WLA: $C_e = ((0.027 + 0.0)1.5 - (0.0 * 0.01))/0.027$
 $C_e = 1.5 \text{ mg/L}$

Acute WLA: $C_e = ((0.027 + 0.0)12.1 - (0.0 * 0.01))/0.027$
 $C_e = 12.1 \text{ mg/L}$

$LTA_c = 1.5 \text{ mg/L (0.780)} = \mathbf{1.2 \text{ mg/L}}$ [CV = 0.6, 99th Percentile, 30 day avg.]
 $LTA_a = 12.1 \text{ mg/L (0.321)} = 3.9 \text{ mg/L}$ [CV = 0.6, 99th Percentile]

Use most protective number of LTA_c or LTA_a .

MDL = 1.2 mg/L (3.11) = 3.7 mg/L [CV = 0.6, 99th Percentile]
 AML = 1.2 mg/L (1.19) = 1.4 mg/L [CV = 0.6, 95th Percentile, n =30]

Winter

Chronic WLA: $C_e = ((0.027 + 0.0)3.1 - (0.0 * 0.01))/0.027$
 $C_e = 3.1 \text{ mg/L}$

Acute WLA: $C_e = ((0.027 + 0.0)12.1 - (0.0 * 0.01))/0.027$
 $C_e = 12.1 \text{ mg/L}$

$LTA_c = 3.1 \text{ mg/L (0.780)} = \mathbf{2.4 \text{ mg/L}}$ [CV = 0.6, 99th Percentile, 30 day avg.]
 $LTA_a = 12.1 \text{ mg/L (0.321)} = 3.9 \text{ mg/L}$ [CV = 0.6, 99th Percentile]

Use most protective number of LTA_c or LTA_a .

MDL = 2.4 mg/L (3.11) = 7.5 mg/L [CV = 0.6, 99th Percentile]
 AML = 2.4 mg/L (1.19) = 2.9 mg/L [CV = 0.6, 95th Percentile, n =30]

Season	Maximum Daily Limit (mg/l)	Average Monthly Limit (mg/l)
Summer	3.7	1.4
Winter	7.5	2.9

- ***Escherichia coli (E. coli)*.** This facility may be required to have *E. coli* effluent limitations when Missouri adopts the implementation of the *E. coli* standards, as per [10 CSR 20-7.031(4)(C)].
- **Fecal Coliform.** Discharge shall not contain more than a monthly geometric mean of 400 colonies/100 mL and a daily maximum of 1000 colonies/100 mL during the recreational season (April 1 – October 31), please see the **APPLICABLE DESIGNATION OF WATERS OF THE STATE** sub-section of the **Receiving Stream Information**. Future renewals of the facility operating permit will contain effluent limitations for *E. coli*, which will replace fecal coliform as the applicable bacteria criteria in Missouri’s water quality standards.

Minimum Sampling and Reporting Frequency Requirements.

PARAMETER	SAMPLING FREQUENCY	REPORTING FREQUENCY
FLOW	ONCE/MONTH	ONCE/QUARTER
BOD ₅	ONCE/QUARTER	ONCE/QUARTER
TSS	ONCE/QUARTER	ONCE/QUARTER
PH	ONCE/QUARTER	ONCE/QUARTER
TEMPERATURE	ONCE/QUARTER	ONCE/QUARTER
AMMONIA AS N (MAY 1 – OCT 31)	ONCE/QUARTER	ONCE/QUARTER
AMMONIA AS N (NOV 1 – APR 30)	ONCE/QUARTER	ONCE/QUARTER
FECAL COLIFORM	ONCE/QUARTER	ONCE/QUARTER

Part VI – Administrative Requirements

On the basis of preliminary staff review and the application of applicable standards and regulations, the Department, as administrative agent for the Missouri Clean Water Commission, proposes to issue a permit(s) subject to certain effluent limitations, schedules, and special conditions contained herein and within the operating permit. The proposed determinations are tentative pending public comment.

PUBLIC NOTICE:

As per the Missouri Clean Water Law, the Missouri Clean Water Commission, and the federal Clean Water Act, persons wishing to comment on Missouri State Operating Permits are directed to do so by a department approved Public Notice coversheet. This Public Notice coversheet is attached to a Missouri State Operating Permit during the Public Notice period.

The Public Notice period for this operating permit is tentatively schedule to begin on 2-6-2009.

DATE OF FACT SHEET: 1-27-2009

Updates for issuance on 12-9-2011: Minor modifications have been made to the Public Notice in the Final Permit. The name of the facility has been changed to Holtgrewe Farms. The owner and continuing authority has been changed to a PSC regulated Sewer Company. Location of outfall is now expressed in UTM Coordinates. Monitoring for temperature has been removed in accordance with current Department policy. Monitoring and limits for Fecal Coliform have been replaced with monitoring and limits for E. Coli. Although PSC regulated facilities are required to have certified operators, this facility is exempt since the design population equivalent is less than 200. Holtgrewe Farms Sewer Company, LLC received a Certificate of Convenience and Necessity from the Missouri Public Service Commission on September 28, 2010; with an effective date of October 10, 2010.

COMPLETED BY:

ANDREW APPELBAUM, P.E.
ST. LOUIS REGIONAL OFFICE
(314) 416-2960
andy.appelbaum@dnr.mo.gov