



Jeremiah W. (Jay) Nixon, Governor • Sara Parker Pauley, Director

DEPARTMENT OF NATURAL RESOURCES

www.dnr.mo.gov

April 25, 2014

Mr. Thomas Oppenheim, Vice President
Cooper Land Development
903 N 47th Street
Rogers, AR 72756

RE: AP13392 Edgewater 2nd Plat – Little Blue Valley Sewer District (LBVSD), Atherton Plant, MO-0101087, Construction Permit No. CPSE00622

Dear Mr. Oppenheim:

The Missouri Department of Natural Resources' Water Protection Program has reviewed and approved the plans and specifications submitted by Warger Associates, LLC for the Cooper Land Development. Please find enclosed Construction Permit No. CPSE00622 and one set of approved plans and specifications.

This permit will terminate 12 months from the date of issuance. In accordance with 10 CSR 20-6.010(4)(G), the Department may grant an extension only one time. If you believe that an extension is necessary, you must submit a request and a justification in writing for the extension at least 30 days prior to the permit expiration date.

Nothing in this permit removes any obligations to comply with county or other local ordinances or restrictions.

If you were adversely affected by this decision, you may appeal to have the matter heard by the Administrative Hearing Commission. To appeal, you must file a petition with the Administrative Hearing Commission within 30 days after the date this decision was mailed or the date it was delivered, whichever date was earlier. If any such petition is sent by registered mail or certified mail, it will be deemed filed on the date it is mailed. If it is sent by any method other than registered mail or certified mail, it will be deemed filed on the date it is received by the Administrative Hearing Commission.


Mr. Thomas Oppenheim, Vice President
April 25, 2014
Page 2

If you have any questions concerning this matter, please contact Mrs. Emily Carpenter, of the Water Protection Program, at 573-751-6569 or Missouri Department of Natural Resources, Water Protection Program, P.O. Box 176, Jefferson City, MO 65102-0176.

Thank you for your efforts to help ensure clean water in Missouri.

Sincerely,

WATER PROTECTION PROGRAM



Byron F. Shaw, Jr., P.E., SRF Engineering Unit Chief
Financial Assistance Center

BFS:ecc

Enclosures

c: Mr. Steve Warger, P.E., Warger Associates, LLC
Mr. Michael Krass, P.E., Director of Public Works, City of Raymore
Mr. David Lilly, P.E., District Engineer, Little Blue Valley Sewer District
Kansas City Regional Office
Mrs. Emily Carpenter, Water Protection Program, Financial Assistance Center

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES

MISSOURI CLEAN WATER COMMISSION



CONSTRUCTION PERMIT

The Missouri Department of Natural Resources hereby issues a permit to:

Cooper Land Development
903 N. 47th Street
Rogers, AR 72756

for the construction of (described facilities):

See attached.

Permit Conditions:

See attached.

Construction of such proposed facilities shall be in accordance with the provisions of the Missouri Clean Water Law, Chapter 644, RSMo, and regulation promulgated thereunder, or this permit may be revoked by the Department of Natural Resources (Department).

As the Department does not examine structural features of design or the efficiency of mechanical equipment, the issuance of this permit does not include approval of these features.

A representative of the Department may inspect the work covered by this permit during construction. Issuance of a permit to operate by the Department will be contingent on the work substantially adhering to the approved plans and specifications.

This permit applies only to the construction of water pollution control components; it does not apply to other environmentally regulated areas.

April 25, 2014
Effective Date

April 24, 2015
Expiration Date

Sara Parker Pauley
Sara Parker Pauley, Director, Department of Natural Resources

John Madros
Director of Staff, Clean Water Commission or Designee

CONSTRUCTION PERMIT

COLLECTION SYSTEM:

The proposed wastewater collection system will consist of a low pressure sewer system, with grinder pumps at each connection, which will carry raw wastewater to the receiving wastewater treatment facility.

Construction and installation of approximately 437 lineal feet (lf) of eight-inch (8") polyvinyl chloride (PVC) Standard Dimension Ratio (SDR)-35 gravity sewer lines with approximately four (4) manholes, 320 lf of two-inch (2") SDR-21 PVC and 403 lf of four-inch (4") SDR-21 PVC force main with cleanouts and air release valves, ten (10) grinder pumps with each operating at 40 gallons per minute (gpm) at 55 feet of total dynamic head (TDH) and all the necessary appurtenances to make a complete and usable wastewater collection system to serve an estimated population equivalent of 78 and an estimated design average flow of 7,770 gallons per day. The project will also include general site work appropriate to the scope and purpose of the project.

These wastewater facilities will be in the vicinity of intersection of Creekmoor Pond Drive and Kingsland Circle, in the city of Raymore, MO, Cass County, and discharge to an existing sewer system and be treated at the Little Blue Valley Sewer District, Atherton Plant, Missouri State Operating Permit No. MO-0101087.

PERMIT CONDITIONS:

1. All construction shall be in accordance with the plans and specifications submitted by Warger Associates, LLC on June 14, 2013 and approved by the Department on April 25, 2014.
2. The Department must be contacted in writing prior to making any changes to the approved plans and specifications that would directly or indirectly have an impact on the capacity, flow, system layout, or reliability of the proposed wastewater treatment facilities or any design parameter that is addressed by 10 CSR 20-8, in accordance with 10 CSR 20-8.110(8).
3. State and Federal Law does not permit bypassing of raw wastewater, therefore steps must be taken to ensure that raw wastewater does not discharge during construction. If a sanitary sewer overflow or bypass occurs, report the appropriate information to the Department's Kansas City Regional Office per 10 CSR 20-7.015(9)(E)2.
4. This Construction Permit is invalid for projects required to comply with the requirements contained in 10 CSR 20-4, "Grants and Loans".

5. Protection of drinking water supplies shall be in accordance with 10 CSR 20-8.120(10). “There shall be no physical connections between a public or private potable water supply system and a sewer, or appurtenance thereto which would permit the passage of any wastewater or polluted water into the potable supply. No water pipe shall pass through or come in contact with any part of a sewer manhole.”
- A. Sewers in relation to water works structures shall meet the requirements of 10 CSR 23-3.010 with respect to minimum distances from public water supply wells or other water supply sources and structures.
 - B. Sewer mains shall be laid at least ten feet (10’) horizontally from any existing or proposed water main. The distances shall be measured edge-to-edge. In cases where it is not practical to maintain a ten foot (10’) separation, the Department may allow a deviation on a case-by-case basis, if supported by data from the design engineer. Such a deviation may allow installation of the sewer closer to a water main, provided that the water main is in a separate trench or on an undisturbed earth shelf located on either side of the sewer and at an elevation so the bottom of the water main is at least 18 inches above the top of the sewer. If it is impossible to obtain proper horizontal and vertical separation as described above for sewers, the sewer must be constructed of slip-on or mechanical joint pipe or continuously encased and be pressure tested to 150 pounds per square inch to assure water tightness.
 - C. Manholes should be located at least ten feet (10’) horizontally from any existing or proposed water main.
 - D. Sewers crossing water mains shall be laid to provide a minimum vertical distance of 18 inches between the outside of the water main and the outside of the sewer. This shall be the case where the water main is either above or below the sewer. The crossing shall be arranged so that the sewer joints will be equidistant and as far as possible from the water main joints. Where a water main crosses under a sewer, adequate structural support shall be provided for the sewer to maintain line and grade. When it is impossible to obtain proper vertical separation as stipulated above, one (1) of the following methods must be specified:
 - 1) The sewer shall be designed and constructed equal to the water pipe and shall be pressure tested to assure water tightness prior to backfilling; or
 - 2) Either the water main or sewer line may be continuously encased or enclosed in a watertight carrier pipe which extends ten feet (10’) on both sides of the crossing, measured perpendicular to the water main. The carrier pipe shall be of materials approved by the Department for use in water main construction.


6. In addition to the requirements for a construction permit, 10 CSR 20-6.200 requires land disturbance activities of one (1) acre or more to obtain a Missouri State Operating Permit to discharge stormwater. The permit requires Best Management Practices sufficient to control runoff and sedimentation to protect waters of the state. Land disturbance permits may only be obtained by means of the Department's ePermitting system available online at www.dnr.mo.gov/env/wpp/epermit/help.htm.

See www.dnr.mo.gov/env/wpp/stormwater/sw-land-disturb-permits.htm for more information.

7. A United States (U.S.) Army Corps of Engineers (COE) permit (404) and a Water Quality Certification (401) issued by the Department or permit waiver may be required for the activities described in this permit. This permit is not valid until these requirements are satisfied. If construction activity will disturb any land below the ordinary high water mark of Jurisdictional Waters of the U.S. then a 404/401 will be required. Since the COE makes determinations on what is jurisdictional, you must contact the COE to determine permitting requirements. You may call the Department's Water Protection Program at 573-751-1300 for more information.

See www.dnr.mo.gov/env/wpp/401/ for more information.

8. In accordance with 10 CSR 20-6.010(6)(B), submit the enclosed form Application for Letter of Authorization – Sewer Extension to the Department following completion of construction. Submit an electronic copy of the as builts with this form.
9. Upon completion of construction, the city of Raymore will become the continuing authority for operation, maintenance, and modernization of these facilities.



MISSOURI DEPARTMENT OF NATURAL RESOURCES
WATER PROTECTION PROGRAM

JUN 14 2013

**APPLICATION FOR CONSTRUCTION PERMIT -
SEWER EXTENSION**

FOR DEPARTMENT USE ONLY	
PERMIT NUMBER	
FEE RECEIVED	DATE RECEIVED

WATER PROTECTION PROGRAM

NOTE ► PLEASE READ THE ACCOMPANYING INSTRUCTIONS BEFORE COMPLETING THIS FORM

1.0 APPLICATION INFORMATION

- 1.1 Is this a Federal/State funded project? YES NO Funding Agency: _____ Project #: _____
- 1.2 Has the Department of Natural Resources approved the proposed project's engineering report?
 YES Date of Approval: _____ NO N/A
- 1.3 Is a copy of the appropriate plans and specifications included with this application? YES NO
- 1.4 Is a summary of design included with this application? YES NO
- 1.5 Is the appropriate fee included with this application? (See instructions for appropriate fee) YES NO

2.0 PROJECT OWNER

NAME Cooper Land Development		TELEPHONE NUMBER WITH AREA CODE (479) 246-6500	E-MAIL ADDRESS	
ADDRESS 903 N 47th Street	CITY Rogers	STATE Ar.	ZIP CODE 72756	COUNTY

3.0 CONTINUING AUTHORITY: Permanent organization that will serve as the continuing authority for the operation, maintenance and modernization of the wastewater collection system.

NAME City of Raymore Missouri		TELEPHONE NUMBER WITH AREA CODE (816) 331-1852	E-MAIL ADDRESS	
ADDRESS 100 Municipal Court	CITY Raymore	STATE mo	ZIP CODE 64083	COUNTY Cass

3.1 A letter from the continuing authority, if different than the owner, is included with this application. YES NO

3.2 Will user charge a rate increase as a result of the proposed sewer extension? YES NO

4.0 CONSULTANT

ENGINEER NAME Warger Associates		TELEPHONE NUMBER WITH AREA CODE (816) 769-6132	E-MAIL ADDRESS steve@wargerassociates.com	
ADDRESS 1617 Swift	CITY North Kansas City	STATE mo	ZIP CODE 64116	COUNTY Clay

5.0 PROJECT INFORMATION

5.1 NAME OF PROJECT
Edgewater 2nd plat

ADDRESS Creekmoor Pond Drive and Kingsland Circle	CITY Raymore	STATE mo	ZIP CODE 64083	COUNTY Cass
--	-----------------	-------------	-------------------	----------------

5.2 Legal Description: NW ¼, NW ¼, Sw ¼, Sec. 4, T 46, R 32

5.3 PROJECT DESCRIPTION
440' of 8 inch PVC line and services and 723' of 4" force main connecting to the existing system

5.4 DESIGN INFORMATION

- A. Population or number of lots to be served by this extension: 21 lots
- B. Estimated flow to be contributed by this extension: Design Average Flow: 7700 gpd Design Peak Hourly Flow: 7700 gph
- C. Industrial Wastes: Type: _____ Flow: _____ gpd
- D. Receiving Sewer: Size: 8" inches Capacity: 780 gpm

6.0 RECEIVING WASTEWATER TREATMENT FACILITY

NAME Little Blue Valley		TELEPHONE NUMBER WITH AREA CODE	E-MAIL ADDRESS	
MISSOURI STATE OPERATING PERMIT #		REMAINING CAPACITY (GPD)		

6.1 Has the receiving treatment facility agreed to accept the additional wastewater flow? YES NO

6.2 A letter from the receiving wastewater treatment facility, if different than the continuing authority, is included with this application.
 YES NO

7.0 PROJECT OWNER: I hereby certify that I am familiar with the information contained in this application and to the best of my knowledge and belief such information is true, complete, and accurate, and if granted this permit, I agree to abide by the Missouri Clean Water Law and all rules, regulations, orders, and decisions, subject to any legitimate appeal available to applicant under Missouri Clean Water Law.

PROJECT OWNER SIGNATURE

Thomas C. Oppenheim

PRINTED NAME

THOMAS C. OPPENHEIM

DATE

4-2-13

TITLE OR CORPORATE POSITION

V.P., ENGINEERING/CONSTR.

TELEPHONE NUMBER WITH AREA CODE

479-246-6804

E-MAIL ADDRESS

toppenheim@ceizs.com

Mail completed copy to:

MISSOURI DEPARTMENT OF NATURAL RESOURCES
WATER PROTECTION PROGRAM
P.O. BOX 176
JEFFERSON CITY, MO 65102-0176