



Jeremiah W. (Jay) Nixon, Governor • Sara Parker Pauley, Director

DEPARTMENT OF NATURAL RESOURCES

www.dnr.mo.gov

January 5, 2015

Mr. Bill Beck, Public Works Director
City of Sedalia
Municipal Building
200 S. Osage Drive
Sedalia, MO 65301

RE: AP18362 City of Sedalia, MO – Peak Flow Improvements, Sedalia Southeast WWTP,
MO-0101567, Construction Permit No. CPSE00908

Dear Mr. Beck:

The Department of Natural Resources' Water Protection Program has reviewed and approved the plans and specifications submitted by Olsson Associates for the city of Sedalia, MO. Please find enclosed Construction Permit No. CPSE00908.

This permit will terminate 12 months from the date of issuance. In accordance with 10 CSR 20-6.010(4)(G), the Department may grant an extension only one time. If you believe that an extension is necessary, you must submit a request and a justification in writing for the extension at least 30 days prior to the permit expiration date.

Nothing in this permit removes any obligations to comply with county or other local ordinances or restrictions.

If you were adversely affected by this decision, you may appeal to have the matter heard by the Administrative Hearing Commission. To appeal, you must file a petition with the Administrative Hearing Commission within 30 days after the date this decision was mailed or the date it was delivered, whichever date was earlier. If any such petition is sent by registered mail or certified mail, it will be deemed filed on the date it is mailed. If it is sent by any method other than registered mail or certified mail, it will be deemed filed on the date it is received by the Administrative Hearing Commission.

Mr. Bill Beck, Public Works Director

January 5, 2015


Page 2

If you have any questions concerning this matter, please contact Mr. David C. Uhlig, P.E. of the Water Protection Program, at 573-751-1302 or Missouri Department of Natural Resources, Water Protection Program, P.O. Box 176, Jefferson City, MO 65102-0176.

Thank you for your efforts to help ensure clean water in Missouri.

Sincerely,

WATER PROTECTION PROGRAM



Byron F. Shaw, Jr., P.E., SRF Engineering Unit Chief
Financial Assistance Center

BFS:duc

Enclosures

- c: Mr. Kevin Waldron, P.E., Olsson Associates
- Mr. Mike Milius, P.E., Olsson Associates
- Mr. Paul Dickerson, Water Protection Program, Compliance and Enforcement Section
Kansas City Regional Office
- Mr. David C. Uhlig, P.E., Water Protection Program, Financial Assistance Center

The Year of Water: Promoting, Protecting and Enjoying our Natural Resources.

Learn more at dnr.mo.gov.

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES

MISSOURI CLEAN WATER COMMISSION



CONSTRUCTION PERMIT

The Missouri Department of Natural Resources hereby issues a permit to:

City of Sedalia
Municipal Building
200 S. Osage Drive
Sedalia, MO 65301

for the construction of (described facilities):

See attached.

Permit Conditions:

See attached.

Construction of such proposed facilities shall be in accordance with the provisions of the Missouri Clean Water Law, Chapter 644, RSMo, and regulation promulgated thereunder, or this permit may be revoked by the Department of Natural Resources.


As the Department does not examine structural features of design or the efficiency of mechanical equipment, the issuance of this permit does not include approval of these features.

A representative of the Department may inspect the work covered by this permit during construction. Issuance of a permit to operate by the Department will be contingent on the work substantially adhering to the approved plans and specifications.

This permit applies only to the construction of water pollution control components; it does not apply to other environmentally regulated areas.

January 5, 2015
Effective Date

January 4, 2016
Expiration Date


Sara Parker Pauley, Director, Department of Natural Resources


Director, Water Protection Program

CONSTRUCTION PERMIT

COLLECTION SYSTEM:

The proposed wastewater collection system will consist of a conventional gravity sewer system with lift stations and force mains, to transport raw wastewater to and from an existing earthen basin at an existing lift station.

The construction and installation will consist of approximately 73 linear feet (lf) of eight-inch polyvinyl chloride (PVC) Standard Dimension Ratio (SDR)-35 or 26 gravity sewer with one manhole, 113 lf of eight-inch AWWA C900 force mains, one duplex lift station with each pump capable of operating at 475 gallons per minute (gpm) at 25 feet of total dynamic head (TDH) and all necessary appurtenances to make a complete and usable wastewater collection system. The project will also include general site work appropriate to the scope and purpose of the project.

These wastewater facilities will be at the Southeast WWTP in the city of Sedalia, MO, Pettis County and discharge to an existing sewer system to be treated at the Sedalia Southeast Wastewater Treatment Facility, Missouri State Operating Permit No. MO-0101567.

PERMIT CONDITIONS:

1. All construction shall be in accordance with the plans and specifications submitted by Olsson Associates as follows:
 - Specifications received on December 18, 2014 titled, "EQ-1 Improvements Sedalia, Missouri 2014", signed and sealed by Mr. Michael D. Milius, P.E. on December 17, 2014.
 - Section 115161(A) of the specifications received on December 18, 2014, titled, "North Equalization Basin Lift Station, Southwest Equalization Basin Lift Station and Southeast Equalization Basin (EQ-2) Lift Station Equipment Pre-Selection Sedalia, Missouri-2014" and signed and sealed by Mr. Michael D. Milius, P.E. on November 26, 2014 and Addendum No. 1. signed and sealed by Mr. Michael D. Milius, P.E. on December 10, 2014.
 - Plans received on December 18, 2014 and signed and sealed by Mr. Michael D. Milius, P.E. on December 17, 2014.
 - And approved by the Department on January 5, 2015.

2. The Department must be contacted in writing prior to making any changes to the approved plans and specifications that would directly or indirectly have an impact on the capacity, flow, system layout, or reliability of the proposed wastewater treatment facilities or any design parameter that is addressed by 10 CSR 20-8, in accordance with 10 CSR 20-8.110(8).
3. State and Federal Law does not permit bypassing of raw wastewater, therefore steps must be taken to ensure that raw wastewater does not discharge during construction. If a sanitary sewer overflow or bypass occurs, report the appropriate information to the Department's Kansas City Regional Office per 10 CSR 20-7.015(9)(E)2.
4. This Construction Permit is invalid for projects required to comply with the requirements contained in 10 CSR 20-4, "Grants and Loans".
5. Protection of drinking water supplies shall be in accordance with 10 CSR 20-8.120(10).

"There shall be no physical connections between a public or private potable water supply system and a sewer, or appurtenance thereto which would permit the passage of any wastewater or polluted water into the potable supply. No water pipe shall pass through or come in contact with any part of a sewer manhole."

 - A. Sewers in relation to water works structures shall meet the requirements of 10 CSR 23-3.010 with respect to minimum distances from public water supply wells or other water supply sources and structures.
 - B. Sewer mains shall be laid at least ten feet horizontally from any existing or proposed water main. The distances shall be measured edge-to-edge. In cases where it is not practical to maintain a ten foot separation, the Department may allow a deviation on a case-by-case basis, if supported by data from the design engineer. Such a deviation may allow installation of the sewer closer to a water main, provided that the water main is in a separate trench or on an undisturbed earth shelf located on either side of the sewer and at an elevation so the bottom of the water main is at least 18 inches above the top of the sewer. If it is impossible to obtain proper horizontal and vertical separation as described above for sewers, the sewer must be constructed of slip-on or mechanical joint pipe or continuously encased and be pressure tested to 150 pounds per square inch to assure water tightness.
 - C. Manholes should be located at least ten feet horizontally from any existing or proposed water main.
 - D. Sewers crossing water mains shall be laid to provide a minimum vertical distance of 18 inches between the outside of the water main and the outside of the sewer. This shall be the case where the water main is either above or below the sewer. The crossing shall be arranged so that the sewer joints will be equidistant and as far as possible from the water main joints. Where a water main crosses under a sewer, adequate structural support shall be provided for the sewer to maintain line

and grade. When it is impossible to obtain proper vertical separation as stipulated above, one of the following methods must be specified:

- 1) The sewer shall be designed and constructed equal to the water pipe and shall be pressure tested to assure water tightness prior to backfilling; or
- 2) Either the water main or sewer line may be continuously encased or enclosed in a watertight carrier pipe which extends ten feet on both sides of the crossing, measured perpendicular to the water main. The carrier pipe shall be of materials approved by the Department for use in water main construction.

6. In addition to the requirements for a construction permit, 10 CSR 20-6.200 requires land disturbance activities of one acre or more to obtain a Missouri State Operating Permit to discharge stormwater. The permit requires Best Management Practices sufficient to control runoff and sedimentation to protect waters of the state. Land disturbance permits may only be obtained by means of the Department's ePermitting system available online at www.dnr.mo.gov/env/wpp/epermit/help.htm.

See www.dnr.mo.gov/env/wpp/stormwater/sw-land-disturb-permits.htm for more information.

7. A United States (U.S.) Army Corps of Engineers (COE) permit (404) and a Water Quality Certification (401) issued by the Department or permit waiver may be required for the activities described in this permit. This permit is not valid until these requirements are satisfied. If construction activity will disturb any land below the ordinary high water mark of Jurisdictional Waters of the U.S. then a 404/401 will be required. Since the COE makes determinations on what is jurisdictional, you must contact the COE to determine permitting requirements. You may call the Department's Water Protection Program at (573) 751-1300 for more information.

See www.dnr.mo.gov/env/wpp/401/ for more information.

8. In accordance with 10 CSR 20-6.010(6)(B), submit the enclosed form Application for Letter of Authorization – Sewer Extension to the Department following completion of construction. Submit an electronic copy of the as built with this form.
9. Upon completion of construction, the city of Sedalia, MO will be the continuing authority for operation, maintenance, and modernization of these facilities.

RECEIVED



MISSOURI DEPARTMENT OF NATURAL RESOURCES
 WATER PROTECTION PROGRAM
APPLICATION FOR CONSTRUCTION PERMIT 5.2014
SEWER EXTENSION

FOR DEPARTMENT USE ONLY	
APP NO.	CP NO.
FEE RECEIVED \$300.00	CHECK NO. 0923599
DATE RECEIVED 4/25/14	SB

WATER PROTECTION PROGRAM

NOTE ► PLEASE READ THE ACCOMPANYING INSTRUCTIONS BEFORE COMPLETING THIS FORM

1.0 APPLICATION INFORMATION (Note – If any of the questions in this section are answered NO, this application may be considered incomplete and returned.)

- 1.1 Is this a Federal/State funded project? YES N/A Funding Agency: _____ Project #: _____
- 1.2 Has the Department of Natural Resources approved the proposed project's engineering report*?
 YES Date of Approval: _____ NO N/A
- 1.3 Is a copy of the appropriate plans* and specifications* included with this application? YES NO
- 1.4 Is a summary of design* included with this application? YES NO
- 1.5 Is the appropriate fee included with this application? (See instructions for appropriate fee.) YES NO

* Must be affixed with a Missouri registered professional engineer's seal, signature and date.

2.0 PROJECT INFORMATION

2.1 NAME OF PROJECT

Peak Flow Management Improvements - Stormwater Equalization (EQ-1) - Southwest Lift Station Basin

ADDRESS	CITY	STATE	ZIP CODE	COUNTY
27882 HWY U	Sedalia	MO	65301	Pettis

2.2 Legal Description: ¼, SW ¼, SE ¼, Sec. 15, T 45N, R 21W

2.3 Project Components (check all that apply):

- Gravity sewers Pumping stations Force mains Alternative sewer system Other (Describe below.)

2.4 PROJECT DESCRIPTION

The improvements at the Southwest Lift Station consist of the construction of a new equalization basin dewatering lift station, force main from the lift station back to Southwest Lift Station, several improvements to structures on the plant site with associated concrete work, piping and valves, the replacement of the Southwest Lift Station pumps and an emergency generator complete with electrical/mechanical, SCADA system wiring and other items of miscellaneous work.

2.5 DESIGN INFORMATION

- A. Population or number of lots to be served by this extension: NA
- B. Estimated flow to be contributed by this extension: Design Average Flow: NA gpd Design Peak Hourly Flow: NA gph
- C. Industrial Wastes: Type: _____ Flow: _____ gpd
- D. Receiving Sewer: Size: _____ inches Capacity: _____ gpm

3.0 PROJECT OWNER

NAME	TELEPHONE NUMBER WITH AREA CODE	E-MAIL ADDRESS	
City of Sedalia	(660) 827-3000	bbeck@cityofsedalia.com	
ADDRESS	CITY	STATE	ZIP CODE
200 S. Osage Drive	Sedalia	MO	65301

4.0 CONTINUING AUTHORITY: Permanent organization that will serve as the continuing authority for the operation, maintenance and modernization of the wastewater collection system.

NAME	TELEPHONE NUMBER WITH AREA CODE	E-MAIL ADDRESS	
City of Sedalia	(660) 827-3000	bbeck@cityofsedalia.com	
ADDRESS	CITY	STATE	ZIP CODE
200 S. Osage Drive	Sedalia	MO	65301

4.1 A letter from the continuing authority, if different than the owner, is included with this application. YES NO N/A

5.0 ENGINEER

ENGINEER NAME / COMPANY NAME	TELEPHONE NUMBER WITH AREA CODE	E-MAIL ADDRESS	
Michael Milius / Olsson Associates	(816) 361-1177	mmilius@olssonassociates.com	
ADDRESS	CITY	STATE	ZIP CODE
1251 NW Briarcliff Pkwy, Suite 50	Kansas City	MO	64116

6.0 RECEIVING WASTEWATER TREATMENT FACILITY

NAME	TELEPHONE NUMBER WITH AREA CODE	E-MAIL ADDRESS
Sedalia Southeast WWTP	(660) 827-3000	bbeck@cityofsedalia.com

MISSOURI STATE OPERATING PERMIT # MO-0101567		REMAINING CAPACITY (GPD) NA	
6.1 Has the receiving treatment facility agreed to accept the additional wastewater flow? <input type="checkbox"/> YES <input type="checkbox"/> NO			
6.2 A letter from the receiving wastewater treatment facility, if different than the continuing authority, is included with this application. <input type="checkbox"/> YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> N/A			
7.0 PROJECT OWNER: I hereby certify that I am familiar with the information contained in this application and to the best of my knowledge and belief such information is true, complete, and accurate, and if granted this permit, I agree to abide by the Missouri Clean Water Law and all rules, regulations, orders, and decisions, subject to any legitimate appeal available to applicant under Missouri Clean Water Law.			
PROJECT OWNER SIGNATURE 			
PRINTED NAME Bill Beck		DATE 04/17/2014	
TITLE OR COPORATE POSITION Public Works Director		TELEPHONE NUMBER WITH AREA CODE (660) 827-3000	E-MAIL ADDRESS bbeck@cityofsedalia.com
Mail completed copy to:		MISSOURI DEPARTMENT OF NATURAL RESOURCES WATER PROTECTION PROGRAM P.O. BOX 176 JEFFERSON CITY, MO 65102-0176	