

TITLE 10 -- DEPARTMENT OF NATURAL RESOURCES
DIVISION 60 – SAFE DRINKING WATER COMMISSION
Chapter 7 – Reporting

PROPOSED AMENDMENT

10 CSR 60-7.010 Reporting Requirements. The commission is adding section (12).

Purpose: This amendment adopts the Revisions to the Total Coliform Rule (78 Federal Register 10269) reporting requirements. The Department of Natural Resources (DNR) must be notified of E. coli maximum contaminant level violations and coliform treatment technique violations by the end of the business day unless certain extenuating circumstances apply. A system must perform a required assessment within thirty days and must report corrective actions to DNR. Failure to comply with coliform monitoring must be reported within ten (10) days. Seasonal systems must certify compliance with start-up procedures.

(12) Reporting Requirements for the Revised Total Coliform Rule.

(A) *E. coli*.

1. A system must notify the department by the end of the day when the system learns of an *E. coli* MCL violation, unless the system learns of the violation after the department office is closed and the department does not have either an after-hours phone line or an alternative notification procedure, in which case the system must notify the department before the end of the next business day, and notify the public in accordance with 10 CSR 60-8.010.

2. A system must notify the department by the end of the day when the system is notified of an *E. coli*-positive routine sample, unless the system is notified of the result after the department office is closed and the department does not have either an after-hours phone line or an alternative notification procedure, in which case the system must notify the department before the end of the next business day.

(B) A system that has violated the treatment technique for coliforms in 10 CSR 60-4.022(9) must report the violation to the department no later than the end of the next business day after it learns of the violation, and notify the public in accordance with 10 CSR 60-8.010.

(C) A system required to conduct an assessment under the provisions of 10 CSR 60-4.022(9) must submit the assessment report to the department within thirty (30) days. The system must notify the department in accordance with 10 CSR 60-4.022(9) when each scheduled corrective action is completed for corrections not completed by the time of submission of the assessment form.

(D) A system that has failed to comply with a coliform monitoring requirement must report the monitoring violation to the department within ten (10) days after the system discovers the violation, and notify the public in accordance with 10 CSR 60-8.010.

(E) A seasonal system must certify to the department, prior to serving water to the public, that it has complied with the department-approved start-up procedure.

AUTHORITY: section 640.100, RSMo Supp. 2009. Original rule filed May 4, 1979, effective Sept. 14, 1979. Amended: Filed April 14, 1981, effective Oct. 11, 1981. Amended: Filed July 12, 1991, effective Feb. 6, 1992. Amended: Filed Dec. 15, 1999, effective Sept. 1, 2000. Amended: Filed March 17, 2003, effective Nov. 30, 2003. Amended: Filed Feb. 27, 2009, effective Oct. 30, 2009. Amended: Filed April 14, 2010, effective Dec. 30, 2010. Amended: Filed Aug. 17, 2015.*

**Original authority: 640.100, RSMo 1939, amended 1978, 1981, 1982, 1988, 1989, 1992, 1993, 1995, 1996, 1998, 1999, 2002, 2006.*

PUBLIC ENTITY COSTS: This amendment is anticipated to cost state agencies and political subdivisions less than \$500 in the aggregate.

PRIVATE ENTITY COSTS: This amendment is anticipated to cost private entities less than \$500 in the aggregate.

NOTICE OF PUBLIC HEARING AND NOTICE TO SUBMIT COMMENTS: The Department of Natural Resources Public Drinking Water Branch will hold a public hearing on this proposed rule at 10:00 a.m. on October 16, 2015 at the Lewis and Clark State Office Building, 1101 Riverside Drive, Jefferson City, Missouri. Any interested person may comment during the public hearing in support of or in opposition to the proposed rule. Written comments postmarked or received by October 19, 2015 will also be accepted. Written comments must be mailed to: Scott Weckenborg, MDNR Public Drinking Water Branch, P.O. Box 176, Jefferson City, MO 65102, or hand-delivered to the Lewis and Clark State Office Building, 1101 Riverside Drive, Jefferson City, Missouri.