



MISSOURI DEPARTMENT OF NATURAL RESOURCES  
 HAZARDOUS WASTE PROGRAM  
**SMALL QUANTITY GENERATOR – TANK ATTACHMENT**

S-T

|      |               |
|------|---------------|
| NAME | EPA ID NUMBER |
| CITY | MO ID NUMBER  |

**T. SMALL QUANTITY GENERATOR TANKS**

| TANK DESIGNATION | CONTENTS | CAPACITY | CONTAINMENT | AGE |
|------------------|----------|----------|-------------|-----|
| 1.               |          |          |             |     |
| 2.               |          |          |             |     |
| 3.               |          |          |             |     |
| 4.               |          |          |             |     |

| C                        | V                        | NA                       | COMMENTS   | 1 | 2 |
|--------------------------|--------------------------|--------------------------|--|---|---|
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Uncovered tanks have two feet freeboard or containment system unless special conditions met. – 10 CSR 25-5.262(1) incorporating 40 CFR 262.34(d)(3) referencing 40 CFR 265.201(b)(3).  | 1 |   |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Continuously fed tanks equipped with a feed cut-off system or a proper by-pass system. – 10 CSR 25-5.262(1) incorporating 40 CFR 262.34(d)(3) referencing 40 CFR 265.201(b)(4).  | 1 |   |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Waste or treatment method is compatible with tank. – 10 CSR 25-5.262(1) incorporating 40 CFR 262.34(d)(3) referencing 40 CFR 265.201(b)(2).  | 1 |   |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Incompatible wastes not placed in same tank unless compliant with 40 CFR 264.17(b). – 10 CSR 25-5.262(1) incorporating 40 CFR 262.34(d)(3) referencing 40 CFR 265.201(h).  | 1 |   |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Ignitable or reactive wastes in tanks rendered safe/protected from sources of ignition or reaction. – 10 CSR 25-5.262(1) incorporating 40 CFR 262.34(d)(3) referencing 40 CFR 265.201(g) and 265.17.                         | 1 |   |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Ignitable or reactive wastes in covered tanks treated/stored in accordance with NFPA's buffer zone requirements. – 10 CSR 25-5.262(1) incorporating 40 CFR 262.34(d)(3) referencing 40 CFR 265.201(e)(2).                    | 1 |   |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Volatiles with vapor pressure > 78mmHg @ 25 deg C not placed in open tanks. – 10 CSR 25-5.262(2)(C)2.F(I).   | 1 |   |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Wastes and residues removed from tank and equipment, and handled properly upon closure. – 10 CSR 25-5.262(1) incorporating 40 CFR 262.34(d)(3) referencing 40 CFR 265.201(f).  | 1 |   |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Date of accumulation clearly marked and visible for inspection on each tank. – 10 CSR 25-5.262(1) incorporating 40 CFR 262.34(d)(4) referencing 40 CFR 262.34(a)(2).   | 1 |   |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Tanks are clearly labeled or marked "Hazardous Waste." – 10 CSR 25-5.262(1) incorporating 40 CFR 262.34(d)(4) referencing 40 CFR 262.34(a)(3).   | 2 |   |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Inspection of tank waste feed cut off, bypass system, monitoring data and freeboard each operating day. – 10 CSR 25-5.262(1) incorporating 40 CFR 262.34(d)(3) referencing 40 CFR 265.201(c).                                | 2 |   |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Weekly inspection of tank confinement structure, construction materials and general area for erosion, leaks, corrosion or discharges. – 10 CSR 25-5.262(1) incorporating 40 CFR 262.34(d)(3) referencing 40 CFR 265.201(c)5. | 2 |   |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | Daily inspection of areas subject to spills where tanks are located, i.e., waste handling areas. – 10 CSR 25-5.262(2)(C)2.C(II) referencing 40 CFR 265.195.  | 2 |   |

**C** (Compliant) **V** (Violation) **NA** (Not Applicable)