

Final Stage 1 Pipeline Preliminary Engineering Report

**U.S. Army Corps of Engineers
Kansas City District**

Northwest Missouri Regional Water
Supply Study – Phase IV

May 12, 2011



**US Army Corps
of Engineers**
Kansas City District

BARTLETT & WEST

SERVICE. THE BARTLETT & WEST WAY.



Missouri Department of
Natural Resources

CDM

Northwest Missouri Regional Water Supply Transmission System Study Phase IV

Final
Stage 1 Pipeline Preliminary Engineering Report

May 2011

Prepared by:

CDM Federal Programs Corporation
9200 Ward Parkway, Suite 500
Kansas City, Missouri 64114

Bartlett & West, Inc.
250 NE Tudor Road
Lee's Summit, Missouri 64086-5696



Table of Contents

Executive Summary	ES-1
Section 1 Introduction	1-1
1.1 Stage 1 Pipeline Project Description	1-1
1.2 Project Background	1-2
Section 2 Future Water Need Projections	2-1
2.1 Description of Need	2-1
2.2 Future Water Need Projections	2-1
2.2.1 Calculation Methodology	2-2
2.2.2 Stage 1 Pipeline Water Demands	2-3
Section 3 Conceptual Design Criteria	3-1
3.1 Model Criteria and Pipeline Sizing	3-1
3.2 Pumping Facilities	3-2
3.3 Water Storage Facilities	3-2
Section 4 Stage 1 Pipeline Alternatives	4-1
4.1 Atchison County Wholesale Water Commission	4-1
4.2 Missouri-American Water Company	4-2
4.3 City of Savannah	4-2
Section 5 Alternative Comparison and Recommended Source	5-1
5.1 Opinion of Probable Cost	5-1
5.2 Water Rate and Capacity Comparison	5-2
5.3 Recommended Source Alternative	5-2
Section 6 Conceptual Plan Preliminary Cost Opinion	6-1
6.1 Opinion of Probable Cost	6-1
6.2 Replacement Cost	6-1
6.3 Annual Operation and Maintenance Cost	6-2
6.4 Water Purchase Cost	6-2
Section 7 Summary of Wholesale Rate Requirements	7-1
Section 8 Conclusions	8-1
8.1 Recommended "Next Steps"	8-1

Appendix A Reference Calculations A-1
Appendix B Modeling Results B-1
Appendix C Supplier Information..... C-1
Appendix D Cost Opinions D-1

Tables

1-1 October 2010 GNWWC Membership 1-2
2-1 Summary of Commission Demands..... 2-2
2-2 Summary of Stage 1 Water System Demands..... 2-3
3-1 Model Development Criteria 3-1
4-1 Missouri-American Rate Schedule 4-2
5-1 OPC for Supply Alternatives..... 5-1
5-2 Water Rate and Capacity Data 5-2
5-3 Estimate of Annual Costs 5-2
6-1 Missouri-American Cost Alternative 6-1
7-1 Summary of Wholesale Rate Requirements 7-1

Figures

1-1 Stage 1 Pipeline Alignment
3-1 Overall System
4-1 ACWWC Option
4-2 Missouri-American Option
4-3 Savannah Option
8-1 Project Schedule

Acronyms/Abbreviations

ACWWC	Atchison County Wholesale Water Commission
CDM	CDM Federal Programs Corporation
Commission	Great Northwest Wholesale Water Commission
GPCD	gallons per capita per day
HP	horsepower
kgal	1,000 gallons
kwh	kilowatt-hours
M	million
MDNR	Missouri Department of Natural Resources
MGD	million gallons per day
O&M	operations and maintenance
OPC	opinion of probable cost
PAS	Planning Assistance to States
PER	Preliminary Engineering Report
psi	pounds per square inch
PWSD	Public Water Supply District
USACE	U.S. Army Corps of Engineers
WTP	water treatment plant

This page left blank intentionally

Executive Summary

Under the July 15, 2010 Planning Assistance to States cost share agreement between the U.S. Army Corps of Engineers and the Missouri Department of Natural Resources Water Resources Center, CDM Federal Programs Corporation was requested to provide engineering and technical support services to the Kansas City District for Phase IV of the Northwest Missouri Regional Water Supply Study. The objective of Phase IV is to provide a Preliminary Engineering Report (PER) for the Stage 1 Pipeline and to provide an update to the 2009 *Phase II Feasibility Study* tailored for the current Great Northwest Wholesale Water Commission (Commission) membership. This report serves as the PER for the Stage 1 Pipeline. The Feasibility Study Update is a separate document, but relies heavily on the conclusions summarized herein.

The Stage 1 Pipeline PER was been completed as a follow-up to the Phase 1, 2 and 3 reports prepared for the Commission. In this study, three water suppliers, Missouri-American, the City of Savannah, and the Atchison Wholesale Water Commission, were compared to determine the most cost effective supplier to provide water to 12 of the current Commission members. These 12 members are Andrew County PWSD #1, Andrew County PWSD #4, City of Albany, City of Barnard, City of Bolckow, City of King City, City of Stanberry, Davies County PWSD #1, DeKalb County PWSD #1, Gentry County #1, Gentry County #2, and Nodaway County #1.

The pipeline lengths and diameters vary between the three options as summarized below in Table ES-1 and ES-2.

**Table ES-1
Alternative Comparison**

Criteria	ACWWC	Savannah	Missouri-American
Pipeline Length	127 miles	108 miles	113 miles
No. of Storage Tanks	2	2	3
Add'l Construction Requirements	None	Ammonia Facilities	Clearwell
OPC	\$88,500,000	\$43,400,000	\$52,100,000
Water Supply Capacity	6 MGD	Up to 3.9 MGD	Existing 8.0 MGD
Cost of Water Per Year	\$3,400,000	\$3,400,000	\$1,500,000
Estimated Annual Cost	\$8.8 Million	\$6.1 Million	\$4.7 Million

While the Savannah alternative has the lowest estimated construction cost, the higher water purchase rate from Savannah and lower potential water treatment capacity do not recommend its selection. It was recommended to purchase water from Missouri-American to supply the Stage 1 pipeline. . The Commission may elect to purchase water from both Savannah and Missouri-American with little additional cost due to Savannah's proximity to the proposed wholesale water pipeline. The recommended waterline alignment and sizing information is shown in Figure 4-2.

The operation and maintenance, replacement, debt service and water purchase costs were combined to project an average cost per 1,000 gallons of water for a wholesale service rate for \$8.83 per 1,000 gallons or an estimated customer monthly wholesale cost (purchasing 5,000 gallons) of \$44.14 per 1,000 gallons. Grant money, should it be available, would reduce the cost significantly and should be pursued by the Commission. The debt services costs were based on 4.75-percent over 33 years.

This report also suggested a series of "Next Steps" for the Commission to proceed with in order to move forward with this project. Three of the most major of those items are identified below:

- The Commission needs to solicit actual water sales numbers from the member utilities to verify that they will be served by the Stage 1 Pipeline and to what extent. Several of the members may request only a portion of the flow choosing to continue either purchasing water from another source or treating their own water. The assumed water demands represent the single largest assumption in this PER. Should a significant number of the utilities choose to purchase a fraction of the total water sales, the OPCs will reduce greatly, as will the volume of water sales.
- Negotiate a water purchase contract with Missouri-American contingent on obtaining funding and receiving water sales agreements with the Commission membership.
- Obtain project funding through the Missouri Water and Wastewater Review Committee or through private lenders.

Section 1

Introduction

Under the July 15, 2010 Planning Assistance to States (PAS) cost share agreement between the U.S. Army Corps of Engineers (USACE) and the Missouri Department of Natural Resources (MDNR) Water Resources Center, CDM Federal Programs Corporation (CDM) was requested to provide engineering and technical support services to the Kansas City District for Phase IV of the Northwest Missouri Regional Water Supply Study. The objective of Phase IV is to provide a Preliminary Engineering Report (PER) for the Stage 1 Pipeline and to provide an update to the 2009 *Phase II Feasibility Study* tailored for the current Great Northwest Wholesale Water Commission (Commission) membership. This report serves as the PER for the Stage 1 Pipeline. The Feasibility Study Update is a separate document, but relies heavily on the conclusions summarized herein.

Funding for this study was provided through the USACE Planning Assistance to States (PAS) Program, Section 22 of the Water Resources Development Act of 1974 (Public Law 93-251) as amended to assist the States in the preparation of comprehensive plans for the development, utilization and conservation of water and related land resources, and Section 319 of the Water Resources Development Act of 1990 (Public Law 101-640). The Missouri Department of Natural Resources (MDNR), as the non-Federal sponsor of the PAS agreement, utilized State general revenue funds for 50-percent of this study's cost. CDM and Bartlett & West completed the work on both documents under this agreement.

The PER and Feasibility Study Update also rely heavily on the data from previous studies and information provided by MDNR, the Commission and its membership and specific non-member water utilities that were identified as potential water supply options. Special recognition should also be given to the important role the Northwest Regional Council of Governments made by supporting communication with the Commission over the course of the project.

1.1 Stage 1 Pipeline Project Description

The Commission membership included the 24 water utilities shown in Table 1-1 at the time this project was initiated. The Commission Strategic Planning Sub-Committee, along with MDNR and USACE assistance, identified the initial Stage 1 Pipeline alignment shown in Figure 1-1. The transmission main from King City east to Daviess County PWSD No. 1 shown on the figure is an optional add-on alternative.

**Table 1-1
October 2010 GNWWC Membership**

Andrew County Public Water Supply District (PWSD) #1
Andrew County PWSD #2
Andrew County PWSD #4
Buchanan County PWSD #1
City of Albany
City of Barnard
City of Bolckow
City of Cameron
City of Gallatin
City of Grant City
City of King City
City of Maitland
City of Maysville
City of Plattsburg
City of Ravenwood
City of Savannah
City of Stanberry
City of Stewarstville
Clinton County PWSD #1
Davies County PWSD #1
DeKalb County PWSD #1
Gentry County #1
Gentry County #2
Nodaway County #1

Three nearby potential water suppliers were identified as alternatives to serve the Stage 1 Pipeline: Missouri-American (located in St. Joseph, Missouri), City of Savannah, and the Atchison County Wholesale Water Commission (ACWWC).

The intent of this report is to determine the potential water demand for the Stage 1 Pipeline, evaluate the three water supply options, provide a recommendation as to the lowest cost source, and provide construction cost information to the Commission to pursue funding.

1.2 Project Background

A group of interested parties and stakeholders from Northwest Missouri established a Water Partnership planning group consisting of representatives from each of the 12 counties Northwest Missouri. The 12 counties included Andrew, Atchison, Buchanan, Caldwell, Clinton, Davies, DeKalb, Gentry, Harrison, Holt, Nodaway, and Worth. The goal of the Water Partnership was to explore options for a regional plan to provide a long-term, affordable, high-quality water supply.


During the 2007 Phase I study, 83 public water systems in the 12 county area were evaluated with regards to their water supply capacity (including source capacity and treatment capacity), ability to withstand drought, and adequacy of water treatment facilities (including excess capacity, age of treatment facilities, and compliance with drinking water standards). Only 40 of the 83 systems had their own water supply sources. Other potential water supply sources for the 12 county area were identified and evaluated. These sources included aquifers, potential reservoir sites, off stream diversions, and other suppliers (City of Kansas City, Missouri, Rathburn Reservoir in Iowa, and Missouri-American Water Company of St. Joseph). The water supply demands were identified, including the existing unserved population, anticipated population growth, and other needs including commercial and industrial projections. The initial studies identified seven of the current water systems that could serve as hubs in a more comprehensive, long-range plan. These systems have the capacity to continue meeting the needs of their current service area while providing additional water to a regional system. The Water Partnership and an appointed engineering/technical subcommittee were assigned responsibility for identifying and evaluating alternative solutions to address the water supply needs for the 12 county area. The subcommittee identified and evaluated several alternatives, and provided the Water Partnership with a recommended water supply transmission system plan. The recommendation was adopted by the Water Partnership as the best alternative to evaluate for implementation in Phase II of the study.

The Phase II study, completed March 6, 2009, provided the preliminary planning report with cost estimates for the regional water supply transmission system and a framework for implementing the regional water supply system outlined in Phase 1.

The Water Partnership eventually formed the Commission that has 24 member utilities as of the beginning of 2011. The Phase III study completed in 2010 provided a methodology for water supply facilities to compare cost, a discussion of how current and future regulatory issues may impact groundwater and surface water supplies, and an analysis of the availability, reliability, and quality of current groundwater and surface water supplies.

As the follow on to the previous work, CDM and Bartlett & West were retained to complete that Phase IV work described above.

This page left blank intentionally



Section 2

Future Water Need Projections

2.1 Description of Need

Water has long been identified as a key driver in the success and stability of population trends. In northwest Missouri, many communities depend on access to the Missouri River and its alluvial aquifers or reservoirs for water supply. Those without access to these sources purchase water from a wholesale supplier. The *Northwest Missouri Regional Water Supply Transmission System Study Phase III Report* dated May 2010 provides a summary of water supply issues in the northwest region of Missouri. The *Phase III Report* discussed four primary topics: formation of the Commission, cost of water, current and future regulatory issues and drinking water sources within the region and on a county-by-county basis.

This report provides water system sizing and cost information specific to the 24 current Commission members individually, rather than analyzing the entire 12 county area as done in the *2007 Phase I Report*. The methodology, assumptions, and projected demands are summarized below.

2.2 Future Water Need Projections

Historical growth trends and water usage surveys for the 24 Commission members were compiled and studied and from that, projections extending to year 2030 were completed. Water demands are projected to the year 2030, which is anticipated to be the first year that all phases of the conceptual system would be built and in operation. This work was performed under the *2007 Phase 1 Report* and modified in the *2009 Phase II Report*, but have been updated as part of this work. The objective was to determine the overall amount of water demand required by the Commission members when all phases of the project would be constructed and in operation.

The 1950 through 2000 city and county population data was provided by the Missouri Census Data Center. The 2006 population data was also used if available from the *2007 Phase I Report*. The historic population trend and population projections through 2030 are shown in Appendix A. Six utilities have a negative population growth since 1950. For those utilities, it was assumed that the current water demands would remain as is without any decline in the future.

Historical water demand data was requested from each Commission member. If data was not available, data from the *2007 Phase I Report* was used. In certain cases, the water demand and sales numbers were modified due to one Commission member selling water to a second member. These changes were made to provide a more realistic view of the water demands for the membership and not to double count water needs.

Similar to the methodology used in the 2007 *Phase I Report* and in the modified 2009 *Phase II Report*, the entire water usage for selected communities has been included in the wholesale supply system. This acknowledges that most of these supplies are aging beyond their expected service life, or suffer from water quality or quantity issues. An important trend identified in the Phase I effort is that of the 83 systems in the region, 43 purchase water from a neighboring community. At one time, 24 of those 43 systems had their own source supply. Since many aging and degrading supplies remain, regionalization and consolidation of water suppliers will likely continue, even in absence of a regional comprehensive system. The assumption that a majority of communities will have abandoned their water supplies within the next 20 years is validated by the trends seen in the area.

2.2.1 Calculation Methodology

The calculations are presented in Appendix A of this report. The 2009 water demand data were divided by the 2009 utility population projections to determine a gallon per capita per day (GPCD). The GPCD was then multiplied by the 2030 projected population to determine the annual water demand and average day water demand. Consistent with the 2009 *Phase II Report*, a peaking factor of 2.0 was multiplied by the average day water demand to estimate the maximum day demands.

One important note was that the population data for water districts was projected from the population data included in the 2007 *Phase I Report*, which used the district reported population and calculated a percentage of the total county population served in 2006. That percentage was assumed to remain constant and multiplied by the individual County growth projections to determine the District population growth.

Table 2-1 summarizes the water demand results of the Commission.

**Table 2-1
Summary of Commission Demands**

District/City	Water Demands (MGD)	
	Current Max. Day	2030 Max. Day
Andrew County PWSD #1	1.02	1.17
Andrew County PWSD #2	0.73	0.84
Andrew County PWSD #4	0.07	0.09
Buchanan County PWSD #1	0.35	0.35
City of Albany	0.44	0.50
City of Barnard	0.04	0.05
City of Bolckow	0.10	0.10
City of Cameron	2.68	3.33
City of Gallatin	0.75	0.78
City of Grant City	0.25	0.25
City of King City	0.20	0.20
City of Maitland	0.05	0.05
City of Maysville	0.17	0.19
City of Ravenwood	0.06	0.07
City of Stanberry	0.23	0.23
City of Stewartsville	0.10	0.13

Table 2-1 (Continued)

District/City	Water Demands (MGD)	
	Current Max. Day	2030 Max. Day
Clinton County PWSD #1	0.12	0.16
Davies County PWSD #1	0.31	0.32
DeKalb County PWSD #1	1.41	1.62
Gentry County #1	0.25	0.25
Gentry County #2	0.10	0.10
Nodaway County #1 ⁽¹⁾	0.60	0.60
City of Plattsburg	1.85	2.07
City of Savannah	0.92	1.13
Total (Excluding Plattsburg & Savannah)	10.03	11.38
Total w/ 15% Additional Growth Included	11.53	13.09

Note 1: Assumes only another 0.3MGD average day and 0.6 MGD maximum day purchased not full system demand
MGD = million gallons per day

The resulting total annual percentage change was 0.61-percent per decade as opposed to 0.26-percent per decade presented in the 2007 *Phase I Report*. However, the 2007 *Phase I Report* analyzed 80 utilities over 12 counties and was a much broader assessment of the area. These projections are tailored specifically to the utilities shown.

This methodology does not account for any future water demands in excess of the current customer base. The overall water demand was increased by 15-percent to allow for some future water sales or supply to water utilities near the transmission mains that are not current Commission members.

2.2.2 Stage 1 Pipeline Water Demands

Table 2-2 provides a summary of the Stage 1 water system demands used for the Stage 1 Pipeline.

Table 2-2
Summary of Stage 1 Water System Demands

District/City	Water Demands (MGD)	
	Current Max. Day	2030 Max. Day
Andrew County PWSD #1	1.02	1.17
Andrew County PWSD #4	0.07	0.09
City of Albany	0.44	0.50
City of Barnard	0.04	0.05
City of Bolckow	0.10	0.10
City of King City	0.20	0.20
City of Stanberry	0.23	0.23
Davies County PWSD #1	0.31	0.32

Table 2-2 (Continued)

District/City	Water Demands (MGD)	
	Current Max. Day	2030 Max. Day
DeKalb County PWSD #1 ⁽¹⁾	0.35	0.40
Gentry County #1	0.25	0.25
Gentry County #2	0.10	0.10
Nodaway County #1 ⁽²⁾	0.60	0.60
Total	3.71	4.01
Total w/ 15% Additional Growth Included	4.27	4.61

Note 1: Listed demand for DeKalb County PWSD #1 includes 25 percent of overall utility demand for Stage 1

Note 2: Assumes only another 0.3 MGD average day and 0.6 MGD maximum day purchased not full system demand

It is important to note that Nodaway County PWSD No. 1 currently purchases all of its water from the City of Maryville and has a long term water purchase contract with that supply. The 0.6 MGD maximum day demand is an estimate of the demands for the unserved areas within Nodaway County that could be served by the Commission supply rather than the Maryville Supply.

Several Commission members on the Stage 1 Pipeline already purchase water from Missouri-American. To maintain an equal comparison between the Savannah, ACWWC, and Missouri-American supply alternatives it is assumed that these water demands are part of the water purchased from any of the three system suppliers.

Section 3

Conceptual Design Criteria

The goal of this conceptual design was to evaluate an overall transmission system for the existing 24 Commission members. For the overall system design, each member has a transmission line connecting their current master meter locations to the overall system. EPANET 2.0 modeling software was used to evaluate the overall system.

The input parameters used to create the EPANET model and the output data can be found in Appendix B. The piping, pumping, and storage facilities for the conceptual plan are shown in Figure 3-1.

To create the overall system model, points were assigned for each utility which represents where they would receive water from the Commission. The actual connection points were selected by referencing the water distribution and transmission system maps provided by the individual utility and referencing the knowledge of wholesale water suppliers to the current membership.

Further, DeKalb County PWSD #1 has two connection points in the system. It was assumed based on pipe diameter that the northern connection point would receive 25 percent of the demand, and the southern connection point would receive 75 percent of the demand.

3.1 Model Criteria and Pipeline Sizing

The hydraulic criteria used in the model are indicated in Table 3-1. These criteria were chosen to minimize energy costs while optimizing storage and pumping facilities. A maximum pressure was selected to minimize the need for energy dissipation at delivery points. Most Commission members should be able to accept incoming water at this selected pressure without the need for throttling or higher pressure class pipelines. Some individual utilities may need to install booster pump stations to meet their individual pressure requirements.

Table 3-1
Model Development Criteria

Model Constraint	Value
Allowable Friction Headloss Range	5 to 16 feet per mile
Target Pressure Range	40 - 150 PSI
Allowable Pressure Range	20 - 200 PSI
Maximum Transmission Velocity	3.5 feet per second
Storage Tank Volume	10% transmission flow
Maximum Horsepower (HP) per Pump	300 HP
Hazen-Williams Roughness Coefficient	140

PSI = pounds per square inch


HP = horsepower

3.2 Pumping Facilities

Pump stations are located in areas where free-flowing pressures from elevated storage or other pump stations would drop below 20 psi. The pump stations are sized to provide flow for peak daily demands in a 24-hour delivery period. Individual pumps were limited to 300 HP to allow low voltage (480 volt or less) equipment while keeping conductor sizes within a reasonable and economical range.

3.3 Water Storage Facilities

Storage facilities are located where the combination of elevation and pipeline friction losses cause pipeline pressure upstream of the pump station to exceed 200 psi. Storage facilities were sized in the transmission system for pump station equalization only. Each member of the Commission will be responsible for their own internal storage needs. Some storage capacity is available on the transmission system, but it is assumed that emergency storage will be provided by each member of the Commission. Recirculation systems will be needed to maintain disinfectant residuals.



Section 4

Stage 1 Pipeline Alternatives

Three wholesale water suppliers were considered to serve the Stage 1 Pipeline. These suppliers include the emerging ACWWC, Missouri-American Water Company in St. Joseph, and the City of Savannah. There are additional supply hubs in the area, Middlefork Water Company being one example, that do have the capability of providing minor quantities of potable water as compared to the three major suppliers named above. These additional local contributors may be considered in the preparation of a final design, but are not further evaluated as part of the preparation of this PER. Water quality from these smaller sources should also be investigated and confirmed to be compatible with the primary source. All sources should have chloramines as the residual disinfectant and be of similar water hardness and pH.

A survey of the three suppliers was completed as an initial task of the Phase II Feasibility Report and was updated again as a portion of this PER. In the survey, the suppliers were asked to define their current capacity and describe any expansion plans. They were also asked to report their current wholesale water rates. Copies of the correspondence with the suppliers are provided in Appendix C. This data was incorporated into the report and provided for the Commission's reference.

4.1 Atchison County Wholesale Water Commission

The ACWWC is currently under design and is scheduled to go online in mid 2013. The initial construction will include a 2.5 MGD groundwater treatment facility and well field. This facility will not have excess treatment or transmission capacity, but the site was selected to allow for future expansions up to 10 MGD. The ACWWC has not set a wholesale water rate, but the 2008 facility plan indicates that it will be approximately \$4.00 per 1,000 gallons. Assuming an inflation rate of 5 percent per year for 5 years, the 2013 rate will be \$5.11 per 1,000 gallons. The ACWWC will provide chloramines as the residual disinfectant and could provide up to 6 MGD to the Commission.

The ACWWC Stage 1 alignment used the new ACWWC Water Treatment Plant (WTP) as its source for the transmission system. The alignment of the ACWWC alternative is shown in Figure 4-1. The transmission system consists of approximately 127 miles of pipeline ranging between 6 and 30 inches in diameter. The system also includes one pump station and two water storage tanks, one near King City and the other near Maryville. The pump station is located at the ACWWC WTP and was designed to pump 6.0 MGD with a head of 376 feet. To keep the pumps at 300 HP or under, there are four pumps in the system, with three operating and one standby. The King City elevated storage tank operating water levels are between 140 and 160 feet above ground and the tank stores up to 400,000 gallons of water. The Maryville standpipe is 200,000 gallons and has a high water level at 63 feet above ground. The storage tanks are not intended to replace any of the Commission members' own storage tanks and were not designed to provide fire protection or emergency storage.

4.2 Missouri-American Water Company

Missouri-American Water Company owns and operates the 30 MGD groundwater treatment municipal water system in St. Joseph, Missouri. The WTP currently has a minimum of additional 8 MGD available capacity to serve the Commission. Missouri-American also uses chloramines as the residual disinfectant. The 2010 wholesale water rate structure includes a minimum charge and a water charge per 1,000 gallons as outlined in Table 4-1 below. The projected 2013 rates were inflated at 5 percent per year for 3 years.

Table 4-1
Missouri-American Rate Schedule

Rate Class	2010 Rate (\$/kgal)	2013 Projected Rate (\$/kgal)
Monthly Minimum Charge (12-inch meter)	\$1,124.62	\$1,301.89
For the first 100,000 gallons	\$4.2794	\$4.95
For the next 1.9 million (M) gallons	\$3.3234	\$3.85
For the next 3.0M gallons	\$2.7691	\$3.21
For all over 5.0M gallons	\$1.8886	\$2.19

Several of the existing Commission members currently purchase water from Missouri-American with varying time frames to their existing contracts. It is assumed that when these contracts expire the individual Commission members would then purchase water from the Commission. Further, for this comparison it is assumed that Missouri-American has one meter location that serves the entire Commission and that the declining rate structure is applied to the entire purchase volume as one location.

The Missouri-American Stage 1 alignment used the existing Missouri-American WTP that serves some current Commission members. The alignment of the Missouri-American alternative is shown in Figure 4-2. The transmission system consists of approximately 113 miles of pipeline ranging between 6 and 24 inches in diameter. The system also includes one pump station, one flow control structure, and two storage tanks. The two storage tanks included in this alternative are identical to those sized for the ACWWC Stage 1 Pipeline Alternative. The pump station is located at the Missouri-American site and sized to provide 6.0 MGD firm capacity with a total dynamic head of 255 feet.

In addition, the Commission would need to construct on-site water storage for the new booster pump station at the Missouri-American plant site. The cost for this additional storage is approximately \$1.8 million.

4.3 City of Savannah

The City of Savannah currently operates a 2.0 MGD municipal groundwater treatment plant constructed in 2008. The 2010 *Drinking Water Facilities Plan* addressed possible plant expansions and provided some projected water rates based on different purchasing scenarios.


The Savannah WTP has free chlorine as its residual disinfectant. All of the other major sources of water are providing chloramines as the residual disinfectant in the system. Purchasing water from the City of Savannah would require the Commission to invest in an ammonia feed facility to convert the residual disinfectant to chloramines to match the other suppliers. This cost is estimated at \$70,000 for the initial construction cost and will add an additional operation and maintenance expense to the Commission that is not incurred with the other alternatives. The cost for the ammonia feed facility is included in the Commission's capital cost.

Based on the Facilities Plan assumptions, the plant could be expanded to 5.0 MGD and make available up to 3.9 MGD for Commission use. It is assumed that Andrew County PWSD No. 1 is part of the general Commission demand and not an individual purchaser for this capacity. The Facilities Plan does note that it may be feasible to expand the plant capacity beyond this amount, but further information is needed regarding the well field yield and evaluation of the plant site and lime sludge lagoon layout to make that determination.

Further, an estimated production cost was provided in the report indicating the cost of water would be \$3.77 per 1,000 gallons, but this did not include city administration and billing costs. For this PER, these improvements were assumed to add 20 percent to the cost of water rate to account for costs not covered in the *Drinking Water Facilities Plan*. The rates were then inflated at 5 percent per year to a projected 2013 rate of \$5.24 per 1,000 gallons.

The Savannah alternative for Stage 1 is similar to the Missouri-American Stage 1 alternative. Savannah's WTP is north of the Missouri-American and the alternative includes a transmission main from the Savannah WTP to the Missouri-American connection. The Savannah alignment is shown in Figure 4-3. The Savannah transmission system is approximately 108 miles of pipeline ranging between 6 and 24 inches in diameter. The storage and pumping facilities sized for the Missouri-American alternative are the same for the Savannah alternative, which is described above.

This page left blank intentionally



Grant City

Nodaway Co PWSD 1

Ravenwood

Maryville

Gentry Co PWSD 1

Gentry Co PWSD 2

Albany

Maitland

Barnard

Stanberry

Andrew Co PWSD 4

Bolckow

King City

Daviess Co PWSD 1

Rosendale

DeKalb Co PWSD 1 2nd 25%

Andrew Co PWSD 1

Maysville

Gallatin

Andrew Co PWSD 2

Buchanan Co PWSD 1


Cameron


DeKalb Co PWSD 1 1st 75%

Stewartsville

Plattsburg

Clinton Co PWSD 1





Atchison Co. PWSD #1

Nodaway Co PWSD 1

Grant City

Worth Co. PWSD #1

Harrison Co. PWSD #1

Nodaway Co PWSD #1

Ravenwood

Harrison Co. PWSD #2

Maitland

Gentry Co PWSD 2

Gentry PWSD 1

Gentry Co. PWSD #2

Albany

Barnard

Stanberry

Holt Co. PWSD #1

Andrew Co PWSD 4

Andrew Co. PWSD #4

Gentry Co. PWSD #1

Daviess Co PWSD 1

Legend

- PS Pump Stations
- Water Storage Tanks
- Water Districts
- Municipal Customers
- Savannah Option
- County Boundary

Roadway Type

- Interstate Highway
- State Highway
- US Highway



Andrew Co. PWSD #3

6

12

24

12

12

12

20

16

8

12

12

12

12

12

12

12

12

12

12

Andrew Co. PWSD #1

Andrew Co. PWSD #2

Andrew Co PWSD 1

Buchanan Co PWSD 1

Andrew Co PWSD 2

Dekalb Co PWSD 1 1st 75%

Dekalb Co. PWSD #1

Maysville

Daviess Co. PWSD #1

Daviess Co. PWSD #3

Livingston Co. PWSD #4

Gallatin

Buchanan Co. PWSD #1

Buchanan Co. PWSD #2

Clinton Co PWSD 1

Platte Co. PWSD #9

Platte Co. PWSD #7

Clinton Co. PWSD #2

Clinton Co. PWSD #4

Clinton Co. PWSD #3

Caldwell Co. PWSD #2

Caldwell Co. PWSD #3

Cameron Caldwell Co. PWSD #2

Ray Co. PWSD #1

Northwest Missouri Water Partnership

Figure 4-3 Savannah Option

Section 5

Alternative Comparison and Recommended Source

5.1 Opinion of Probable Cost

Opinions of Probable Cost (OPC) for the initial construction cost of the conceptual system were developed using an approach that incorporates actual prices from recent similar rural water projects. Facilities are divided into three classes: pipeline, pump stations, and water storage.

Individual cost opinions were developed for each Stage I Alternative. Pipeline costs were estimated by assuming a unit price per foot for each size of pipe. These prices ranged from \$27.00 per linear foot for a 6-inch diameter pipe up to \$150.00 per linear foot for a 30-inch diameter pipe. Pipeline unit prices include design, material, installation, and easement acquisition.

Pump station costs were estimated by assuming a fixed cost for a pump station, which includes design, land, structure, power, and instrumentation. Additional cost is then added per pump and per HP for additional building footprint, power, and equipment costs. Estimated pump station costs range from \$1.25 million for a 450 HP station with 3 pumps to \$1.73 million for a 650 HP station with four pumps.

Water storage tank costs have been estimated assuming a fixed cost for a basic installation, which includes cost for land acquisition, design, and basic structure. Additional cost is then added per foot of height and per 1,000 gallons of volume. Estimated storage tank costs range from \$550,000 for the Maryville standpipe to \$970,000 for the 400,000 gallon King City elevated storage tank.

In addition, legal and financial costs (5 percent) and contingency and inflation (20-percent) were added to arrive at the total cost.

As shown in Table 5-1, Alternative 3 (Savannah) has the lowest OPC for initial construction. The OPC for constructing Alternative 2 (Missouri-American) is 17-percent higher than Alternative 3 and Alternative 1 (ACWWC) is double the cost of Alternative 3. A more detailed cost summary that includes specific OPC tables can be found in the Appendix D.

Table 5-1
OPC for Supply Alternatives

	Alternative 1 ACWWC	Alternative 2 Missouri-American	Alternative 3 Savannah
Construction, Land, and Engineering	\$70,800,000	\$41,700,000	\$34,700,000
Legal and Financial (5%)	\$3,500,000	\$2,100,000	\$1,750,000
Contingency and Inflation (20%)	\$14,200,000	\$8,300,000	\$6,950,000
Total	\$88,500,000	\$52,100,000	\$43,400,000

5.2 Water Rate and Capacity Comparison

Each of the water supply alternatives was contacted for information on current and/or projected rates and system source capacity. Table 5-2 provides a comparison of the available capacity and projected water rates for the three supplies.

**Table 5-2
Water Rate and Capacity Data**

	Savannah	Missouri-American	ACWWC
Annual Est. Water Purchase Volume (kgal) ⁽¹⁾	654,000	654,000	654,000
Cost to Purchase Water (\$/kgal)	\$5.24	\$2.19 to \$4.95	\$5.11
Cost of Water Per Year ⁽²⁾	\$3,400,000	\$1,500,000	\$3,400,000
Water Supply Capacity	Up to 3.9 MGD	Existing 8.0 MGD	6 MGD

(1) Current Avg. Day for Stage 1 Pipeline Customers x 1.05 to account for system water loss x 365 days/year.

(2) Cost to Purchase Water (\$/kgal) x Annual Est. Water Purchase Volume (kgal). Assumes single point of purchase.

The water rate calculation assumptions and capacity descriptions are included in Section 4 of this report. Based on the annual estimated water purchase volume, the cost to purchase water from Missouri-American is approximately half that of any other source. The Missouri-American average cost per 1,000 gallons is approximately \$2.29/kgal when all water is purchased from one meter. The second benefit to the Missouri-American option is that the additional system capacity already exists, unlike the ACWWC and Savannah alternatives.

5.3 Recommended Source Alternative

If an assumption of debt service of 4.75-percent per year for 33 years was applied to the OPC numbers to generate an annual debt service cost and added to the estimated annual cost to purchase water, the new total for each alternative is summarized in Table 5-3.

**Table 5-3
Estimate of Annual Costs**

	Savannah	Missouri-American	ACWWC
Est. Annual Debt Service	\$2,700,000	\$3,200,000	\$5,400,000
Cost of Water Per Year	\$3,400,000	\$1,500,000	\$3,400,000
Estimated Annual Cost	\$6.1 Million	\$4.7 Million	\$8.8 Million

Based on these results, Missouri-American is the lowest cost water supply alternative to serve the Stage 1 Pipeline. Further, Missouri-American already has the water treatment to serve the Stage 1 Pipeline projected water demands at the time this report was written.

Section 6

Conceptual Plan Preliminary Cost Opinion

This section presents the underlying information required for a water rate analysis, including initial construction costs, system replacement cost, and annual operating and maintenance (O&M) costs.

6.1 Opinion of Probable Cost

The assumptions used for developing the OPCs were outlined in Section 5 of this report. Based on the purchase cost of water and OPCs, Missouri-American was the supply alternative determined to be the lowest cost. The remainder of Sections 6 and 7 focus on this alternative alone.

As part of the development of Stage 1, an additional pipeline alignment to serve Daviess County PWSD No. 1 from King City was requested. The OPCs below present the base cost opinion as well as the cost to include Daviess County PWSD No. 1.

Table 6-1
Missouri-American Cost Alternative

Item	Base Alignment	Including Daviess PWSD No. 1
Pump Stations	\$1,300,000	\$1,300,000
Water Storage Facilities	\$3,300,000	\$3,300,000
Pipeline	\$37,100,000	\$43,400,000
Subtotal	\$41,700,000	\$48,000,000
Legal and Financial (5%)	\$2,100,000	\$2,400,000
Contingency and Inflation (20%)	\$8,300,000	\$9,600,000
Total OPC	\$52,100,000	\$60,000,000

6.2 Replacement Cost

System replacement costs are essential to managing a water system and are an important component in determining rates. This report assumes full replacement of each component at the end of its lifespan at the inflated initial construction cost, minus 40-percent for one-time project incidentals. These expenses, such as easement acquisition and some design costs, do not need to be paid again during a replacement project. Projected lifespan is assumed as 20 years for pump stations, 40 years for storage facilities, and 60 years for pipeline. When compensating for price inflation during the lifespan of the facilities, it is assumed that cash investments set aside for depreciation will gain interest at a rate equal to inflation.

Using this assumption for the Missouri-American Alignment (Figure 4-2), annualized replacement costs are approximately \$40,000 for pump station replacement, \$50,000 for storage tank replacement, and \$380,000 for pipeline replacement, for a total of \$470,000 per year in replacement costs. Most often, investments can be chosen which exceed the rate of price inflation. If this happens, the amount of cash needed to fund depreciation is reduced.

6.3 Annual Operation and Maintenance Cost

O&M costs were developed using similar data from comparable water systems. Although many different factors combine to make up a system's annual budget, often the bulk of the cost is represented in four components: staffing, energy (electricity) costs, storage repainting, and pipeline maintenance and repair. Costs for these four categories have been estimated and the total of these costs are represented as the estimated annual O&M cost for the system. The annual O&M costs identified below are for the Missouri-American base alignment only.

Staffing costs assume a staffing level of one part-time and three full-time employees, comprised of two administrative and two field employees. Estimated staffing costs including benefits and employer payroll contributions total \$210,000.

Electrical costs are mostly derived from pumping operations. Assuming pumping operations are active approximately 25-percent of the total hours available in a year, the system would have an annual electrical demand of approximately 735,000 kilowatt-hours (kwh). Assuming a rate cost of \$0.12 per kwh, the resultant annual energy cost is approximately \$89,000 per year.

Storage tank recoating represents another significant maintenance cost on the conceptual system. To develop this cost estimate, it is assumed that the coating systems used require a full blast and recoat every 15 years. Recent recoating costs for similar size tanks indicate the present value cost of recoating is approximately \$150,000 per tank. If this cost is annualized, the cost to recoat both of the system's storage tanks is budgeted at approximately \$30,000 per year.

The final component of the estimated O&M costs is pipeline maintenance. For this component, it is assumed that one break will occur for every 20 miles of pipeline each year. The present value repair cost represents the additional labor cost, equipment cost, and parts, and is estimated at \$3,000 per repair. Multiplying those two factors show an estimated cost of upkeep for the conceptual pipeline system is approximately \$15,000 per year.

Combining these four factors provides a representation of annual O&M costs for the conceptual system, excluding depreciation as represented in the previous section. This annual cost totals approximately \$344,000 per year.

6.4 Water Purchase Cost

Water purchase costs were calculated assuming that all water for resale is purchased from Missouri-American. Assuming annual purchases of 654 million gallons, the annual water purchase costs total \$1.5 million.

One additional scenario that could be considered as the Commission moves into design phase activities is to evaluate purchasing the remaining water supply available from the City of Savannah in addition to the Missouri-American supply source. The 2010 Feasibility Study states that up to 0.9 MGD could be made available to the Commission should the hours of operation increase at the WTP. The cost of water from Savannah would be approximately \$5.93 per thousand gallons as compared to the averaged cost from Missouri-American of \$2.30 per 1,000 gallons. Adding a second source of supply would provide redundancy for the Commission and the location of the Savannah WTP is near the proposed waterline alignment minimizing the additional construction costs. However, the ammonia feed facility at the Savannah WTP would still be necessary before purchasing water from that supply and combining it with the Missouri-American water. Following the methodology outlined in Section 7 of this report, the combined estimated cost per 1,000 gallons is \$10.91.

Section 7

Summary of Wholesale Rate Requirements

This section of the report presents the results of financial analyzes required to provide a preliminary estimate of the wholesale rates applicable to this project. Rate requirements are composed of debt service on construction of facilities, O&M expenses of the facilities, and water cost purchased for resale. The following is based on the base scenario and does not include the demands or additional construction cost from Daviess County PWSD No. 1. These costs are estimated under the following capital improvement financing scenarios:

- Scenario 1 assumes 100-percent revenue bond financing
- Scenario 2 assumes 80-percent revenue bond financing and 20-percent grant funding
- Scenario 3 assumes 50-percent revenue bond financing and 50-percent grant funding

Table 7-1
Summary of Wholesale Rate Requirements

	Scenario 1	Scenario 2	Scenario 3
Estimated Annual Debt Service	\$3,200,000	\$2,600,000	\$1,600,000
Estimated O&M Expense	\$340,000	\$340,000	\$340,000
Estimated Annual Renewal and Replacement	\$470,000	\$470,000	\$470,000
Estimated Annual Water Purchase	\$1,500,000	\$1,500,000	\$1,500,000
Total Estimated Annual Revenue Requirement	\$5,500,000	\$4,900,000	\$3,900,000
Estimated Water Sales (kgal/MGD)	623,000/1.7	623,000/1.7	623,000/1.7
Estimated Cost per 1,000 gallons	\$8.83	\$7.87	\$6.26
Estimated Customer Monthly Wholesale Cost (5,000 gal)	\$44.14	\$39.33	\$31.30

The necessity and amount of capital and operating reserves and bond issuance costs cannot be established at this time. The bond underwriter will determine the need for reserves to provide investor security based on the actual project phasing plan to be implemented. Typically, if these reserves are deemed necessary, they can be accumulated over a period of time by the entity. Bond issuance cost is directly related to the size of the bond issues. Without a phasing plan, bond issuance sizes cannot be determined along with bond issuance costs.

It is also important to note that additional cost savings would be possible by omitting the additional 15-percent service capacity added in Section 2 of this report. Scenario 2 and 3 illustrate the impacts to the overall rate structure should grant funds be made available for this project.

For purpose of these financial analyses, the following assumptions are used:

- Total estimated capital improvements will be \$52.1 million for the entire project, including transmission mains, pumping stations, and storage facilities.
- Annual water usage was calculated using the current 1.7 MGD average daily use assuming all wholesale customers are under contract for service.
- No phasing of the issuance of revenue bonds has been assumed. All revenue bonds are assumed to have been issued at a 4.75-percent interest rate, 33-year term, with equal annual debt service payments.
- All funding of any operating and capital reserves, which may be necessary for revenue bond issuance has been completed. Reserves may not be necessary should insurance be ultimately obtained.
- Estimated revenue bond issuance amounts do not reflect impact of any issuance costs nor any capitalized interest during construction.
- Water purchases are from Missouri-American.
- Estimated annual renewal and replacement cost is based on straight-line depreciation projections for various facility types.

To refine the “Summary of Wholesale Rate Requirements” presented in Table 7-1, certain key activities must be initiated and completed in order to have an accurate representation of the project’s long term financial requirements. The list below denotes key activities:

- Establishment of a political entity with rate setting, enforcement, and debt issuing authority.
- Legal commitment by community members to participate in the project during design, construction, and operation of the project facilities through take or pay agreements. Development and execution of these agreements between the system and wholesale customers to establish rate stability and strengthen the financial viability of the system.
- Development of a project strategic financial plan that recognizes project “phasing” and changes in membership in order to determine the actual size of needed bond issues and timing. This will impact the need and level of “capitalized interest during construction” and reflect the financing scheme developed by the entity and its memberships for funding during construction.
- Hiring of bond council and underwriter to develop revenue bond ordinance; an official bond offering statement; projected debt service schedules; bond issuance cost; the need for amount and timing of any necessary operation and capital reserves to provide investor security; bond issuance amount; interest rate; bond term; adequate level of “capitalized interest during construction”; and bond market timing.

Section 8

Conclusions

The recommended potable water supply alternative for the Commission is to negotiate a water purchase contract with Missouri-American. It is still feasible for the Commission to evaluate additional or smaller water purchase contracts from others.

Figure 8-1 is a proposed project schedule for the Commission to follow towards construction completion of this project. There is still significant work for the Commission to do in order for this project to be feasible as outlined as part of the “Next Steps.”

8.1 Recommended “Next Steps”

This PER concludes, given the assumptions and conceptual design as presented, that the project may be feasible if the rate information produced is acceptable to the member entities. The following summarizes the recommended “next steps” to be implemented for this project before moving into final design and construction:

- The Commission needs to solicit actual water sales numbers from the member utilities to verify that they will be served by the Stage 1 Pipeline and to what extent. Several of the members may request only a portion of the flow choosing to continue either purchasing water from another source or treating their own water. The assumed water demands represent the single largest assumption in this PER. Should a significant number of the utilities choose to purchase a fraction of the total water sales, the OPCs will reduce greatly, as will the volume of water sales.
- Environmental clearances need to be completed in compliance with the Missouri Water and Wastewater Review Committee Guidelines.
- Public meetings need to be held to be in compliance with the Missouri Water and Wastewater Review Committee Guidelines.
- Conduct survey of proposed pipeline alignment.
- Negotiate a water purchase contract with Missouri-American contingent on obtaining funding and receiving water sales agreements with the Commission membership.
- Obtain project funding through the Missouri Water and Wastewater Review Committee or through private lenders.
- Establish a contractual mechanism as to how to administer water sales to the customers and select a method of equitable payment for the Commission members.
- Acquire property right for pump stations, storage tanks, and pipeline.

This page left blank intentionally

Appendix A
Reference Calculations

CDM	Calculation Form (Excel)	Job # <u>6198-78941</u>	Calc. By: <u>CSC</u>
Client:	<u>Northwest Missouri Water Commission</u>	Checked By: <u>SAS</u>	Date: <u>12/08/10</u>
Project:	<u>NoWMo Water Study</u>	Date: <u>12/10/10</u>	Calc. No.: _____
Detail:	<u>Water Demand Projections</u>	Reviewed By: <u>K. Rood</u>	Revision#: _____
		Date: <u>12/10/10</u>	Date: _____

Calculation Brief Title: Water Demand projections for the NWMo Commission members

1.0 Purpose/Objective

Calculate the water demand for 2030

2.0 Procedure

1. Identify population growth trends from the Census population data (1950 to 2000).
2. Estimate 2030 population and find a Population Change per year for each district and city.
3. Analyze 2005 to 2009 measured water demands from commission members, and correlate them with the projected population to estimate a per capita consumption
4. Apply the population change slopes to estimate 2030 population.
5. Estimate 2030 Demands from 2030 estimated population and average per capita per day estimations

3.0 References/Data Sources

1. Source 1950 - 1990 city population figures: <http://mcdc.missouri.edu/trends/historical.shtml>
2. Source 2000 city population figures: http://mcdc2.missouri.edu/websas/dp3_2kmenus/mo/Places/
3. Source of 1950 - 2000 counties population figures: <http://mcdc.missouri.edu/trends/historical.shtml>
4. Phase II Feasibility Study
5. Data provided by each commission member
6. Phase 1 Report, Appendix H

4.0 Assumptions and Limitations

1. Population growth changes are linear
2. Negative population growth trends will be taken as no growth (Population Change slope = 0)

5.0 Calculations

See attached tables

6.0 Conclusions/Results

See attached tables.

Population Analysis and Projections

County or City	City and County US Census Population Data (1)							2030 Projected Population (3)	Annual Population Change (4)	Revised 2030 Projected Population (5)	Revised Annual Population Change (5)
	1950	1960	1970	1980	1990	2000	(2) 2006				
Andrew County	11,727	11,062	11,913	13,980	14,632	16,492		19,600	105	19,600	105
Buchanan County	96,826	90,581	86,915	87,888	83,083	85,998		79,500	-216	86,000	0
City of Albany	1,850	1,662	1,804	2,152	1,958	1,937	3600	4,100	21	4,100	21
City of Barnard	275	237	206	234	234	257	300	310	0	310	0
City of Bolckow	250	232	225	245	253	234	240	240	0	240	0
City of Cameron	3,570	3,674	3,960	4,519	4,831	8,312	9788	12,300	105	12,300	105
City of Gallatin	1,634	1,658	1,833	2,063	1,864	1,789	1834	1,900	3	1,900	3
City of Grant City	1,184	1,061	1,095	1,068	998	926	1341	1,300	0	1,300	0
City of King City	1,031	1,009	1,023	1,063	986	1,012		1,000	0	1,020	0
City of Maitland	456	427	319	415	338	342	340	290	-2	340	0
City of Maysville	973	942	1,045	1,187	1,176	1,212		1,400	6	1,400	6
City of Plattsburg	1,655	1,663	1,832	2,095	2,248	2,354		2,800	16	2,800	16
City of Ravenwood	319	282	336	436	409	448	438	510	3	510	3
City of Savannah	2,332	2,455	3,324	4,184	4,352	4,762	5000	6,200	51	6,200	51
City of Stanberry	1,651	1,409	1,479	1,387	1,310	1,243		1,000	-7	1,250	0
City of Stewarville	414	466	634	832	732	759		1,000	8	1,000	8
Clinton County	11,726	11,588	12,462	15,916	16,595	18,979		23,700	156	23,700	156
Davies County	11,180	9,502	8,420	8,905	7,865	8,016		6,300	-58	8,100	0
DeKalb County	8,047	7,226	7,305	8,222	9,967	11,597		13,900	77	13,900	77
Gentry County	11,036	8,793	8,060	7,887	6,848	6,861		4,600	-77	6,900	0
Nodaway County	24,033	22,215	22,467	21,996	21,709	21,912		20,800	-36	22,000	0

(1)

Source 1950 - 1990 city population figures: <http://mcdc.missouri.edu/trends/historical.shtml>

Source 2000 city population figures: http://mcdc2.missouri.edu/websas/dp3_2kmenus/mo/Places/

Source of 1950 - 2000 counties population figures: <http://mcdc.missouri.edu/trends/historical.shtml>


(2) Population in 2006, based on the Phase I report

(3) Estimated 2030 population by linear extrapolation of the 1950 to 2000 data, based in 2000 for the counties, and based in 2006 Phase I report for the cities

(4) Population Change per year based on linear interpolation (slope of the least squares regression line)

(5) Revised Projections to show no negative population growth. Areas showing negative are assumed to maintain current population and demands.

Cities and Districts Population Trends



- | | | | |
|-------------------------|-------------------------|---------------------------|--------------------------|
| — Andrew County PWSD #2 | — Andrew County PWSD #4 | — Buchanan County PWSD #1 | — City of Albany |
| — City of Barnard | — City of Bolckow | — City of Gallatin | — City of Grant City |
| — City of King City | — City of Maitland | — City of Maysville | — City of Plattsburg |
| — City of Ravenwood | — City of Stanberry | — City of Stewartville | — Clinton County PWSD #1 |
| — Davies County PWSD #1 | — Gentry County #1 | — Gentry County #2 | — Andrew County PWSD #1 |
| — City of Cameron | — City of Savannah | — DeKalb County PWSD #1 | — Nodaway County #1 |

Average Annual Water Demand for the Cities

District / City	Annual Water Production Purchased (gallons)						Average Annual Water Demand	Notes	Estimated Population (4)					Gallons Per Capita Daily Demand (GPCD) (5)					Average GPCD (6)	2030 Revised Projected Population (7)	2030 Water Demand (8)	
	2005	2006	2007	2008	2009	2010			2005	2006	2007	2008	2009	2005	2006	2007	2008	2009			Avg. Day (gpd)	Annual (gal)
	City of Albany	83,818,400	79,669,320	78,676,180	82,507,830	79,907,480				80,916,000	(3), (9)	3,579	3,600	3,621	3,642	3,663	64	61			60	62
City of Barnard							8,030,000	(1)	300	300	300	301	301						73	310	23,000	8,259,000
City of Bolckow							18,250,000	(1)	240	240	240	240	240						208	240	50,000	18,250,000
City of Cameron	482,222,350	486,340,400	518,828,800	488,042,200	466,381,000		488,363,000	(3)	9,683	9,788	9,893	9,999	10,104	136	136	144	134	126	135	12,300	1,665,000	607,381,000
City of Gallatin							137,605,000	(1)	1,831	1,834	1,837	1,841	1,844						204	1,900	389,000	141,761,000
City of Grant City							45,625,000	(1)	1,341	1,341	1,341	1,341	1,341						93	1,300	125,000	45,625,000
City of King City	38,157,000	36,633,800	36,076,400	37,146,800	34,583,500		36,520,000	(3)	1,012	1,012	1,012	1,012	1,012	103	99	98	101	94	99	1,020	101,000	36,809,000
City of Maitland							9,125,000	(1)	340	340	340	340	340						74	340	25,000	9,125,000
City of Maysville						31,864,500	31,865,000	(2)	1,241	1,247	1,253	1,259	1,264						69	1,400	97,000	35,282,000
City of Plattsburg							336,895,000	(1)	2,433	2,449	2,464	2,480	2,496						370	2,800	1,036,000	377,963,000
City of Ravenwood	11,984,260	10,927,160	9,751,460	9,622,490	9,903,870		10,438,000	(3)	435	438	441	444	447	75	68	61	59	61	65	510	34,000	12,084,000
City of Savannah	158,365,285	172,504,100	178,491,415	165,427,000	164,486,390	171,309,286	167,855,000	(3)	4,949	5,000	5,051	5,102	5,153	88	95	97	89	87	91	6,200	565,000	206,062,000
City of Stanberry	42,500,240	43,055,770	41,581,660	39,688,370	39,024,980	35,029,216	41,171,000	(3), (10)	1,243	1,243	1,243	1,243	1,243	94	95	92	87	86	91	1,250	114,000	41,403,000
City of Stewartsville	21,737,900	18,812,500	17,782,300	17,542,200	17,587,800	14,156,300	18,693,000	(3)	798	806	813	821	829	75	64	60	59	58	63	1,000	64,000	23,008,000

Average Annual Water Demand for the Counties

District / City	Annual Water Production Purchased (gallons)						Average Annual Water Demand	% of County Pop. served by the PWS	Estimated Population (4)					Gallons Per Capita Daily Demand (GPCD) (5)					Average GPCD (6)	2030 Revised Projected Population (7)	2030 Water Demand (8)	
	2005	2006	2007	2008	2009	2010			2005	2006	2007	2008	2009	2005	2006	2007	2008	2009			Avg. Day (gpd)	Annual (gal)
	Andrew County PWS #1	181,270,500	183,473,250	202,632,250	174,327,600	190,350,000				186,411,000	35%	5,963	6,000	6,037	6,073	6,110	83	84			92	79
Andrew County PWS #2 (12)	122,664,650	138,888,150	136,832,236	141,590,675	123,494,400	137,286,900	132,695,000	18%	2,982	3,000	3,018	3,037	3,055	113	127	124	128	111	120	3,500	422,000	153,875,000
Andrew County PWS #4		12,441,560	14,882,400	14,441,200	12,899,200	11,949,700	13,667,000	4%	728	732	736	741	745	47	55	53	47	51	51	840	43,000	15,540,000
Buchanan County PWS #1	66,400,000	61,000,000	69,000,000	63,600,000	63,300,000	64,000,000	64,660,000	2%	2,000	2,000	2,000	2,000	2,000	91	84	95	87	87	89	2,000	178,000	64,660,000
Clinton County PWS #1	20,648,000	22,497,600	22,618,400	23,083,300	24,410,400		22,652,000	5%	943	950	957	965	972	60	65	65	66	69	65	1,200	78,000	28,378,000
Davies County PWS #1	59,663,030	57,334,750	60,619,300	53,994,030	54,343,310		57,191,000	33%	2,628	2,628	2,628	2,628	2,628	62	60	63	56	57	60	2,700	161,000	58,758,000
DeKalb County PWS #1 (11)		255,953,566	256,983,766	257,223,866	257,178,266	260,609,766	256,835,000	83%	9,936	10,000	10,064	10,127	10,191	70	70	70	69	70	70	11,600	809,000	295,120,000
Gentry County #1	43,250,600	47,399,680	48,392,820	44,561,170	47,161,520		46,154,000	29%	2,000	2,000	2,000	2,000	2,000	59	65	66	61	65	63	2,000	127,000	46,154,000
Gentry County #2	13,732,000	17,574,000	19,404,000	21,325,000	19,028,000		18,213,000	9%	600	600	600	600	600	63	80	89	97	87	83	600	50,000	18,213,000
Nodaway County #1	162,240,050	157,646,980	171,892,620	164,911,713	164,590,140		164,257,000	30%	6,500	6,500	6,500	6,500	6,500	68	66	72	70	69	69	6,500	451,000	164,257,000

- (1) Data from Phase II Feasibility Study
- (2) Estimated data based on City reporting 87,300 average daily production for 2010.
- (3) Data provided by utility
- (4) Estimated Population by linear extrapolation of U.S. Census Data with revised projections
- (5) Estimated Per Capita Daily Demand = Annual water demand / Estimated population / 365 days
- (6) Average of GPCD (Gallons/Capita/Day)
- (7) Areas showing neagtive population change are assumed to remain at the current population
- (8) Average annual water demand = GPCD x 2030 Revised Projected Population x 365 days
- (9) Albany Production data minus Gentry 1 purchased water
- (10) Stanberry Purchased water minus water sold to Gentry 2
- (11) DeKalb purchased water minus Stewartsville purchased water
- (12) Andrew #2 Water Purchased minus water sold to DeKalb County #1

County population portions served by each PWSD

Public Water Supply District	District Population in 2006 (1)	County served by the PWSD (2)	2006 County Population (3)	% of County Population served by the PWSD (4)	District Annual Population Change (cap) (5)	District 2030 Projected Population (6)
Andrew County PWSD #1	6000	Andrew County	17,119	35%	37	6,900
Andrew County PWSD #2	3000	Andrew County	17,119	18%	18	3,500
Andrew County PWSD #4	732	Andrew County	17,119	4%	4	840
Buchanan County PWSD #1	2000	Buchanan County	85,998	2%	0	2,000
Clinton County PWSD #1	950	Clinton County	19,917	5%	7	1,200
Davies County PWSD #1	2628	Daviess County	8,016	33%	0	2,700
DeKalb County PWSD #1	10000	DeKalb County	12,058	83%	64	11,600
Gentry County #1	2000	Gentry County	6,861	29%	0	2,000
Gentry County #2	600	Gentry County	6,861	9%	0	600
Nodaway County #1	6500	Nodaway County	21,912	30%	0	6,500

(1) 2006 population from Ref No. 4; Phase I report

(2) County that consumes most of the Public Water District supply

(3) Entire County population in 2006, linear extrapolation of 2000 census data with revised projections

(4) PWSD Population / County Population

(5) District Annual Population Change (County Annual Population change times Percentage of County Population served by the PWSD)

(6) District 2030 Projected Population based on 2006 Phase I Report

Estimated Future Demands

District / City	Current Water Demands			2030 Future Projected Water Demand		
	Annual Demand (MG)	Avg. Day (MGD)	Max. Day (MGD) (1)	Annual Demand (MG)	Avg. Day (MGD)	Max. Day (MGD) (1)
Andrew County PWSD #1	186	0.51	1.02	213	0.58	1.17
Andrew County PWSD #2	133	0.36	0.73	154	0.42	0.84
Andrew County PWSD #4	14	0.04	0.07	16	0.04	0.09
Buchanan County PWSD #1	65	0.18	0.35	65	0.18	0.35
City of Albany	81	0.22	0.44	92	0.25	0.50
City of Barnard	8	0.02	0.04	8	0.02	0.05
City of Bolckow	18	0.05	0.10	18	0.05	0.10
City of Cameron	488	1.34	2.68	607	1.66	3.33
City of Gallatin	138	0.38	0.75	142	0.39	0.78
City of Grant City	46	0.13	0.25	46	0.13	0.25
City of King City	37	0.10	0.20	37	0.10	0.20
City of Maitland	9	0.03	0.05	9	0.03	0.05
City of Maysville	32	0.09	0.17	35	0.10	0.19
City of Ravenwood	10	0.03	0.06	12	0.03	0.07
City of Stanberry	41	0.11	0.23	41	0.11	0.23
City of Stewartville	19	0.05	0.10	23	0.06	0.13
Clinton County PWSD #1	23	0.06	0.12	28	0.08	0.16
Davies County PWSD #1	57	0.16	0.31	59	0.16	0.32
DeKalb County PWSD #1	257	0.70	1.41	295	0.81	1.62
Gentry County #1	46	0.13	0.25	46	0.13	0.25
Gentry County #2	18	0.05	0.10	18	0.05	0.10
Nodaway County #1 (2)	164	0.45	0.90	110	0.30	0.60
TOTAL (MG)	1,889	5.18	10.35	2,074	5.68	11.36
			15% increase	2,385	6.53	13.07
			20% increase	2,489	6.82	13.64
				<i>Annual Percentage Change:</i>		<i>0.47%</i>
Phase I Totals (MG)	1,289	3.53	7.06	1,383	3.79	7.58
			15% increase	1,590	4.36	8.71
			20% increase	1,660	4.55	9.09
				<i>Annual Percentage Change:</i>		<i>0.35%</i>
City of Plattsburg	337	0.92	1.85	378	1.04	2.07
City of Savannah (2)	168	0.46	0.92	206	0.56	1.13
TOTAL (MG)	505	1	3	584	2	3
				<i>Annual Percentage Change:</i>		<i>0.75%</i>

(1) Max Day = Avg. Day (gpd) x 2.0

(2) Assumption: Nodaway will only purchase 0.3 MGD (Avg. Day) and 0.6 MGD (Max. Day) from the Commission to supply current unserved areas.

CDM Calculation Form (Excel)

Client: GNWWC
 Project: Stage 1 PER
 Detail: Cost Comparison

Job # 78941
 Checked By: A. Szerwinski
 Date: 05/10/11
 Reviewed By: A. Casey
 Date: 05/10/11

Calc. By: SAS
 Date: 05/09/11
 Calc. No.: --
 Revision#:
 Date:

Calculation Brief Title: Determine the Annual Cost Comparison for the three water supply sources for the Stage 1 Pipeline.

1.0 Purpose/Objective

Determine the Annual Cost Comparison for the three water supply sources for the Stage 1 Pipeline.

2.0 Procedure

- 1 Summarize OPCC data from Bartlett & West
- 2 Summarize water rate data from the various water suppliers and project 2013 costs.
- 3 Determine O&M, Debt Service, Replacement Costs, and Staffing Costs

3.0 References/Data Sources

- 1 2010 Water Rates from Missouri American date July 1, 2010.
- 2 January 24, 2011 B&West letter regarding ACWWC
- 3 "Drinking Water Facilities Plan Water Treatment Plant Improvements" City of Savannah, MO prepared by Casey Patton from B&West. Received copy January 2011.
- 4 "Section 8 Conceptual Plan Preliminary Cost Estimate" from Phase II Feasibility Study dated March 6, 2009.
- 5 CDM 12-17-10 2030 Demands Summary Table.pdf and GNW Demand Handout.xls
- 6 OPCCs provided by Bartlett & West on 2-18-11 for each alternative including contingency, land acquisition, engineering & legal

4.0 Assumptions and Limitations

- 1 Assumptions are summarized throughout the document.

5.0 Calculations

1. See the following sheets.

Savannah Alternative Summary
 Missouri American Alternative Summary
 ACWWC Alternative Summary

Current Water Demands

Annual Water Purchased	Annual Water Sales	
(Ref. 5)	(Ref. 5)	
654,000	623,000	kgal

Water Sales = Water Purchased / (1 + Percentage of Unaccounted Water (Assumed to be 5% of total purchase volume))

Annual Est. Water Purchase Volume (kgal)	654,000
Savannah Annual Purchase Volume (kgal)	328,500
Missouri American Annual Purchase Volume (kgal)	325,500
Missouri American Avg. Monthly Purchase Volume (kgal)	27,125
Annual Est. Water Sales Volume (kgal)	623,000
Savannah Cost to Purchase Water (\$/kgal)	\$5.93
MoAM Cost to Purchase Water (\$/kgal)	\$4.95 to \$2.19
OPCC, Ref 6.	\$52,200,000
Savannah Cost of Water Per Year	\$1,900,000
Missouri American Cost of Water Per Year	\$805,146
Est. Annual Debt Service (4)	\$3,200,000
Est. O&M Costs	\$433,000
Est. Replacement Costs	\$504,000
Estimated Annual Costs	\$6,800,000
Cost per kgal (5)	\$10.91

- (1) Current Avg. Day for Stage 1 Pipeline Customers x 1.05 to account for system water loss x 365 days/year
- (2) Assumes buying 0.9 MGD 365 days per year from Savannah
- (3) Total Est. Water Purchase - Savannah Purchase Volume
- (4) MoAm Annual Purchase / 12 months per year
- (5) Current Avg. Day for Stage 1 Pipeline Customers x 365 days/year
- (6) Cost to Purchase Water (\$/kgal) x Annual Est. Water Purchase Volume (kgal). Based on current water demands
- (6) Cost to Purchase Water (\$/kgal) x Annual Est. Water Purchase Volume (kgal). Based on current water demands
- (7) Estimated based on 33 years at 4.75% interest, assuming even payments
- (8) Cost per kgal = Estimated Annual Costs / Annual Est. Sales Volume (kgal)

6.0 Conclusions/Results

Combined Rate for Missouri American and Savannah is \$10.91 per 1,000 gallons

Description:
Savannah Alternative Background Calculations

Cost of Service Number

	Total Sales Capacity of WTP (MGD)	Water Cost (1) (\$/kgal)	Purchase Cost of Water (2) (\$/kgal)	
Option 1	Up to 0.9	\$4.27	\$5.93	**Selected
Option 2	Up to 2.7	\$6.02	\$8.36	
Option 3	Up to 3.9	\$3.77	\$5.24	

(see pg. 8 - 9) (see pg. 12)

*Based on "Drinking Water Facilities Plan, Water Treatment Plant Improvements, City of Savannah, MO" - Ref. 3

*Capacities from text on pages 8 and 9 - Ref. 3

(1) These numbers exclude City Admin Costs per the report. Calculations also show no "profit" to the city.

(2) ASSUMPTION: Increased purchase cost of water by 20% from what was in report to consider omitted costs, ammonia dosage and potential "profit"

(3) Increased water rates to 2013 numbers: Cost of Water * (1+0.05)^3. This assumes 5% inflation.

Replacement Costs

OPCC Break Down - Provided by B&West (w/o Davies 1 Extension)		(Assumed Values)	
		Replacement Costs	Proposed Life Span (yrs.)
Ammonia Feed Facility	\$70,000 (Ref. 3, pg. 26)	\$3,000	20
Transmission Lines	\$31,840,000	\$319,000	60
Elevated Water Storage Tanks	\$1,520,000	\$23,000	40
Pump Stations	\$1,330,000	\$40,000	20
Total	\$34,760,000	\$385,000	

Replacement Cost = 2013 OPCC Value * (1-0.4) / Proposed Life Span; 40% of initial OPCC is assumed as a one time expense

Proposed lifespan (Ref. 4): 20 years for pump stations, 40 years for storage facilities, 60 years for pipelines

O&M Costs

O&M Cost Summary per year	
Staffing	\$210,000
Electrical	\$89,000
Storage Tanks	\$20,000
Piping	\$15,000
Total O&M	\$334,000

Staffing Assumptions: 1 full time and 1 part time ADMIN and 2 full time field service employees, Employee cost is \$60,000 per employee per year

\$210,000

Electrical: Assume PS operates 25% of the time on an annual basis per Phase II O&M assumptions

HP	KW	KW*HR	Cost / KWH	Annual Cost
450	335.565	734887.35	0.12	\$88,186

(OPCC report from B&West)

Storage Tanks: Assumed \$150K every 15 years for repainting and maintenance
 \$10,000 per tank

No. of Tanks **2** (OPCC report from B&West)

Pipelines: Assume 1 break every 20 miles and \$3000 to fix each break

Total Pipeline Mileage	85.27 miles
Total Breaks Per Year	5
Total Line O&M	\$15,000

w/o Davies 1 transmission main (OPCC report from B&West)

OPCC

Construction Cost	\$34,760,000	(Const. Cost + Ammonia Feed Facility)
Land Acquisition	\$1,740,000	
Contingency	\$6,940,000	
Total OPCC	\$43,400,000	

Description:
Missouri American Alternative Background Calculations

Cost of Service Number

	1,000 Gallons/ Month	Public Authority / Sale for Resale Current Rates (\$/kgal)	2013 Projection (\$/kgal)
Monthly Minimum Charge (1)		\$1,124.62	\$1,301.89
For the first	100	\$4,2794	\$4.95
For the next	1900	\$3,3234	\$3.85
For the next	3000	\$2,7691	\$3.21
For everything over	5000	\$1,8886	\$2.19

*Cost per table provided by Missouri American dated July 1, 2010
 Inflated cost by 5% per year to 2013 numbers: = 2010 Rate(1.05)^3
 (1) 2" meter size was chosen for the monthly charge.

Replacement Costs

OPCC Break Down - Provided by B&West (w/o Davies 1 Ex		(Assumed Values)	
		Replacement Costs	Proposed Life Span (yrs.)
Transmission Lines	\$37,050,000	\$371,000	60
Water Storage Tanks	\$3,320,000	\$50,000	40
Pump Stations	\$1,330,000	\$40,000	20
Total	\$41,700,000	\$461,000	

Replacement Cost = 2013 OPCC Value * (1-0.4) / Proposed Life Span; 40% of initial OPCC is assumed as a one time expense
 Proposed lifespan (Ref. 4): 20 years for pump stations, 40 years for storage facilities, 60 years for pipelines

O&M Costs

O&M Cost Summary per year	
Summary:	
Staffing	\$210,000
Electrical	\$89,000
Storage Tanks	\$30,000
Piping	\$15,000
Total O&M	\$344,000

Staffing Assumptions: 1 full time and 1 part time ADMIN and 2 full time field service employees, Employee cost is \$60,000 per employee per year
\$210,000

Electrical				
Assume PS operates 25% of the time				
HP	KW	KW*HR	Cost / KWH	Annual Cost
450	335.565	734887.35	0.12	\$88,186

(OPCC report from B&West)

Storage Tanks Assumed \$150K every 15 years for repainting and maintenance No. of Tanks **3** (OPCC report from B&West)
 \$10,000 per tank

Pieplines: Assume 1 break every 20 miles and \$3000 to fix each break
 Total Pipeline Mileage **90.68** miles w/o Davies 1 transmission main (OPCC report from B&West)
 Total Breaks Per Year 5
 Total Line O&M \$15,000

OPCC

Construction Cost	\$41,700,000
Land Acquisition	\$2,090,000
Contingency	\$8,340,000
Total OPCC	\$52,130,000

CDM Calculation Form (Excel)

Job # 78941
 Checked By: A. Szerwinski
 Date: 02/22/11 5/9/11
 Reviewed By: A. Casey
 Date: 05/10/11

Calc. By: SAS
 Date: 02/21/11
 Calc. No.: --
 Revision#: 1
 Date: _____

Calculation Brief Title: Determine the Annual Cost Comparison for the three water supply sources for the Stage 1 Pipeline.

1.0 Purpose/Objective Determine the Annual Cost Comparison for the three water supply sources for the Stage 1 Pipeline.

2.0 Procedure

- 1 Summarize OPCC data from Bartlett & West
- 2 Summarize water rate data from the various water suppliers and project 2013 costs.
- 3 Determine O&M, Debt Service, Replacement Costs, and Staffing Costs

3.0 References/Data Sources

- 1 2010 Water Rates from Missouri American date July 1, 2010.
- 2 January 24, 2011 B&West letter regarding ACWWC
- 3 "Drinking Water Facilities Plan Water Treatment Plant Improvements" City of Savannah, MO prepared by Casey Patton from B&West. Received copy January 2011.
- 4 "Section 8 Conceptual Plan Preliminary Cost Estimate" from Phase II Feasibility Study dated March 6, 2009.
- 5 CDM 12-17-10 2030 Demands Summary Table.pdf and GNW Demand Handout.xlsx
- 6 OPCCs provided by Bartlett & West on 2-18-11 for each alternative including contingency, land acquisition, engineering & legal

4.0 Assumptions and Limitations

- 1 Assumptions are summarized throughout the document.

5.0 Calculations

1. See the following sheets. Savannah Alternative Summary
 Missouri American Alternative Summary
 ACWWC Alternative Summary

Current Water Demands

Annual Water Purchased	Annual Water Sales	
(Ref. 5)	(Ref. 5)	
654,000	623,000	kgal

Water Sales = Water Purchased / (1 + Percentage of Unaccounted Water (Assumed to be 5% of total purchase volume))

Comparison Table

	Alternative 1 Savannah	Alternative 2 Missouri American	Alternative 3 ACWWC
Annual Est. Water Purchase Volume (kgal) (1)	654,000	654,000	654,000
Annual Est. Water Sales Volume (kgal) (2)	623,000	623,000	623,000
Cost to Purchase Water (\$/kgal)	\$5.24	\$4.95 to \$2.19	\$5.11
Cost of Water Per Year (3)	\$3,400,000	\$1,500,000	\$3,400,000
OPCC, Ref 6.	\$43,400,000	\$52,100,000	\$88,500,000
Est. Annual Debt Service (4)	\$2,700,000	\$3,200,000	\$5,400,000
Est. O&M Costs	\$334,000	\$344,000	\$379,000
Est. Replacement Costs	\$385,000	\$470,000	\$751,000
Estimated Annual Costs	\$6,800,000	\$5,500,000	\$9,900,000
Cost per kgal (5)	\$10.91	\$8.83	\$15.89

(1) Current Avg. Day for Stage 1 Pipeline Customers x 1.05 to account for system water loss x 365 days/year
 (2) Current Avg. Day for Stage 1 Pipeline Customers x 365 days/year
 (3) Cost to Purchase Water (\$/kgal) x Annual Est. Water Purchase Volume (kgal). Based on current water demands
 (4) Estimated based on 33 years at 4.75% interest, assuming even payments
 (5) Cost per kgal = Estimated Annual Costs / Annual Est. Sales Volume (kgal)

6.0 Conclusions/Results

1 Missouri American is the least cost supplier based on both OPCC and annual costs.
 Summary Table based on MoAM selected alternative

	100% Loan Money	80% Loan/20% Grant	50% Grant/Loan
Est. Annual Debt Service (4)	\$3,200,000	\$2,600,000	\$1,600,000
Est. O&M Costs	\$340,000	\$340,000	\$340,000
Est. Replacement Costs	\$470,000	\$470,000	\$470,000
Estimated Annual Costs	\$5,500,000	\$4,900,000	\$3,900,000
Cost per kgal (5)	\$8.83	\$7.87	\$6.26
Customer Monthly Wholesale Cost (5,000 gal)	\$44.14	\$39.33	\$31.30



Description:

Savannah Alternative Background Calculations

Cost of Service Number

	Quantity Available for Sale (MGD)	Water Cost (1) (\$/kgal)	Purchase Cost of (\$/kgal)
Option 1	Up to 0.9	\$4.27	\$5.93
Option 2	Up to 2.7	\$6.02	\$8.36
Option 3	Up to 3.9	\$3.77	\$5.24

(see pg. 8 - 9) (see pg. 12)

*Based on "Drinking Water Facilities Plan, Water Treatment Plant Improvements, City of Savannah, MO" - Ref. 3

*Capacities from text on pages 8 and 9 - Ref. 3

(1) These numbers exclude City Admin Costs per the report. Calculations also show no "profit" to the city.

(2) ASSUMPTION: Increased purchase cost of water by 20% from what was in report to consider omitted costs, ammonia dosage and potential "profit"

(3) Increased water rates for 3 years inflation: Cost of Water * (1+0.05)^3. This assumes 5% inflation.

Replacement Costs

OPCC Break Down - Provided by B&West (w/o Davies 1 Extension)

			Replacement Costs	Proposed Life Span (yrs.)
Ammonia Feed Facility	\$70,000	(Ref. 3, pg. 26)	\$3,000	20
Transmission Lines	\$31,840,000		\$319,000	60
Elevated Water Storage Tanks	\$1,520,000		\$23,000	40
Pump Stations	\$1,330,000		\$40,000	20
Total	\$34,760,000		\$385,000	

Replacement Cost = 2013 OPCC Value * (1-0.4) / Proposed Life Span; 40% of initial OPCC is assumed as a one time expense

Proposed lifespan (Ref. 4): 20 years for pump stations, 40 years for storage facilities, 60 years for pipelines

O&M Costs

O&M Cost Summary per year	
Staffing	\$210,000
Electrical	\$89,000
Storage Tanks	\$20,000
Piping	\$15,000
Total O&M	\$334,000

Staffing Assumptions: 1 full time and 1 part time ADMIN and 2 full time field service employees, Employee cost is \$60,000 per employee per year

\$210,000

Electrical: Assume PS operates 25% of the time on an annual basis per Phase II O&M assumptions

HP	KW	KW*HR	Cost / KWH	Annual Cost
450	335.565	734887.35	0.12	\$88,186

(OPCC report from B&West)

Storage Tanks: Assumed \$150K every 15 years for repainting and maintenance \$10,000 per tank

No. of Tanks **2** (OPCC report from B&West)

Pipelines: Assume 1 break every 20 miles and \$3000 to fix each break

Total Pipeline Mileage	85.27 miles
Total Breaks Per Year	5
Total Line O&M	\$15,000

w/o Davies 1 transmission main (OPCC report from B&West)

OPCC

Construction Cost	\$34,760,000	(Const. Cost + Ammonia Feed Facility)
Land Acquisition	\$1,740,000	
Contingency	\$6,940,000	
Total OPCC	\$43,440,000	

Description:
Missouri American Alternative Background Calculations

Cost of Service Number

	1,000 Gallons/ Month	Public Authority / Sale for Resale Current Rates (\$/kgal)	2013 Projection (\$/kgal)
Monthly Minimum Charge (1)		\$1,124.62	\$1,301.89
For the first	100	\$4,2794	\$4.95
For the next	1900	\$3,3234	\$3.85
For the next	3000	\$2,7691	\$3.21
For everything over	5000	\$1,8886	\$2.19

*Cost per table provided by Missouri American dated July 1, 2010
 Inflated cost by 5% per year to 2013 numbers: = 2010 Rate(1.05)^3
 (1) 2" meter size was chosen for the monthly charge.

Replacement Costs

OPCC Break Down - Provided by B&West (w/o Davies 1 Ex		(Assumed Values)	
		Replacement Costs	Proposed Life Span (yrs.)
Transmission Lines	\$37,050,000	\$380,000	60
Water Storage Tanks	\$3,320,000	\$50,000	40
Pump Stations	\$1,330,000	\$40,000	20
Total	\$41,700,000	\$470,000	

Replacement Cost = 2013 OPCC Value * (1-0.4) / Proposed Life Span; 40% of initial OPCC is assumed as a one time expense
 Proposed lifespan (Ref. 4): 20 years for pump stations, 40 years for storage facilities, 60 years for pipelines

O&M Costs

O&M Cost Summary per year	
Summary:	
Staffing	\$210,000
Electrical	\$89,000
Storage Tanks	\$30,000
Piping	\$15,000
Total O&M	\$344,000

Staffing Assumptions: 1 full time and 1 part time ADMIN and 2 full time field service employees, Employee cost is \$60,000 per employee per year
\$210,000

Electrical				
Assume PS operates 25% of the time				
HP	KW	KW*HR	Cost / KWH	Annual Cost
450	335.565	734887.35	0.12	\$88,186

(OPCC report from B&West)

Storage Tanks Assumed \$150K every 15 years for repainting and maintenance No. of Tanks **3** (OPCC report from B&West)
 \$10,000 per tank

Pieplines: Assume 1 break every 20 miles and \$3000 to fix each break
 Total Pipeline Mileage **90.68** miles w/o Davies 1 transmission main (OPCC report from B&West)
 Total Breaks Per Year 5
 Total Line O&M \$15,000

OPCC

Construction Cost	\$41,700,000
Land Acquisition	\$2,100,000
Contingency	\$8,300,000
Total OPCC	\$52,100,000



Description:
ACWWC Alternative Background Calculations

Cost of Service Number

(2) 6 MGD is total volume available. Cost of water is \$4.00/kgal in Nov. 2008, increased by 5% per year to 2013 costs.

Cost of Water = \$4.00 x 1.05^(2013-2008) = \$5.11

Replacement Costs

CC Break Down - Provided by B&West (w/o Davies 1 Extens) (Assumed Values)

		Replacement Costs	Proposed Life Span (yrs.)
Transmission Lines	\$67,530,000	\$676,000	60
Elevated Water Storage Tanks	\$1,520,000	\$23,000	40
Pump Stations	\$1,730,000	\$52,000	20
Total	\$70,780,000	\$751,000	

Replacement Cost = 2013 OPCC Value * (1-0.4) / Proposed Life Span; 40% of initial OPCC is assumed as a one time expense
 Proposed lifespan (Ref. 4): 20 years for pump stations, 40 years for storage facilities, 60 years for pipelines

O&M Costs

O&M Cost Summary per year

Staffing	\$210,000
Electrical	\$128,000
Storage Tanks	\$20,000
Piping	\$21,000
Total O&M	\$379,000

Staffing Assumptions: 1 full time and 1 part time ADMIN and 2 full time field service employees, Employee cost is \$60,000 per employee per year
\$210,000

Electrical: Assume PS operates 25% of the time

HP	KW	KW*HR	Cost / KWH	Annual Cost
650	484.705	1061503.95	0.12	\$127,380

(OPCC report from B&West)

Storage Tanks: Assumed \$150K every 15 years for repainting and maintenance \$10,000 per tank No. of Tanks **2** (OPCC report from B&West)

Pipelines: Assume 1 break every 20 miles and \$3000 to fix each break
 Total Pipeline Mileage **126.78** miles w/o Davies 1 transmission main (OPCC report from B&West)
 Total Breaks Per Year 7
 Total Line O&M \$21,000

OPCC

Construction Cost	\$70,780,000
Contingency	\$3,540,000
Land Acquisition	\$14,160,000
Total OPCC	\$88,480,000

Appendix B
Modeling Results

Date: 10 May 2011
 By: Molly Pesce
 Checked By: Bruce Hattig
 Re: Pressure Table for Stage I

Community	Elevation (feet)	Minimum Pressure (psi)	Maximum Pressure (psi)	HGL _{Min} (feet) - Calculated	HGL _{Max} (feet) - Calculated	HGL _{Min} (feet) - Modeled	HGL _{Max} (feet) - Modeled
Albany	950	63	123	1096	1235	1095	1235
Andrew Co PWSD # 1	1020	73	132	1189	1325	1188	1325
Andrew Co PWSD #4	1010	74	117	1181	1281	1181	1280
Barnard	1010	74	117	1181	1281	1181	1280
Bolckow	948	103	149	1186	1293	1185	1292
Daviess Co PWSD #1	780	183	197	1203	1236	1201	1235
DeKalb Co PWSD #1 - 2nd Pt (25%)	1053	55	92	1181	1266	1181	1265
Gentry Co PWSD #1	950	63	123	1096	1235	1095	1235
Gentry Co PWSD #2	948	83	124	1140	1235	1140	1235
King City	1081	60	67	1220	1236	1220	1235
Nodaway Co PWSD #1	1131	37	46	1217	1238	1217	1236
Stanberry	904	103	143	1142	1235	1142	1235

*Max Pressure was found using 50% of peak day supply and zero demand. It was assumed that pump speed will be controlled so the critical node does not exceed 200 psi.

ACWWC Input

[TITLE]

[JUNCTIONS]

;ID	Elev	Demand	Pattern
10	857.809601	0	;New Junction
102	1044.269305	0	;New Junction
104	1095.411482	0	;New Junction
106	903.047204	0	;New Junction
108	1073.979188	0	;New Junction
110	905.820219	0	;New Junction
112	1046.223409	0	;New Junction
114	866.960169	0	;New Junction
116	1105.922624	0	;New Junction
118	939.736083	0	;New Junction
12	1081.236626	160	;King City
120	828.322389	623	;Gallatin
122	1052.862488	323	;DeKalb (25%)
124	1142.690699	0	;New Junction
126	966.687472	0	;New Junction
128	974.419391	0	;New Junction
132	1089.919218	0	;New Junction
134	1085.452118	0	;New Junction
136	1009.968566	112	;Barnard & Andrew
4			
138	968.939746	0	;New Junction
140	948.421877	40	;Maitland
142	1142.219321	0	;New Junction
144	971.030920	0	;New Junction
146	1153.426120	0	;New Junction
148	1027.710715	56	;Ravenwood
150	947.524072	80	;Bolckow & Andrew
4			
152	1059.031783	0	;New Junction
154	773.299736	256	;Davies 1
156	780.384461	0	;New Junction
158	779.610107	0	;New Junction
160	904.443523	184	;Stanberry
162	835.894863	0	;New Junction
164	950.172635	0	;
166	927.761637	0	;New Junction
168	1024.644839	200	;Grant City
170	928.562323	0	;New Junction
172	1122.841860	0	;New Junction
174	1098.435806	0	;New Junction
176	933.329393	0	;New Junction
178	950.510050	0	;New Junction
180	1061.069591	0	;New Junction
182	1120.462428	0	;New Junction
184	891.121420	0	;New Junction
186	997.639586	0	;New Junction
188	903.394734	0	;New Junction
190	1005.020974	0	;New Junction
192	1034.991181	0	;New Junction
194	981.096012	-4215	;ACWWC
196	1031.436401	0	;New Junction
198	1100.310413	0	;New Junction
200	886.298880	0	;New Junction
28	931.309406	599	;Gentry 1 &
Albany			
30	840.189502	0	;New Junction
32	1020.039770	934	;Andrew 1
42	1122.846663	0	;

147	90	92	15446.070030	12
140.000000	0.000000	Open	;New Pipe	
155	12	102	23242.244643	16
140.000000	0.000000	Open	;New Pipe	
157	104	106	25129.350635	20
140.000000	0.000000	Open	;New Pipe	
159	108	110	21670.464670	20
140.000000	0.000000	Open	;New Pipe	
161	48	78	15924.247181	24
140.000000	0.000000	Open	;New Pipe	
163	112	68	4396.201801	24
140.000000	0.000000	Open	;New Pipe	
165	114	116	41715.258354	4
140.000000	0.000000	Open	;New Pipe	
167	118	120	53895.626546	12
140.000000	0.000000	Open	;New Pipe	
169	102	104	9735.164451	16
140.000000	0.000000	Open	;New Pipe	
171	122	102	12017.922714	8
140.000000	0.000000	Open	;New Pipe	
173	124	126	8498.010350	8
140.000000	0.000000	Open	;New Pipe	
175	12	128	72241.288684	12
140.000000	0.000000	Open	;New Pipe	
189	132	42	24084.498481	12
140.000000	0.000000	Open	;New Pipe	
191	134	132	5272.301439	16
140.000000	0.000000	Open	;New Pipe	
193	46	134	3225.361603	24
140.000000	0.000000	Open	;New Pipe	
195	78	112	10166.340821	24
140.000000	0.000000	Open	;New Pipe	
197	80	136	1991.774638	6
140.000000	0.000000	Open	;New Pipe	
199	138	112	7242.862487	4
140.000000	0.000000	Open	;New Pipe	
201	116	138	7019.142244	4
140.000000	0.000000	Open	;New Pipe	
203	140	114	2718.890522	4
140.000000	0.000000	Open	;New Pipe	
205	142	66	11822.619789	24
140.000000	0.000000	Open	;New Pipe	
207	64	142	1346.075690	24
140.000000	0.000000	Open	;New Pipe	
209	86	84	2063.121682	24
140.000000	0.000000	Open	;New Pipe	
211	62	144	6025.010030	8
140.000000	0.000000	Open	;New Pipe	
213	144	146	20119.608793	8
140.000000	0.000000	Open	;New Pipe	
215	146	124	11968.320398	8
140.000000	0.000000	Open	;New Pipe	
217	126	148	6806.791630	8
140.000000	0.000000	Open	;New Pipe	
219	82	150	4630.219333	6
140.000000	0.000000	Open	;New Pipe	
221	110	134	15674.961160	20
140.000000	0.000000	Open	;New Pipe	
223	152	108	1519.641879	20
140.000000	0.000000	Open	;New Pipe	
225	106	152	9040.789911	20
140.000000	0.000000	Open	;New Pipe	

229		128		154		14806.835473	12
	140.000000		0.000000		Open	;New Pipe	
231		156		158		696.853118	12
	140.000000		0.000000		Open	;New Pipe	
233		154		156		18054.998208	12
	140.000000		0.000000		Open	;New Pipe	
235		158		118		37390.425439	12
	140.000000		0.000000		Open	;New Pipe	
237		58		160		1536.532116	12
	140.000000		0.000000		Open	;New Pipe	
239		160		10		6239.234188	12
	140.000000		0.000000		Open	;New Pipe	
241		56		60		524.540342	12
	140.000000		0.000000		Open	;New Pipe	
243		92		54		1569.151793	12
	140.000000		0.000000		Open	;New Pipe	
245		162		90		6489.571040	12
	140.000000		0.000000		Open	;New Pipe	
247		164		162		7272.475229	12
	140.000000		0.000000		Open	;New Pipe	
249		30		164		5883.562452	12
	140.000000		0.000000		Open	;New Pipe	
251		90		94		36600.129687	8
	140.000000		0.000000		Open	;New Pipe	
253		96		166		12574.225393	8
	140.000000		0.000000		Open	;New Pipe	
255		166		168		12642.977728	8
	140.000000		0.000000		Open	;New Pipe	
257		170		172		41751.192219	30
	140.000000		0.000000		Open	;New Pipe	
259		174		86		38342.847653	24
	140.000000		0.000000		Open	;New Pipe	
261		176		178		13315.076526	30
	140.000000		0.000000		Open	;New Pipe	
263		180		182		3067.083289	30
	140.000000		0.000000		Open	;New Pipe	
265		184		186		9553.343107	30
	140.000000		0.000000		Open	;New Pipe	
267		188		190		7658.702192	30
	140.000000		0.000000		Open	;New Pipe	
269		192		194		1307.570770	30
	140.000000		0.000000		Open	;New Pipe	
271		182		192		3028.512640	30
	140.000000		0.000000		Open	;New Pipe	
273		180		176		10741.721387	30
	140.000000		0.000000		Open	;New Pipe	
275		178		184		14235.383343	30
	140.000000		0.000000		Open	;New Pipe	
277		186		188		7146.001452	30
	140.000000		0.000000		Open	;New Pipe	
279		190		196		1011.387448	30
	140.000000		0.000000		Open	;New Pipe	
281		196		170		7485.719735	30
	140.000000		0.000000		Open	;New Pipe	
283		172		198		3074.951661	24
	140.000000		0.000000		Open	;New Pipe	
285		198		200		27482.854480	24
	140.000000		0.000000		Open	;New Pipe	
287		200		174		14848.861700	24
	140.000000		0.000000		Open	;New Pipe	
1		1		12		1000	20
	100		0		Open	;	

2		2		84		1000	24
	100		0		Open	;	
5		3		46		24186	24
	140		0		Open	;	
4		4		96		1000	8
	140		0		Open	;	
7		96		5		1000	8
	140		0		Open	;	
8		12		6		20000	16
	140		0		Open	;	
9		6		10		35000	12
	140		0		Open	;	

[PUMPS]

;ID	Node1	Node2	Parameters
3	44	3	HEAD 2 ;
6	94	4	HEAD 3 ;

[VALVES]

;ID	Node1	Node2	Diameter	Type	Setting
	MinorLoss				

[TAGS]

[DEMANDS]

;Junction	Demand	Pattern	Category
-----------	--------	---------	----------

[STATUS]

;ID	Status/Setting
-----	----------------

[PATTERNS]

;ID	Multipliers
-----	-------------

[CURVES]

;ID	X-Value	Y-Value
;PUMP:		
1	0	2000
1	3500	500
1	3700	10
;PUMP:		
2	0	2000
2	3300	500
2	3500	10
;PUMP:		
3	0	2000
3	180	500
3	210	10

[CONTROLS]

[RULES]

[ENERGY]

Global Efficiency	70.000000
Global Price	0
Demand Charge	0.000000

[EMITTERS]

;Junction	Coefficient
-----------	-------------

[QUALITY]

;Node	InitQual
-------	----------

[SOURCES]
;Node Type Quality Pattern

[REACTIONS]
;Type Pipe/Tank Coefficient

[REACTIONS]
Order Bulk 1.000000
Order Tank 1.000000
Order Wall 1
Global Bulk 0.000000
Global Wall 0.000000
Limiting Potential 0
Roughness Correlation 0

[MIXING]
;Tank Model

[TIMES]
Duration 0
Hydraulic Timestep 1:00
Quality Timestep 0:05
Pattern Timestep 1:00
Pattern Start 0:00
Report Timestep 1:00
Report Start 0:00
Start ClockTime 12 am
Statistic None

[REPORT]
Status Yes
Summary No
Page 0

[OPTIONS]
Units GPM
Headloss H-W
Specific Gravity 1.000000
Viscosity 1
Trials 40
Accuracy 0.001
CHECKFREQ 2
MAXCHECK 10
DAMPLIMIT 0
Unbalanced Stop
Pattern 1
Demand Multiplier 1.000000
Emitter Exponent 0.500000
Quality None mg/L
Diffusivity 1
Tolerance 0.001000

[COORDINATES]
;Node X-Coord Y-Coord
10 2780454.89 1469510.73
102 2758855.25 1415487.11
104 2749550.50 1416474.04
106 2724989.51 1418416.59
108 2714429.22 1418470.25
110 2696806.80 1412687.02
112 2685645.66 1468909.31

114	2629679.73	1470035.78
116	2671386.54	1469196.31
118	2907800.85	1392181.46
12	2781399.77	1415871.36
120	2937499.81	1369053.29
122	2758291.93	1403351.44
124	2728398.36	1521190.79
126	2736884.73	1521398.55
128	2854296.86	1414561.68
132	2682202.70	1405422.22
134	2682206.46	1410704.93
136	2698698.88	1460800.86
138	2678404.26	1469055.06
140	2626672.75	1469804.13
142	2684216.82	1509395.43
144	2696316.10	1521755.47
146	2716433.19	1521465.22
148	2740714.13	1524252.45
150	2698698.88	1437649.60
152	2715948.84	1418462.53
154	2869158.13	1415256.95
156	2887130.29	1413195.54
158	2887826.54	1413166.58
160	2777682.03	1473146.63
162	2815686.98	1483549.80
164	2821774.87	1486461.79
166	2815057.93	1560610.38
168	2815537.69	1573244.25
170	2554822.64	1519247.14
172	2598376.77	1518679.00
174	2640039.67	1522905.78
176	2525877.95	1551604.43
178	2539189.66	1551324.42
180	2515216.46	1552148.21
182	2512231.52	1551760.44
184	2538835.67	1537173.46
186	2538732.03	1527625.43
188	2539082.80	1520713.51
190	2546334.08	1519240.56
192	2509951.47	1549792.46
194	2505771.74	1548689.89
196	2547342.52	1519306.45
198	2599601.97	1518266.50
200	2627073.66	1517649.89
28	2835817.64	1489590.49
30	2827717.27	1486575.07
32	2687123.25	1354905.30
42	2687123.25	1383630.00
44	2685043.39	1437683.52
46	2683072.77	1413773.36
48	2684979.62	1443223.05
54	2792161.36	1483987.94
56	2777975.02	1479337.24
58	2777892.87	1474990.17
60	2777965.11	1478812.79
62	2690291.36	1521812.16
64	2684321.60	1510552.18
66	2683883.74	1497590.61
68	2685780.51	1473303.44
78	2685343.99	1458750.75
80	2696769.35	1459040.35
82	2694111.67	1437726.71
84	2680596.70	1522064.72

86	2678223.19	1522015.53
88	2678308.00	1522963.04
90	2809198.39	1483633.21
92	2793758.24	1483910.74
94	2813748.25	1518368.96
96	2814621.91	1548043.88
3	2685041.54	1436662.60
4	2814010.20	1519216.20
6	2782615.40	1433302.64
1	2779299.55	1409353.62
2	2680692.35	1524681.18
5	2813381.31	1547910.45

[VERTICES]

;Link	X-Coord	Y-Coord
107	2835625.24	1489332.96
107	2831600.54	1489269.37
107	2830840.72	1488483.39
107	2829944.63	1486612.75
115	2686924.81	1382209.92
115	2687120.92	1381948.85
115	2687589.85	1381104.14
115	2687575.85	1376142.57
115	2687518.17	1370879.82
115	2687535.91	1368858.24
115	2687437.40	1367955.26
115	2687374.51	1367832.40
115	2687411.35	1367573.18
115	2687474.10	1367062.63
115	2687510.74	1366007.69
115	2687488.08	1364456.38
115	2687511.28	1364042.65
115	2687608.48	1363573.32
115	2687837.55	1362505.33
115	2687987.55	1361793.29
115	2688232.10	1360287.07
115	2688324.80	1360085.63
115	2688345.05	1358397.00
115	2688321.50	1357381.61
115	2688224.70	1356860.30
115	2687951.35	1356214.23
115	2687758.16	1356113.54
115	2687547.92	1356061.29
115	2687116.04	1356151.48
119	2685083.33	1439195.00
119	2685042.92	1438961.97
119	2685021.34	1438280.10
119	2685032.06	1437645.08
123	2791464.54	1483988.64
123	2787235.74	1484034.78
123	2783292.84	1484045.39
123	2778731.66	1484045.53
123	2778273.17	1483728.55
123	2778049.16	1483260.91
127	2690228.30	1520424.81
127	2690152.40	1520008.77
127	2690022.67	1519342.96
127	2689855.84	1518419.38
127	2689774.18	1517853.94
127	2689621.40	1517569.31
127	2689253.23	1517029.19
127	2688867.61	1516527.95
127	2688510.84	1515940.06

127	2687928.57	1515159.94
127	2687208.65	1514077.68
127	2686898.45	1513782.10
127	2686590.64	1513345.54
127	2685659.61	1511994.26
127	2685223.05	1511323.27
127	2684624.01	1510939.84
127	2684378.46	1510744.89
129	2683899.04	1497471.34
129	2685701.52	1495845.24
129	2686303.02	1495263.77
129	2686278.83	1489701.85
129	2686030.03	1483426.15
129	2685774.11	1475492.08
139	2687472.32	1458642.38
139	2694859.37	1458613.29
139	2696014.50	1458555.86
141	2688056.34	1437723.71
143	2681037.19	1522079.56
143	2681563.12	1522067.50
143	2681672.54	1522076.35
143	2681765.57	1522089.58
143	2681892.17	1522116.21
143	2681981.59	1522136.38
143	2682109.16	1522174.67
143	2682228.82	1522198.85
143	2682380.29	1522202.58
143	2682739.55	1522188.86
143	2683327.32	1522173.18
143	2684076.02	1522153.24
143	2685051.05	1522121.97
143	2685365.85	1522117.99
143	2685403.50	1522097.64
143	2685450.21	1522023.83
143	2685486.02	1521974.31
143	2685528.33	1521954.05
143	2686421.61	1521931.89
143	2687253.15	1521907.52
143	2688102.13	1521885.78
143	2688970.96	1521862.05
143	2689866.78	1521828.28
147	2804324.03	1483860.00
147	2793925.19	1483896.89
157	2748214.30	1417816.72
157	2732851.51	1418376.64
159	2704855.40	1418518.89
159	2703839.07	1418092.35
159	2703556.25	1416654.66
159	2703080.84	1414497.25
159	2701672.46	1413040.59
159	2700357.78	1412097.28
159	2698311.33	1412062.79
167	2908251.50	1392192.04
167	2908378.34	1389655.28
167	2909773.56	1389528.44
167	2910027.23	1386738.00
167	2913451.86	1386484.32
167	2913832.38	1379761.90
167	2915861.79	1379761.90
167	2918525.39	1378366.68
167	2921442.67	1378620.36
167	2921950.02	1366190.21
167	2927277.23	1366190.21

167	2934690.39	1366518.13
169	2750535.56	1415457.64
173	2732543.97	1521095.70
175	2801410.81	1415284.68
175	2834619.28	1415591.92
175	2835884.87	1415360.90
189	2681953.20	1390355.43
189	2682511.04	1388570.30
189	2682986.53	1387335.94
189	2683156.12	1386908.44
189	2683382.40	1386490.01
189	2684284.85	1385457.71
189	2686543.73	1382954.15
191	2682285.14	1410629.49
193	2683053.31	1413732.38
193	2682359.95	1412079.79
195	2685334.34	1458764.71
205	2684197.70	1509174.07
205	2684066.40	1506641.87
205	2683985.99	1505022.98
205	2683762.72	1498534.00
207	2684301.72	1510378.61
209	2678529.91	1522006.75
209	2679033.63	1521997.80
209	2679177.46	1522039.87
209	2679319.08	1522074.91
209	2679465.57	1522097.21
209	2679618.13	1522105.63
209	2680085.69	1522098.40
213	2708969.21	1521636.41
217	2737194.04	1521420.13
217	2740438.28	1521311.98
219	2696061.37	1437551.01
221	2695940.68	1413046.36
221	2694502.99	1413329.19
221	2693179.70	1412897.49
221	2691563.24	1411642.04
221	2690864.23	1410606.76
221	2688921.84	1410471.68
229	2854729.67	1414542.89
235	2892904.08	1412993.51
235	2892904.08	1406905.27
235	2894299.30	1404749.02
235	2896709.22	1397138.73
235	2896709.22	1394982.48
235	2902797.46	1394601.97
235	2902926.11	1392067.00
239	2777864.95	1473452.89
239	2778915.77	1473431.75
239	2779398.22	1473430.57
239	2779723.72	1473415.85
239	2779835.84	1473411.52
239	2779924.73	1473400.57
239	2780004.52	1473375.46
239	2780095.37	1473341.20
239	2780178.51	1473302.15
239	2780236.81	1473259.56
239	2780293.74	1473206.05
239	2780341.46	1473144.61
239	2780378.24	1473086.10
239	2780413.63	1473018.22
239	2780435.99	1472984.36
239	2780475.78	1472932.12

239	2780496.42	1472815.75
239	2780497.01	1472730.19
239	2780484.92	1472667.72
239	2780482.44	1472169.68
239	2780478.91	1471642.06
239	2780470.09	1470782.87
239	2780460.33	1470163.32
245	2813142.71	1483545.31
247	2821521.41	1486392.93
247	2820831.04	1486072.01
247	2820223.19	1485443.24
247	2819010.10	1484031.12
247	2818245.06	1483554.31
249	2824688.95	1486523.83
251	2808930.92	1501635.49
251	2810304.27	1505696.71
251	2810143.07	1515212.05
253	2814716.96	1551631.46
257	2555038.23	1519246.45
257	2555893.21	1519232.81
257	2557471.20	1519203.31
257	2558291.49	1519193.41
257	2559585.83	1519174.24
257	2560103.08	1519170.03
257	2561408.28	1519148.88
257	2562365.41	1519122.84
257	2563419.27	1519107.24
257	2564546.76	1519102.55
257	2565514.16	1519095.15
257	2566356.45	1519063.99
257	2567421.68	1519033.43
257	2568213.60	1519034.89
257	2568268.34	1518996.86
257	2568365.86	1518994.10
257	2568393.23	1519033.61
257	2568836.78	1519036.80
257	2570092.42	1519003.99
257	2571691.88	1518985.66
257	2572854.25	1518966.42
257	2574090.13	1518950.59
257	2575886.82	1518913.97
257	2576880.23	1518904.84
257	2577761.26	1518887.32
257	2578599.29	1518857.53
257	2579588.32	1518846.88
257	2580726.90	1518827.24
257	2581700.84	1518817.78
257	2583101.69	1518772.29
257	2583588.82	1518752.78
257	2584948.60	1518710.55
257	2586184.98	1518666.59
257	2587596.73	1518616.95
257	2588299.93	1518622.38
257	2589033.60	1518617.51
257	2590025.30	1518582.38
257	2591361.11	1518544.44
257	2592301.25	1518495.26
257	2593366.29	1518465.91
257	2594282.09	1518440.32
257	2595206.40	1518423.53
257	2596444.95	1518379.60
259	2640202.94	1522906.42
259	2641759.27	1522885.20

259	2645623.61	1522806.14
259	2645779.34	1522802.95
259	2645887.68	1522800.73
259	2645976.57	1522787.91
259	2646085.19	1522763.79
259	2646207.07	1522722.57
259	2646355.07	1522673.14
259	2646524.89	1522613.26
259	2646701.12	1522557.82
259	2646868.84	1522493.58
259	2646975.44	1522460.76
259	2647066.78	1522434.17
259	2647162.27	1522418.48
259	2647262.01	1522407.19
259	2647357.28	1522407.15
259	2647445.94	1522407.11
259	2647541.02	1522416.25
259	2647674.83	1522437.99
259	2647825.36	1522494.65
259	2647992.71	1522579.72
259	2648168.61	1522671.43
259	2648306.05	1522734.36
259	2648426.65	1522768.86
259	2648525.73	1522796.51
259	2648648.83	1522811.58
259	2648763.46	1522815.69
259	2650051.74	1522783.65
259	2650237.74	1522784.42
259	2651447.83	1522763.82
259	2652045.24	1522756.64
259	2653606.44	1522705.21
259	2655440.42	1522647.57
259	2656672.58	1522601.38
259	2658227.33	1522547.67
259	2659853.22	1522514.53
259	2660647.74	1522493.49
259	2661936.09	1522452.57
259	2663313.25	1522406.67
259	2664049.39	1522386.69
259	2665401.88	1522392.31
259	2666188.21	1522401.30
259	2666687.02	1522406.26
259	2667114.95	1522398.36
259	2668022.58	1522354.30
259	2668673.66	1522316.39
259	2669208.91	1522303.31
259	2669376.66	1522309.66
259	2669758.57	1522334.78
259	2669972.81	1522348.91
259	2670389.13	1522338.48
259	2671182.12	1522318.12
259	2671270.89	1522309.41
259	2671448.05	1522308.64
259	2671775.94	1522287.81
259	2672061.57	1522286.41
259	2672329.81	1522278.13
259	2672728.63	1522268.57
259	2673060.01	1522248.55
259	2673341.05	1522241.66
259	2673675.98	1522219.36
259	2673838.31	1522201.13
259	2674055.66	1522169.85
259	2674651.73	1522144.98

259	2675552.10	1522117.12
259	2675706.22	1522102.25
259	2676578.61	1522073.91
259	2677369.44	1522044.19
261	2526073.76	1551601.27
261	2527165.19	1551594.92
261	2528308.46	1551579.88
261	2528949.95	1551573.55
261	2529633.79	1551554.53
261	2531012.71	1551530.09
261	2531526.61	1551521.43
261	2532824.51	1551495.77
261	2534081.00	1551465.42
261	2535038.80	1551441.82
261	2536302.83	1551413.17
261	2537461.88	1551371.59
261	2537881.43	1551358.05
263	2514706.49	1552141.76
263	2514136.89	1552156.32
263	2513813.61	1552171.01
263	2513563.33	1552166.76
263	2513329.34	1552154.71
263	2513059.50	1552113.79
263	2512729.85	1552027.43
263	2512421.77	1551860.68
265	2538878.51	1536709.73
265	2538892.60	1536389.71
265	2538910.79	1536082.75
265	2538897.31	1535608.73
265	2538891.49	1535180.09
265	2538885.49	1534641.18
265	2538872.67	1533993.97
265	2538865.60	1533262.46
265	2538844.42	1532853.13
265	2538841.68	1532507.07
265	2538828.01	1531779.57
265	2538793.06	1530396.26
265	2538762.76	1529376.56
265	2538766.58	1528896.24
265	2538735.83	1527774.84
267	2540775.86	1520659.99
267	2541955.68	1520630.23
267	2542256.29	1520604.38
267	2545225.54	1520105.75
267	2545451.60	1520056.33
267	2545665.01	1519966.06
267	2545866.28	1519862.53
267	2546042.01	1519682.49
267	2546148.09	1519552.29
267	2546313.29	1519280.12
269	2509881.92	1549721.87
269	2509677.76	1549617.45
269	2509361.06	1549482.86
269	2509160.25	1549418.88
269	2508963.13	1549375.15
271	2512049.58	1551664.57
271	2511830.16	1551507.41
271	2511631.14	1551338.47
271	2511333.32	1551042.68
271	2511141.75	1550910.22
271	2510900.38	1550619.43
271	2510598.39	1550331.64
271	2510335.05	1550145.47

271	2510092.30	1549935.41
273	2515415.72	1552140.10
273	2515618.76	1552133.98
273	2515917.64	1552121.83
273	2516251.76	1552064.32
273	2516384.19	1551932.55
273	2516549.12	1551921.94
273	2518635.27	1551846.34
273	2519412.79	1551834.66
273	2520395.50	1551803.49
273	2520652.99	1551748.51
273	2520883.78	1551687.34
273	2520989.44	1551666.16
273	2521085.24	1551662.04
273	2521508.56	1551650.09
273	2521663.34	1551668.03
273	2521933.31	1551666.87
273	2522284.04	1551646.03
273	2523329.78	1551623.59
273	2523835.25	1551622.60
273	2525206.22	1551615.25
275	2539183.96	1551209.38
275	2539123.29	1551173.89
275	2539076.22	1551127.14
275	2539027.53	1551063.13
275	2539009.07	1551022.61
275	2538981.47	1550844.08
275	2538952.92	1550587.98
275	2538938.59	1550053.18
275	2538957.24	1549151.18
275	2538954.87	1548653.45
275	2538968.04	1548387.52
275	2538965.56	1548275.04
275	2538958.66	1548175.30
275	2538942.54	1547978.11
275	2538933.78	1547856.79
275	2538912.55	1547704.96
275	2538903.43	1547605.26
275	2538898.59	1547380.14
275	2538887.74	1546724.24
275	2538860.69	1545916.71
275	2538861.52	1545358.45
275	2538844.78	1543412.84
275	2538841.08	1542229.14
275	2538844.01	1541036.89
275	2538837.77	1539747.12
275	2538830.10	1538797.05
275	2538812.24	1537427.01
277	2538713.77	1526906.75
277	2538696.99	1526110.16
277	2538668.22	1524871.94
277	2538651.74	1523980.03
277	2538562.12	1523982.95
277	2538538.56	1522692.88
277	2538542.71	1522448.43
277	2538560.49	1522292.94
277	2538650.95	1521935.27
277	2538750.24	1521566.93
277	2538788.89	1521457.23
277	2538831.42	1521373.56
277	2538939.84	1521232.58
277	2538975.88	1521148.80
277	2539017.28	1521004.52

277	2539023.62	1520885.62
277	2539024.17	1520725.50
279	2546402.03	1519251.49
279	2546696.20	1519258.64
279	2546908.13	1519266.56
279	2547130.69	1519285.49
281	2547500.09	1519322.04
281	2547681.25	1519357.06
281	2547828.36	1519360.07
281	2548382.38	1519356.48
281	2548908.31	1519350.25
281	2549633.34	1519343.07
281	2550572.75	1519326.54
281	2551781.06	1519275.61
281	2552605.68	1519265.79
281	2554287.32	1519248.86
283	2597055.46	1518363.99
283	2598839.73	1518296.86
285	2600604.53	1518229.40
285	2602074.60	1518187.23
285	2603512.12	1518151.01
285	2604744.08	1518113.47
285	2605692.56	1518075.45
285	2607309.97	1518022.80
285	2608739.13	1517969.12
285	2609191.53	1517961.64
285	2609988.43	1517929.71
285	2610898.01	1517888.86
285	2612153.96	1517840.91
285	2613102.52	1517798.56
285	2614092.19	1517756.91
285	2614886.89	1517727.10
285	2615298.05	1517727.58
285	2615826.00	1517732.20
285	2616897.25	1517728.72
285	2617665.41	1517733.08
285	2618576.57	1517726.89
285	2619494.08	1517729.46
285	2620459.30	1517729.74
285	2621350.88	1517726.31
285	2623090.72	1517727.78
285	2624443.30	1517728.93
285	2624703.06	1517722.54
285	2625473.93	1517694.49
285	2626285.77	1517675.80
285	2627011.14	1517651.30
287	2627229.80	1517646.35
287	2627428.98	1517641.07
287	2627608.55	1517644.12
287	2627712.24	1517654.53
287	2627811.39	1517677.85
287	2627908.24	1517709.79
287	2628009.18	1517754.78
287	2628141.85	1517843.60
287	2628252.84	1517934.20
287	2628331.31	1518028.59
287	2628405.27	1518133.72
287	2628457.56	1518240.64
287	2628509.49	1518369.20
287	2628580.99	1518491.60
287	2628648.24	1518609.60
287	2628747.94	1518728.15
287	2628841.81	1518807.65

287	2628935.79	1518880.65
287	2629027.94	1518934.15
287	2629137.39	1518987.95
287	2629238.52	1519022.12
287	2629346.22	1519052.08
287	2629458.54	1519064.81
287	2629601.29	1519069.39
287	2629909.15	1519052.49
287	2631106.56	1518986.78
287	2632434.51	1518913.90
287	2632588.23	1518910.11
287	2632748.43	1518906.34
287	2632884.70	1518910.81
287	2633016.63	1518915.21
287	2633150.65	1518923.98
287	2633243.46	1518938.53
287	2633344.85	1518957.57
287	2633473.96	1519000.87
287	2633574.98	1519041.54
287	2633708.12	1519102.22
287	2633845.23	1519184.62
287	2634018.71	1519291.44
287	2634241.72	1519451.04
287	2634405.52	1519579.32
287	2635296.64	1520245.82
287	2635982.71	1520753.02
287	2636621.51	1521239.95
287	2637399.14	1521835.27
287	2637728.28	1522078.90
287	2637984.85	1522262.87
287	2638188.03	1522404.81
287	2638346.07	1522528.68
287	2638486.99	1522641.44
287	2638621.78	1522732.45
287	2638756.79	1522810.48
287	2638909.48	1522867.18
287	2639041.05	1522893.21
287	2639207.53	1522902.53
5	2684940.95	1418453.22
5	2683426.16	1414535.66
8	2782113.36	1415640.34
8	2782637.23	1416982.75
9	2782894.21	1461867.25
9	2782894.21	1461867.25
9	2780312.35	1465505.32

[LABELS]

;X-Coord	Y-Coord	Label & Anchor Node		
----------	---------	---------------------	--	--

[BACKDROP]

DIMENSIONS	2486665.28	1314604.96	2958321.18	1585560.41
UNITS	None			
FILE				
OFFSET	0.00	0.00		

[END]

Missouri-American Input

[TITLE]

[JUNCTIONS]

;ID	Elev	Demand	Pattern
10	857.809601	0	;
102	1044.269305	0	;
104	1095.411482	0	;New Junction
106	903.047204	0	;New Junction
108	1073.979188	0	;New Junction
110	905.820219	0	;New Junction
112	1046.223409	0	;New Junction
114	866.960169	0	;New Junction
116	1105.922624	0	;New Junction
118	939.736083	0	;New Junction
12	1081.236626	160	;King City
120	828.322389	623	;Gallatin
122	1052.862488	323	;DeKalb (25%)
124	1142.690699	0	;New Junction
126	966.687472	0	;New Junction
128	974.419391	0	;New Junction
132	1089.919218	0	;New Junction
134	1085.452118	0	;New Junction
136	1009.968566	112	;Barnard & Andrew
4			
138	968.939746	0	;New Junction
140	948.421877	40	;Maitland
142	1142.219321	0	;New Junction
144	971.030920	0	;New Junction
146	1153.426120	0	;New Junction
148	1027.710715	56	;Ravenwood
150	947.524072	80	;Bolckow
152	1059.031783	0	;New Junction
154	773.299736	0	;
156	780.384461	256	;Davies 1
158	779.610107	0	;New Junction
160	904.443523	184	;Stanberry
162	835.894863	0	;New Junction
164	950.172635	599	;Albany & Gentry
1			
166	927.761637	0	;New Junction
168	1024.644839	200	;Grant City
32	1020.039770	934	;Andrew 1
34	1033.037074	0	;New Junction
42	1122.846663	0	;
44	1042.668734	0	;New Junction
46	1101.459428	0	;New Junction
48	997.923834	0	;
50	1103.505249	0	;-4125
54	853.906592	0	;
56	940.257727	0	;New Junction
58	948.381330	80	;Gentry 2
60	954.501766	0	;New Junction
62	1019.226867	0	;New Junction
64	1117.131729	0	;New Junction
66	1141.306697	0	;New Junction
68	1111.461243	0	;New Junction
78	1029.407103	0	;New Junction
80	918.907434	0	;New Junction
82	918.943579	0	;New Junction

84	1156.700050	0	;
86	1140.430515	0	;New Junction
88	1130.523219	479	;Nodaway 1
90	906.351272	0	;New Junction
92	864.535480	0	;New Junction
94	871.651245	0	;New Junction
96	1087.661239	0	;New Junction
3	1100	0	;
5	872	0	;

[RESERVOIRS]

;ID	Head	Pattern
-----	------	---------

[TANKS]

;ID	Elevation	InitLevel	MinLevel	MaxLevel
	Diameter	MinVol	VolCurve	
1	1081	139	0	160
	50	0		;King City Tank
2	1157	63	0	130
	50	0		;Maryville Tank
4	1088	50	0	70
	10	0		;

[PIPES]

;ID	Node1	Node2	Length	Diameter
	Roughness	MinorLoss	Status	
109	32	34	25889.584309	24
	140.000000	0.000000	Open	;New Pipe
115	42	32	28628.27	24
	140.000000	0.000000	Open	;New Pipe
117	44	46	24186.604064	12
	140.000000	0.000000	Open	;New Pipe
119	48	44	5259.850703	12
	140.000000	0.000000	Open	;New Pipe
123	54	56	18459.301865	12
	140.000000	0.000000	Open	;New Pipe
125	58	60	3823.306885	12
	140.000000	0.000000	Open	;New Pipe
127	62	64	13013.826416	12
	140.000000	0.000000	Open	;New Pipe
129	66	68	25353.873685	12
	140.000000	0.000000	Open	;New Pipe
139	78	80	11571.705202	6
	140.000000	0.000000	Open	;New Pipe
141	44	82	9084.235681	6
	140.000000	0.000000	Open	;New Pipe
143	84	62	10111.368967	12
	140.000000	0.000000	Open	;New Pipe
145	86	88	951.294959	12
	140.000000	0.000000	Open	;New Pipe
147	90	92	15446.070030	12
	140.000000	0.000000	Open	;New Pipe
155	12	102	23242.244643	16
	140.000000	0.000000	Open	;New Pipe
157	104	106	25129.350635	20
	140.000000	0.000000	Open	;New Pipe
159	108	110	21670.464670	20
	140.000000	0.000000	Open	;New Pipe
161	48	78	15924.247181	12
	140.000000	0.000000	Open	;New Pipe

163		112	68		4396.201801	12
	140.000000	0.000000		Open	;New Pipe	
165		114	116		41715.258354	4
	140.000000	0.000000		Open	;New Pipe	
167		118	120		53895.626546	12
	140.000000	0.000000		Open	;New Pipe	
169		102	104		9735.164451	16
	140.000000	0.000000		Open	;New Pipe	
171		122	102		12017.922714	8
	140.000000	0.000000		Open	;New Pipe	
173		124	126		8498.010350	8
	140.000000	0.000000		Open	;New Pipe	
175		12	128		72241.288684	12
	140.000000	0.000000		Open	;New Pipe	
187		34	50		2763.671968	24
	140.000000	0.000000		Open	;New Pipe	
189		132	42		24016.78	24
	140.000000	0.000000		Open	;New Pipe	
191		134	132		5272.301439	24
	140.000000	0.000000		Open	;New Pipe	
193		46	134		3225.361603	12
	140.000000	0.000000		Open	;New Pipe	
195		78	112		10166.340821	12
	140.000000	0.000000		Open	;New Pipe	
197		80	136		1991.774638	6
	140.000000	0.000000		Open	;New Pipe	
199		138	112		7242.862487	4
	140.000000	0.000000		Open	;New Pipe	
201		116	138		7019.142244	4
	140.000000	0.000000		Open	;New Pipe	
203		140	114		2718.890522	4
	140.000000	0.000000		Open	;New Pipe	
205		142	66		11822.619789	12
	140.000000	0.000000		Open	;New Pipe	
207		64	142		1346.075690	12
	140.000000	0.000000		Open	;New Pipe	
209		86	84		2063.121682	12
	140.000000	0.000000		Open	;New Pipe	
211		62	144		6025.010030	8
	140.000000	0.000000		Open	;New Pipe	
213		144	146		20119.608793	8
	140.000000	0.000000		Open	;New Pipe	
215		146	124		11968.320398	8
	140.000000	0.000000		Open	;New Pipe	
217		126	148		6806.791630	8
	140.000000	0.000000		Open	;New Pipe	
219		82	150		4630.219333	6
	140.000000	0.000000		Open	;New Pipe	
221		110	134		15674.961160	20
	140.000000	0.000000		Open	;New Pipe	
223		152	108		1519.641879	20
	140.000000	0.000000		Open	;New Pipe	
225		106	152		9040.789911	20
	140.000000	0.000000		Open	;New Pipe	
229		128	154		14806.835473	12
	140.000000	0.000000		Open	;New Pipe	
231		156	158		696.853118	12
	140.000000	0.000000		Open	;New Pipe	
233		154	156		18054.998208	12
	140.000000	0.000000		Open	;New Pipe	

235		158		118		37390.425439	12
	140.000000		0.000000	Open		;New Pipe	
237		58		160		1536.532116	12
	140.000000		0.000000	Open		;New Pipe	
239		160		10		6239.234188	12
	140.000000		0.000000	Open		;New Pipe	
241		56		60		524.540342	12
	140.000000		0.000000	Open		;New Pipe	
243		92		54		1569.151793	12
	140.000000		0.000000	Open		;New Pipe	
245		162		90		6489.571040	12
	140.000000		0.000000	Open		;New Pipe	
247		164		162		7219.68	12
	140.000000		0.000000	Open		;New Pipe	
251		90		94		36600.129687	8
	140.000000		0.000000	Open		;New Pipe	
253		96		166		12574.225393	8
	140.000000		0.000000	Open		;New Pipe	
255		166		168		12642.977728	8
	140.000000		0.000000	Open		;New Pipe	
1		1		12		1000	24
	140		0	Open		;	
2		2		84		1000	12
	140		0	Open		;	
3		12		3		20000	16
	140		0	Open		;	
4		3		10		35008.020082	12
	140		0	Open		;	
6		4		96		100	8
	140		0	Open		;	
8		5		96		29725.922466	8
	140		0	Open		;	

[PUMPS]

;ID	Node1	Node2	Parameters
9	94	5	HEAD 2 ;

[VALVES]

;ID	Node1	Node2	Diameter	Type	Setting
MinorLoss					

[TAGS]

[DEMANDS]

;Junction	Demand	Pattern	Category
-----------	--------	---------	----------

[STATUS]

;ID	Status/Setting
9	Closed

[PATTERNS]

;ID	Multipliers
-----	-------------

[CURVES]

;ID	X-Value	Y-Value
;PUMP: PUMP:		
1	0	2000
1	3000	500
1	3200	10
;PUMP: PUMP:		

2	0	2000
2	180	500
2	210	10

[CONTROLS]

[RULES]

[ENERGY]

Global Efficiency	70.000000
Global Price	0
Demand Charge	0.000000

[EMITTERS]

;Junction Coefficient

[QUALITY]

;Node InitQual

[SOURCES]

;Node Type Quality Pattern

[REACTIONS]

;Type Pipe/Tank Coefficient

[REACTIONS]

Order Bulk	1.000000
Order Tank	1.000000
Order Wall	1
Global Bulk	0.000000
Global Wall	0.000000
Limiting Potential	0
Roughness Correlation	0

[MIXING]

;Tank Model

[TIMES]

Duration	0:00
Hydraulic Timestep	1:00
Quality Timestep	0:05
Pattern Timestep	1:00
Pattern Start	0:00
Report Timestep	1:00
Report Start	0:00
Start ClockTime	12 am
Statistic	NONE

[REPORT]

Status	Yes
Summary	No
Page	0

[OPTIONS]

Units	GPM
Headloss	H-W

Specific Gravity	1.000000
Viscosity	1
Trials	40
Accuracy	0.001
CHECKFREQ	2
MAXCHECK	10
DAMPLIMIT	0
Unbalanced	Stop
Pattern	1
Demand Multiplier	1.000000
Emitter Exponent	0.500000
Quality	None mg/L
Diffusivity	1
Tolerance	0.001000

[COORDINATES]

;Node	X-Coord	Y-Coord
10	2780454.89	1469510.73
102	2758855.25	1415487.11
104	2749550.50	1416474.04
106	2723973.99	1418435.66
108	2714517.67	1418813.91
110	2696280.95	1412932.18
112	2685645.66	1468909.31
114	2629679.73	1470035.78
116	2671386.54	1469196.31
118	2907800.85	1392181.46
12	2781446.58	1415881.53
120	2936642.36	1368195.83
122	2758291.93	1403351.44
124	2728398.36	1521190.79
126	2736884.73	1521398.55
128	2854296.86	1414561.68
132	2682202.70	1405422.22
134	2682333.00	1410762.56
136	2698631.04	1461178.24
138	2678404.26	1469055.06
140	2626672.75	1469804.13
142	2684216.82	1509395.43
144	2696316.10	1521755.47
146	2716433.19	1521465.22
148	2740687.24	1524151.91
150	2698757.93	1439201.27
152	2715948.84	1418462.53
154	2868903.49	1415355.80
156	2887130.29	1413195.54
158	2887826.54	1413166.58
160	2777682.03	1473146.63
162	2815686.98	1483549.80
164	2821774.87	1486461.79
166	2815057.93	1560610.38
168	2815537.69	1573244.25
32	2686592.79	1355843.19
34	2685559.31	1330855.90
42	2686526.95	1382879.89
44	2685032.30	1437572.32
46	2683063.92	1413803.70
48	2684979.62	1443223.05
50	2685650.86	1328101.48
54	2792060.71	1483964.98

56	2777975.02	1479337.24
58	2777892.87	1474990.17
60	2777965.11	1478812.79
62	2690291.36	1521812.16
64	2684321.60	1510552.18
66	2683883.74	1497590.61
68	2685780.51	1473303.44
78	2685343.99	1458750.75
80	2696769.35	1459040.35
82	2694111.67	1437726.71
84	2680596.70	1522064.72
86	2677448.88	1522076.96
88	2678340.36	1523110.32
90	2809198.39	1483633.21
92	2793758.24	1483910.74
94	2813748.25	1518368.96
96	2814621.91	1548043.88
3	2782927.32	1442033.13
5	2813812.26	1519169.65
1	2780711.92	1415031.39
2	2680474.91	1522455.21
4	2812810.11	1547949.72

[VERTICES]

;Link	X-Coord	Y-Coord
109	2687445.31	1355401.85
109	2687636.79	1355120.86
109	2687780.11	1354806.59
109	2687964.63	1353973.32
109	2688242.66	1352889.91
109	2688331.61	1352428.56
109	2688327.06	1349797.60
109	2688254.06	1349309.17
109	2688255.04	1346832.58
109	2688229.65	1346409.92
109	2688147.04	1346010.65
109	2687948.51	1345260.27
109	2687666.69	1344151.22
109	2687169.69	1342315.88
109	2686738.25	1340928.24
109	2686530.38	1340250.79
109	2686462.77	1339924.85
109	2686326.24	1338866.96
109	2686190.80	1337744.13
109	2686085.33	1337255.16
109	2685883.06	1337211.16
109	2685768.62	1335804.49
109	2685730.46	1334691.41
109	2685572.89	1332951.08
115	2686924.81	1382209.92
115	2687120.92	1381948.85
115	2687589.85	1381104.14
115	2687575.85	1376142.57
115	2687518.17	1370879.82
115	2687535.91	1368858.24
115	2687437.40	1367955.26
115	2687374.51	1367832.40
115	2687411.35	1367573.18
115	2687474.10	1367062.63
115	2687510.74	1366007.69

115	2687488.08	1364456.38
115	2687511.28	1364042.65
115	2687608.48	1363573.32
115	2687837.55	1362505.33
115	2687987.55	1361793.29
115	2688232.10	1360287.07
115	2688324.80	1360085.63
115	2688345.05	1358397.00
115	2688321.50	1357381.61
115	2688224.70	1356860.30
115	2687951.35	1356214.23
115	2687758.16	1356113.54
115	2687547.92	1356061.29
115	2687116.04	1356151.48
117	2685040.28	1435197.07
117	2685048.35	1434720.81
117	2685175.75	1434226.72
117	2685205.42	1433644.96
117	2685175.52	1432671.81
117	2685122.66	1430705.78
117	2685136.24	1429508.40
117	2685082.27	1427608.53
117	2685027.82	1424166.97
117	2684941.44	1419871.33
117	2684918.33	1418494.69
117	2684859.43	1418063.62
117	2684760.17	1417671.56
117	2684538.13	1417105.41
117	2683989.67	1415885.33
117	2683423.92	1414512.77
119	2685083.33	1439195.00
119	2685042.92	1438961.97
119	2685021.34	1438280.10
119	2685032.06	1437645.08
123	2791464.54	1483988.64
123	2787235.74	1484034.78
123	2783292.84	1484045.39
123	2778731.66	1484045.53
123	2778273.17	1483728.55
123	2778049.16	1483260.91
127	2690228.30	1520424.81
127	2690152.40	1520008.77
127	2690022.67	1519342.96
127	2689855.84	1518419.38
127	2689774.18	1517853.94
127	2689621.40	1517569.31
127	2689253.23	1517029.19
127	2688867.61	1516527.95
127	2688510.84	1515940.06
127	2687928.57	1515159.94
127	2687208.65	1514077.68
127	2686898.45	1513782.10
127	2686590.64	1513345.54
127	2685659.61	1511994.26
127	2685223.05	1511323.27
127	2684624.01	1510939.84
127	2684378.46	1510744.89
129	2683899.04	1497471.34
129	2685701.52	1495845.24
129	2686303.02	1495263.77

129	2686278.83	1489701.85
129	2686030.03	1483426.15
129	2685774.11	1475492.08
139	2687472.32	1458642.38
139	2694859.37	1458613.29
139	2696014.50	1458555.86
141	2688056.34	1437723.71
143	2681037.19	1522079.56
143	2681563.12	1522067.50
143	2681672.54	1522076.35
143	2681765.57	1522089.58
143	2681892.17	1522116.21
143	2681981.59	1522136.38
143	2682109.16	1522174.67
143	2682228.82	1522198.85
143	2682380.29	1522202.58
143	2682739.55	1522188.86
143	2683327.32	1522173.18
143	2684076.02	1522153.24
143	2685051.05	1522121.97
143	2685365.85	1522117.99
143	2685403.50	1522097.64
143	2685450.21	1522023.83
143	2685486.02	1521974.31
143	2685528.33	1521954.05
143	2686421.61	1521931.89
143	2687253.15	1521907.52
143	2688102.13	1521885.78
143	2688970.96	1521862.05
143	2689866.78	1521828.28
147	2804324.03	1483860.00
147	2793925.19	1483896.89
157	2748214.30	1417816.72
157	2732851.51	1418376.64
159	2704855.40	1418518.89
159	2703839.07	1418092.35
159	2703556.25	1416654.66
159	2703080.84	1414497.25
159	2701672.46	1413040.59
159	2700357.78	1412097.28
159	2698311.33	1412062.79
167	2908251.50	1392192.04
167	2908378.34	1389655.28
167	2909773.56	1389528.44
167	2910027.23	1386738.00
167	2913451.86	1386484.32
167	2913832.38	1379761.90
167	2915861.79	1379761.90
167	2918525.39	1378366.68
167	2921442.67	1378620.36
167	2921950.02	1366190.21
167	2927277.23	1366190.21
167	2934690.39	1366518.13
169	2750535.56	1415457.64
173	2732543.97	1521095.70
175	2801410.81	1415284.68
175	2834619.28	1415591.92
175	2835884.87	1415360.90
187	2685536.08	1330065.47
187	2685524.15	1329241.60

187	2685640.03	1328471.35
189	2681953.20	1390355.43
189	2682511.04	1388570.30
189	2682986.53	1387335.94
189	2683156.12	1386908.44
189	2683382.40	1386490.01
189	2684284.85	1385457.71
189	2686543.73	1382954.15
191	2682285.14	1410629.49
193	2683053.31	1413732.38
193	2682359.95	1412079.79
195	2685334.34	1458764.71
205	2684197.70	1509174.07
205	2684066.40	1506641.87
205	2683985.99	1505022.98
205	2683762.72	1498534.00
207	2684301.72	1510378.61
209	2678529.91	1522006.75
209	2679033.63	1521997.80
209	2679177.46	1522039.87
209	2679319.08	1522074.91
209	2679465.57	1522097.21
209	2679618.13	1522105.63
209	2680085.69	1522098.40
213	2708969.21	1521636.41
217	2737194.04	1521420.13
217	2740438.28	1521311.98
219	2696061.37	1437551.01
221	2695940.68	1413046.36
221	2694502.99	1413329.19
221	2693179.70	1412897.49
221	2691563.24	1411642.04
221	2690864.23	1410606.76
221	2688921.84	1410471.68
229	2854729.67	1414542.89
235	2892904.08	1412993.51
235	2892904.08	1406905.27
235	2894299.30	1404749.02
235	2896709.22	1397138.73
235	2896709.22	1394982.48
235	2902797.46	1394601.97
235	2902926.11	1392067.00
239	2777864.95	1473452.89
239	2778915.77	1473431.75
239	2779398.22	1473430.57
239	2779723.72	1473415.85
239	2779835.84	1473411.52
239	2779924.73	1473400.57
239	2780004.52	1473375.46
239	2780095.37	1473341.20
239	2780178.51	1473302.15
239	2780236.81	1473259.56
239	2780293.74	1473206.05
239	2780341.46	1473144.61
239	2780378.24	1473086.10
239	2780413.63	1473018.22
239	2780435.99	1472984.36
239	2780475.78	1472932.12
239	2780496.42	1472815.75
239	2780497.01	1472730.19

239	2780484.92	1472667.72
239	2780482.44	1472169.68
239	2780478.91	1471642.06
239	2780470.09	1470782.87
239	2780460.33	1470163.32
245	2813142.71	1483545.31
247	2821521.41	1486392.93
247	2820831.04	1486072.01
247	2820223.19	1485443.24
247	2819010.10	1484031.12
247	2818245.06	1483554.31
251	2808930.92	1501635.49
251	2810304.27	1505696.71
251	2810143.07	1515212.05
253	2814716.96	1551631.46
3	2782316.20	1416026.33
3	2782757.56	1441557.81
4	2783007.84	1461937.82
4	2782269.05	1463292.27
4	2780483.64	1465816.47

[LABELS]

;X-Coord	Y-Coord	Label & Anchor Node
2660805.75	1385527.66	"Savannah"
2705131.92	1460854.07	"Andrew 4"
2702444.52	1443881.44	"Bolckow"
2621467.45	1478956.13	"Maitland"
2702444.52	1467030.20	"Barnard"
2737969.35	1532668.04	"Ravenwood"
2672531.59	1532289.78	"Nodaway 1"
2819428.44	1579467.04	"Grant City"
2785629.21	1422596.44	"King City"
2837828.11	1492573.23	"Gentry 1"
2813241.67	1496355.76	"Albany"
2784494.45	1492194.98	"Gentry 2"
2749982.15	1483978.40	"Stanberry"
2745534.40	1396875.25	"DeKalb (25%)"
2884025.85	1422818.73	"Davies 1"
2927852.30	1377206.10	"Gallatin"
2691065.99	1359428.21	"Andrew 1"
2625144.19	1417839.08	"Flow Control Structure"

[BACKDROP]

DIMENSIONS	2486665.00	1314604.00	2958321.00	1585560.00
UNITS	None			
FILE				
OFFSET	0.00	0.00		

[END]

Savannah Input

[TITLE]

[JUNCTIONS]

;ID	Elev	Demand	Pattern
10	857.809601	0	;New Junction
102	1044.269305	0	;New Junction
104	1095.411482	0	;New Junction
106	903.047204	0	;New Junction
108	1073.979188	0	;New Junction
110	905.820219	0	;New Junction
112	1046.223409	0	;New Junction
114	866.960169	0	;New Junction
116	1105.922624	0	;New Junction
118	939.736083	0	;New Junction
12	1081.236626	160	;King City
120	828.322389	623	;Gallatin
122	1052.862488	323	;DeKalb (25%)
124	1142.690699	0	;New Junction
126	966.687472	0	;New Junction
128	974.419391	0	;New Junction
132	1089.919218	0	;New Junction
134	1085.452118	0	;New Junction
136	1009.968566	112	;Barnard & Andrew
4			
138	968.939746	0	;New Junction
140	948.421877	40	;Maitland
142	1142.219321	0	;New Junction
144	971.030920	0	;New Junction
146	1153.426120	0	;New Junction
148	1027.710715	56	;Ravenwood
150	947.524072	80	;Bolckow
152	1059.031783	0	;New Junction
154	773.299736	0	;
156	780.384461	256	;Davies 1
158	779.610107	0	;New Junction
160	904.443523	184	;Stanberry
162	835.894863	0	;New Junction
164	950.172635	599	;Albany & Gentry
1			
166	927.761637	0	;New Junction
168	1024.644839	200	;Grant City
32	1020.039770	934	;Andrew 1
42	1122.846663	-4125	;
44	1042.668734	0	;New Junction
46	1101.459428	0	;New Junction
48	997.923834	0	;
54	853.906592	0	;
56	940.257727	0	;New Junction
58	948.381330	80	;Gentry 2
60	954.501766	0	;New Junction
62	1019.226867	0	;New Junction
64	1117.131729	0	;New Junction
66	1141.306697	0	;New Junction
68	1111.461243	0	;New Junction
78	1029.407103	0	;New Junction
80	918.907434	0	;New Junction
82	918.943579	0	;New Junction
84	1156.700050	0	;
86	1140.430515	0	;New Junction
88	1130.523219	479	;Nodaway 1
90	906.351272	0	;New Junction
92	864.535480	0	;New Junction

94	871.651245	0	;New Junction
96	1087.661239	0	;New Junction
3	1100	0	;
5	872	0	;

[RESERVOIRS]

;ID	Head	Pattern
-----	------	---------

[TANKS]

;ID	Elevation	InitLevel	MinLevel	MaxLevel
	Diameter	MinVol	VolCurve	
1	1081	139	0	160
	50	0		;King City Tank
2	1157	63	0	130
	50	0		;Maryville Tank
4	1088	50	0	70
	10	0		;

[PIPES]

;ID	Node1	Node2	Length	Diameter
	Roughness	MinorLoss	Status	
115	42	32	28628.27	12
	140.000000	0.000000	Open	;New Pipe
117	44	46	24186.604064	12
	140.000000	0.000000	Open	;New Pipe
119	48	44	5259.850703	12
	140.000000	0.000000	Open	;New Pipe
123	54	56	18459.301865	12
	140.000000	0.000000	Open	;New Pipe
125	58	60	3823.306885	12
	140.000000	0.000000	Open	;New Pipe
127	62	64	13013.826416	12
	140.000000	0.000000	Open	;New Pipe
129	66	68	25353.873685	12
	140.000000	0.000000	Open	;New Pipe
139	78	80	11571.705202	6
	140.000000	0.000000	Open	;New Pipe
141	44	82	9084.235681	6
	140.000000	0.000000	Open	;New Pipe
143	84	62	10111.368967	12
	140.000000	0.000000	Open	;New Pipe
145	86	88	951.294959	12
	140.000000	0.000000	Open	;New Pipe
147	90	92	15446.070030	12
	140.000000	0.000000	Open	;New Pipe
155	12	102	23242.244643	16
	140.000000	0.000000	Open	;New Pipe
157	104	106	25129.350635	20
	140.000000	0.000000	Open	;New Pipe
159	108	110	21670.464670	20
	140.000000	0.000000	Open	;New Pipe
161	48	78	15924.247181	12
	140.000000	0.000000	Open	;New Pipe
163	112	68	4396.201801	12
	140.000000	0.000000	Open	;New Pipe
165	114	116	41715.258354	4
	140.000000	0.000000	Open	;New Pipe
167	118	120	53895.626546	12
	140.000000	0.000000	Open	;New Pipe
169	102	104	9735.164451	16
	140.000000	0.000000	Open	;New Pipe
171	122	102	12017.922714	8
	140.000000	0.000000	Open	;New Pipe

173	140.000000	124	0.000000	126	Open	8498.010350	8
						;New Pipe	
175	140.000000	12	0.000000	128	Open	72241.288684	12
						;New Pipe	
189	140.000000	132	0.000000	42	Open	24016.78	24
						;New Pipe	
191	140.000000	134	0.000000	132	Open	5272.301439	24
						;New Pipe	
193	140.000000	46	0.000000	134	Open	3225.361603	12
						;New Pipe	
195	140.000000	78	0.000000	112	Open	10166.340821	12
						;New Pipe	
197	140.000000	80	0.000000	136	Open	1991.774638	6
						;New Pipe	
199	140.000000	138	0.000000	112	Open	7242.862487	4
						;New Pipe	
201	140.000000	116	0.000000	138	Open	7019.142244	4
						;New Pipe	
203	140.000000	140	0.000000	114	Open	2718.890522	4
						;New Pipe	
205	140.000000	142	0.000000	66	Open	11822.619789	12
						;New Pipe	
207	140.000000	64	0.000000	142	Open	1346.075690	12
						;New Pipe	
209	140.000000	86	0.000000	84	Open	2063.121682	12
						;New Pipe	
211	140.000000	62	0.000000	144	Open	6025.010030	8
						;New Pipe	
213	140.000000	144	0.000000	146	Open	20119.608793	8
						;New Pipe	
215	140.000000	146	0.000000	124	Open	11968.320398	8
						;New Pipe	
217	140.000000	126	0.000000	148	Open	6806.791630	8
						;New Pipe	
219	140.000000	82	0.000000	150	Open	4630.219333	6
						;New Pipe	
221	140.000000	110	0.000000	134	Open	15674.961160	20
						;New Pipe	
223	140.000000	152	0.000000	108	Open	1519.641879	20
						;New Pipe	
225	140.000000	106	0.000000	152	Open	9040.789911	20
						;New Pipe	
229	140.000000	128	0.000000	154	Open	14806.835473	12
						;New Pipe	
231	140.000000	156	0.000000	158	Open	696.853118	12
						;New Pipe	
233	140.000000	154	0.000000	156	Open	18054.998208	12
						;New Pipe	
235	140.000000	158	0.000000	118	Open	37390.425439	12
						;New Pipe	
237	140.000000	58	0.000000	160	Open	1536.532116	12
						;New Pipe	
239	140.000000	160	0.000000	10	Open	6239.234188	12
						;New Pipe	
241	140.000000	56	0.000000	60	Open	524.540342	12
						;New Pipe	
243	140.000000	92	0.000000	54	Open	1569.151793	12
						;New Pipe	
245	140.000000	162	0.000000	90	Open	6489.571040	12
						;New Pipe	
247	140.000000	164	0.000000	162	Open	7219.68	12
						;New Pipe	

251	140.000000	90	0.000000	94	Open	36600.129687	8
						;New Pipe	
253	140.000000	96	0.000000	166	Open	12574.225393	8
						;New Pipe	
255	140.000000	166	0.000000	168	Open	12642.977728	8
						;New Pipe	
1	140	1	0	12	Open	1000	24
						;	
2	140	2	0	84	Open	1000	12
						;	
3	140	12	0	3	Open	20000	16
						;	
4	140	3	0	10	Open	35008.020082	12
						;	
6	140	4	0	96	Open	100	8
						;	
8	140	5	0	96	Open	29725.922466	8
						;	

[PUMPS]

;ID	Node1	Node2	Parameters
9	94	5	HEAD 2 ;

[VALVES]

;ID	Node1	Node2	Diameter	Type	Setting
MinorLoss					

[TAGS]

[DEMANDS]

;Junction	Demand	Pattern	Category
-----------	--------	---------	----------

[STATUS]

;ID	Status/Setting
-----	----------------

[PATTERNS]

;ID	Multipliers
-----	-------------

[CURVES]

;ID	X-Value	Y-Value
;PUMP:		
1	0	2000
1	3000	500
1	3200	10
;PUMP:		
2	0	2000
2	180	500
2	210	10

[CONTROLS]

[RULES]

[ENERGY]

Global Efficiency	70.000000
Global Price	0
Demand Charge	0.000000

[EMITTERS]

;Junction	Coefficient
-----------	-------------

[QUALITY]

;Node InitQual

[SOURCES]

;Node Type Quality Pattern

[REACTIONS]

;Type Pipe/Tank Coefficient

[REACTIONS]

Order Bulk	1.000000
Order Tank	1.000000
Order Wall	1
Global Bulk	0.000000
Global Wall	0.000000
Limiting Potential	0
Roughness Correlation	0

[MIXING]

;Tank Model

[TIMES]

Duration	0
Hydraulic Timestep	1:00
Quality Timestep	0:05
Pattern Timestep	1:00
Pattern Start	0:00
Report Timestep	1:00
Report Start	0:00
Start ClockTime	12 am
Statistic	None

[REPORT]

Status	Yes
Summary	No
Page	0

[OPTIONS]

Units	GPM
Headloss	H-W
Specific Gravity	1.000000
Viscosity	1
Trials	40
Accuracy	0.001
CHECKFREQ	2
MAXCHECK	10
DAMPLIMIT	0
Unbalanced	Stop
Pattern	1
Demand Multiplier	1.000000
Emitter Exponent	0.500000
Quality	None mg/L
Diffusivity	1
Tolerance	0.001000

[COORDINATES]

;Node	X-Coord	Y-Coord
10	2780454.89	1469510.73
102	2758855.25	1415487.11
104	2749550.50	1416474.04
106	2723973.99	1418435.66
108	2714517.67	1418813.91
110	2696280.95	1412932.18

112	2685645.66	1468909.31
114	2629679.73	1470035.78
116	2671386.54	1469196.31
118	2907800.85	1392181.46
12	2781446.58	1415881.53
120	2936642.36	1368195.83
122	2758291.93	1403351.44
124	2728398.36	1521190.79
126	2736884.73	1521398.55
128	2854296.86	1414561.68
132	2682202.70	1405422.22
134	2682333.00	1410762.56
136	2698631.04	1461178.24
138	2678404.26	1469055.06
140	2626672.75	1469804.13
142	2684216.82	1509395.43
144	2696316.10	1521755.47
146	2716433.19	1521465.22
148	2740687.24	1524151.91
150	2698757.93	1439201.27
152	2715948.84	1418462.53
154	2868903.49	1415355.80
156	2887130.29	1413195.54
158	2887826.54	1413166.58
160	2777682.03	1473146.63
162	2815686.98	1483549.80
164	2821774.87	1486461.79
166	2815057.93	1560610.38
168	2815537.69	1573244.25
32	2686592.79	1355843.19
42	2686526.95	1382879.89
44	2685032.30	1437572.32
46	2683063.92	1413803.70
48	2684979.62	1443223.05
54	2792060.71	1483964.98
56	2777975.02	1479337.24
58	2777892.87	1474990.17
60	2777965.11	1478812.79
62	2690291.36	1521812.16
64	2684321.60	1510552.18
66	2683883.74	1497590.61
68	2685780.51	1473303.44
78	2685343.99	1458750.75
80	2696769.35	1459040.35
82	2694111.67	1437726.71
84	2680596.70	1522064.72
86	2677448.88	1522076.96
88	2678340.36	1523110.32
90	2809198.39	1483633.21
92	2793758.24	1483910.74
94	2813748.25	1518368.96
96	2814621.91	1548043.88
3	2782927.32	1442033.13
5	2813812.26	1519169.65
1	2780711.92	1415031.39
2	2680474.91	1522455.21
4	2812810.11	1547949.72

[VERTICES]

;Link	X-Coord	Y-Coord
115	2686924.81	1382209.92
115	2687120.92	1381948.85
115	2687589.85	1381104.14

115	2687575.85	1376142.57
115	2687518.17	1370879.82
115	2687535.91	1368858.24
115	2687437.40	1367955.26
115	2687374.51	1367832.40
115	2687411.35	1367573.18
115	2687474.10	1367062.63
115	2687510.74	1366007.69
115	2687488.08	1364456.38
115	2687511.28	1364042.65
115	2687608.48	1363573.32
115	2687837.55	1362505.33
115	2687987.55	1361793.29
115	2688232.10	1360287.07
115	2688324.80	1360085.63
115	2688345.05	1358397.00
115	2688321.50	1357381.61
115	2688224.70	1356860.30
115	2687951.35	1356214.23
115	2687758.16	1356113.54
115	2687547.92	1356061.29
115	2687116.04	1356151.48
117	2685040.28	1435197.07
117	2685048.35	1434720.81
117	2685175.75	1434226.72
117	2685205.42	1433644.96
117	2685175.52	1432671.81
117	2685122.66	1430705.78
117	2685136.24	1429508.40
117	2685082.27	1427608.53
117	2685027.82	1424166.97
117	2684941.44	1419871.33
117	2684918.33	1418494.69
117	2684859.43	1418063.62
117	2684760.17	1417671.56
117	2684538.13	1417105.41
117	2683989.67	1415885.33
117	2683423.92	1414512.77
119	2685083.33	1439195.00
119	2685042.92	1438961.97
119	2685021.34	1438280.10
119	2685032.06	1437645.08
123	2791464.54	1483988.64
123	2787235.74	1484034.78
123	2783292.84	1484045.39
123	2778731.66	1484045.53
123	2778273.17	1483728.55
123	2778049.16	1483260.91
127	2690228.30	1520424.81
127	2690152.40	1520008.77
127	2690022.67	1519342.96
127	2689855.84	1518419.38
127	2689774.18	1517853.94
127	2689621.40	1517569.31
127	2689253.23	1517029.19
127	2688867.61	1516527.95
127	2688510.84	1515940.06
127	2687928.57	1515159.94
127	2687208.65	1514077.68
127	2686898.45	1513782.10
127	2686590.64	1513345.54
127	2685659.61	1511994.26
127	2685223.05	1511323.27

127	2684624.01	1510939.84
127	2684378.46	1510744.89
129	2683899.04	1497471.34
129	2685701.52	1495845.24
129	2686303.02	1495263.77
129	2686278.83	1489701.85
129	2686030.03	1483426.15
129	2685774.11	1475492.08
139	2687472.32	1458642.38
139	2694859.37	1458613.29
139	2696014.50	1458555.86
141	2688056.34	1437723.71
143	2681037.19	1522079.56
143	2681563.12	1522067.50
143	2681672.54	1522076.35
143	2681765.57	1522089.58
143	2681892.17	1522116.21
143	2681981.59	1522136.38
143	2682109.16	1522174.67
143	2682228.82	1522198.85
143	2682380.29	1522202.58
143	2682739.55	1522188.86
143	2683327.32	1522173.18
143	2684076.02	1522153.24
143	2685051.05	1522121.97
143	2685365.85	1522117.99
143	2685403.50	1522097.64
143	2685450.21	1522023.83
143	2685486.02	1521974.31
143	2685528.33	1521954.05
143	2686421.61	1521931.89
143	2687253.15	1521907.52
143	2688102.13	1521885.78
143	2688970.96	1521862.05
143	2689866.78	1521828.28
147	2804324.03	1483860.00
147	2793925.19	1483896.89
157	2748214.30	1417816.72
157	2732851.51	1418376.64
159	2704855.40	1418518.89
159	2703839.07	1418092.35
159	2703556.25	1416654.66
159	2703080.84	1414497.25
159	2701672.46	1413040.59
159	2700357.78	1412097.28
159	2698311.33	1412062.79
167	2908251.50	1392192.04
167	2908378.34	1389655.28
167	2909773.56	1389528.44
167	2910027.23	1386738.00
167	2913451.86	1386484.32
167	2913832.38	1379761.90
167	2915861.79	1379761.90
167	2918525.39	1378366.68
167	2921442.67	1378620.36
167	2921950.02	1366190.21
167	2927277.23	1366190.21
167	2934690.39	1366518.13
169	2750535.56	1415457.64
173	2732543.97	1521095.70
175	2801410.81	1415284.68
175	2834619.28	1415591.92
175	2835884.87	1415360.90

189	2681953.20	1390355.43
189	2682511.04	1388570.30
189	2682986.53	1387335.94
189	2683156.12	1386908.44
189	2683382.40	1386490.01
189	2684284.85	1385457.71
189	2686543.73	1382954.15
191	2682285.14	1410629.49
193	2683053.31	1413732.38
193	2682359.95	1412079.79
195	2685334.34	1458764.71
205	2684197.70	1509174.07
205	2684066.40	1506641.87
205	2683985.99	1505022.98
205	2683762.72	1498534.00
207	2684301.72	1510378.61
209	2678529.91	1522006.75
209	2679033.63	1521997.80
209	2679177.46	1522039.87
209	2679319.08	1522074.91
209	2679465.57	1522097.21
209	2679618.13	1522105.63
209	2680085.69	1522098.40
213	2708969.21	1521636.41
217	2737194.04	1521420.13
217	2740438.28	1521311.98
219	2696061.37	1437551.01
221	2695940.68	1413046.36
221	2694502.99	1413329.19
221	2693179.70	1412897.49
221	2691563.24	1411642.04
221	2690864.23	1410606.76
221	2688921.84	1410471.68
229	2854729.67	1414542.89
235	2892904.08	1412993.51
235	2892904.08	1406905.27
235	2894299.30	1404749.02
235	2896709.22	1397138.73
235	2896709.22	1394982.48
235	2902797.46	1394601.97
235	2902926.11	1392067.00
239	2777864.95	1473452.89
239	2778915.77	1473431.75
239	2779398.22	1473430.57
239	2779723.72	1473415.85
239	2779835.84	1473411.52
239	2779924.73	1473400.57
239	2780004.52	1473375.46
239	2780095.37	1473341.20
239	2780178.51	1473302.15
239	2780236.81	1473259.56
239	2780293.74	1473206.05
239	2780341.46	1473144.61
239	2780378.24	1473086.10
239	2780413.63	1473018.22
239	2780435.99	1472984.36
239	2780475.78	1472932.12
239	2780496.42	1472815.75
239	2780497.01	1472730.19
239	2780484.92	1472667.72
239	2780482.44	1472169.68
239	2780478.91	1471642.06
239	2780470.09	1470782.87

239	2780460.33	1470163.32
245	2813142.71	1483545.31
247	2821521.41	1486392.93
247	2820831.04	1486072.01
247	2820223.19	1485443.24
247	2819010.10	1484031.12
247	2818245.06	1483554.31
251	2808930.92	1501635.49
251	2810304.27	1505696.71
251	2810143.07	1515212.05
253	2814716.96	1551631.46
3	2782316.20	1416026.33
3	2782757.56	1441557.81
4	2783007.84	1461937.82
4	2782269.05	1463292.27
4	2780483.64	1465816.47

[LABELS]

;X-Coord	Y-Coord	Label & Anchor Node
2660805.75	1385527.66	"Savannah"
2705131.92	1460854.07	"Andrew 4"
2702444.52	1443881.44	"Bolckow"
2621467.45	1478956.13	"Maitland"
2702444.52	1467030.20	"Barnard"
2737969.35	1532668.04	"Ravenwood"
2672531.59	1532289.78	"Nodaway 1"
2819428.44	1579467.04	"Grant City"
2785629.21	1422596.44	"King City"
2837828.11	1492573.23	"Gentry 1"
2813241.67	1496355.76	"Albany"
2784494.45	1492194.98	"Gentry 2"
2749982.15	1483978.40	"Stanberry"
2745534.40	1396875.25	"DeKalb (25%)"
2884025.85	1422818.73	"Davies 1"
2927852.30	1377206.10	"Gallatin"
2691065.99	1359428.21	"Andrew 1"
2625144.19	1417839.08	"Flow Control Structure"

[BACKDROP]

DIMENSIONS	2486665.00	1314604.00	2958321.00	1585560.00
UNITS	None			
FILE				
OFFSET	0.00	0.00		

[END]

Appendix C
Supplier Information

Stewart, Sarah

From: Michael.Wood@amwater.com
Sent: Friday, January 28, 2011 11:53 AM
To: Stewart, Sarah
Cc: Bernard.Meyer@amwater.com; Derek.Linam@amwater.com;
Christopher.Parrish@amwater.com
Subject: Great Northwest Wholesale Water Commission
Attachments: 2009 WQ Report.pdf; 2982_001.pdf

Sarah:

I promised you a response today. I can write a letter next week addressing everything if this is not adequate but wanted to pass along what I have to date. I will address each of your bullet points below.

There have been no significant changes in operations or water treatment from our last update provided. Majority of that information can be utilized for this update.

1) We do utilize chloramines for disinfection and the plant is rated at 30 mgd.

2) The Missouri American Water Company's St. Joseph District owns and operates a well field and treatment plant in southwestern Andrew County. Raw water is taken from the Missouri River alluvium by seven, 3 MGD vertical-drilled wells and/or one collector well consisting of seven horizontal-drilled wells, and containing three pumping units rated at 6 MGD each. The raw water travels from the well field to the 30mgd ground water treatment plant through two, 36-inch raw water lines.

The raw water enters the plant and an initial dose of chlorine is added for disinfection/oxidation. The water then moves through two mixing chambers where ferric, polymer, and carbon can be added to condition the water for removal of excess iron and manganese. The water then flows to any of 3 process clarifiers. At the point the water enters the clarifiers, slaked lime is added to raise the pH and reduce hardness. The clarifiers allow the precipitated minerals to settle for removal to lagoons located on the plant property. Prior to filtration, polyphosphate is added to sequester the remaining minerals. The water then proceeds to any of 6 dual-media filters, which have a rating of six MGD each. After filtration, additional chlorine is added with ammonia to create a chloramine for disinfection purposes. The water is then fluoridated and stored in a 1.5 mg below ground concrete clear well.

Meeting Phase 1 Demand - should not be a major issue if current demands do not change.
Meeting Total Commission Demand - I will have our Engineering Department evaluate and provide comments.

Preferred connection point would be at our Treatment Plant.

I am attaching a copy (pdf) of our most recent Consumer Confidence Report.
(See attached file: 2009 WQ Report.pdf)

Necessary Capital Improvements - requires further review

Capability to finance - May not be applicable depending upon Engineering comments from bullet point above.

Cost of water - See attached pdf of current rates.

(See attached file: 2982_001.pdf)

5 Year average of Wholesale Customers - not readily available.


Timeline to construct improvements - May not be applicable depending upon Engineering comments from bullet point above.

I hope this supplies you with enough information to proceed with study. If you need anything additional, please advise.

Thanks

Michael Wood
Operations Manager
Missouri American Water Company
Northwest Operations
3901 Beck Road, Suite B
St. Joseph, MO 64506
Office (816) 233-4000 Ext. 2222
Internal 7-412-2222
Cell (816) 262-5246
Home (816) 689-6306

2009 Annual Water Quality Report



St. Joseph

PWS ID: MO1010714

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

A Message from the Missouri American Water President

Missouri American Water is proud to be your local water company. Our lives revolve around water. It's in everything we do, everything we use. That's why it's important that we share with our customers information about our commitment to providing high-quality water service – a service you enjoy at about a penny a gallon.

I am pleased to provide you with the 2009 Annual Water Quality Report with detailed information about the source and quality of your drinking water. We have prepared this report using the data from water quality testing conducted for your local water system from January through December 2009. You'll find that we supply water that surpasses or meets all federal and state water quality regulations.

Just as important, we place a strong focus on acting as stewards of our environment. In Missouri, we participate in activities that help communities protect the watershed and educate customers on how to use water wisely. You can learn more about these programs on our website at www.missouriamwater.com.

Also in 2009, RWE Group sold its remaining shares of American Water stock, completing the divestiture of American Water from RWE Group. As a subsidiary of American Water, we are proud to celebrate this milestone.

At Missouri American Water, we deliver more than just water. We deliver a key resource for public health, fire protection, economic opportunity and the overall quality of life we enjoy. We also deliver value – our water service costs about a penny a gallon! It's part of our commitment to serve you and everyone in the community. For more information or for additional copies of this report, visit us online at www.missouriamwater.com or contact our Customer Service Center at 1-866-430-0820.

Sincerely,

Frank Kartmann
President
Missouri American Water

A+ WATER QUALITY FOR LESS THAN A PENNY

Did you know that you pay less than a penny for a gallon of your tap water?

Providing high-quality water service is our business. Our team of water quality experts and certified operators monitor your water from source to tap, and we have an exceptional track record when it comes to water quality. **Our compliance record for meeting or surpassing state and federal drinking water standards was 100 percent last year.** That beats the national average.

Tap water: an exceptional value!

WE CARE ABOUT WATER. IT'S WHAT WE DO.

What is a Water Quality Report?

To comply with state and U.S. Environmental Protection Agency (USEPA) regulations, Missouri American Water issues a report annually describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect drinking water sources. In 2009, we conducted tests for hundreds of contaminants, all of which were below state and federal maximum allowable levels. This report provides an overview of last year's (2009) water quality. It includes details about where your water comes from and what it contains.

If you have any questions about this report or your drinking water, please call our Customer Service Center at (toll-free) 1-866-430-0820.

About Missouri American Water

Founded in 1886, American Water is the largest investor-owned U.S. water and wastewater utility company. With headquarters in Voorhees, N.J., the company employs more than 7,000 dedicated professionals who provide drinking water, wastewater and other related services to approximately 15 million people in 32 states and Ontario, Canada.

At Missouri American Water, and all of American Water, we work hard everyday to provide our customers with water they can enjoy and use with confidence.

Source Water Information

Missouri American Water supplies quality drinking water to more than 32,000 residential, commercial and industrial customers in the City of St. Joseph. The St. Joseph District also supplies water to four water districts and the neighboring cities of Elwood and Wathena, Kansas. The St. Joseph water treatment plant uses groundwater taken from numerous vertical wells and a horizontal collector well.

How to Contact Us

For more information regarding this report or any of the other services provided by Missouri American Water, please call our Customer Service Center at (toll-free) 1-866-430-0820, or you may visit us at www.missouriamwater.com.

Water Information Sources

- **Missouri American Water**
www.missouriamwater.com
- **Missouri Department of Natural Resources**
www.dnr.mo.gov
- **United States Environmental Protection Agency**
www.epa.gov/safewater
- **Safe Drinking Water Hotline:** (800) 426-4791
- **Centers for Disease Control and Prevention**
www.cdc.gov
- **American Water Works Association**
www.awwa.org
- **Water Quality Association**
www.wqa.org
- **National Library of Medicine/
National Institute of Health**
www.nlm.nih.gov/medlineplus

Substances Expected to be in Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and groundwater wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

Contaminants that may be present in source water include:

Microbial Contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants, such as salts and metals, which can be naturally occurring or may result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides, which may come from a variety of sources, such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive Contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

For more information about the contaminants and potential health effects, call the USEPA's Safe Drinking Water Hotline at (800) 426-4791.

St. Joseph Water Treatment Facility Earns Special Recognition

The Missouri Department of Natural Resources honored Missouri American Water's St. Joseph Treatment Facility for successful completion of the Missouri Environmental Management Partnership Program (MEMP). The partnership encourages organizations to improve their environmental performance by developing and implementing an environmental management system (EMS). Missouri American Water is the first company in Missouri to receive this distinction. Environmental management is an integral part of Missouri American Water's operations. Achieving Advanced Partner status in the MEMP Program has allowed us to increase environmental awareness and reduce environmental risks. Missouri American Water's participation in this program is an example of the company's dedication to making environmental management a fundamental part of the business. As providers of high quality, affordable water, our responsibility is to not only protect one of our most precious resources but to improve the environment.

Special Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the USEPA's Safe Drinking Water Hotline (800) 426-4791.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Missouri American Water is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

To ensure that tap water is of high quality, the USEPA prescribes regulations limiting the amount of certain substances in water provided by public water systems. U.S. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Missouri American Water's advanced water treatment processes are designed to reduce any such substances to levels well below any health concern.

How to Read This Table

Missouri American Water conducts extensive monitoring to ensure that your water meets all water quality standards. The results of our monitoring are reported in the following tables. While most monitoring was conducted in 2009, certain substances are monitored less than once per year because the levels do not change frequently. For help with interpreting this table, see the "Table Definitions" section.

Starting with a **Substance**, read across. **Year Sampled** is usually in 2009 or year prior. **MCL** shows the highest level of substance (contaminant) allowed. **MCLG** is the goal level for that substance (this may be lower than what is allowed). **Results** represents the measured amount (less is better). **Range** tells the highest and lowest amounts measured. A **Yes** under **Compliance Achieved** means the amount of the substance met government requirements. **Typical Source** tells where the substance usually originates.

Unregulated substances are measured, but maximum contaminant levels have not been established by the government.

Definitions of Terms Used in This Report

- **AL (Action Level):** The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.
- **MCL (Maximum Contaminant Level):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **MCLG (Maximum Contaminant Level Goal):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **MRDL (Maximum Residual Disinfectant Level):** The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **MRDLG (Maximum Residual Disinfectant Level Goal):** The level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.
- **NA:** Not applicable
- **ND:** Not detected
- **pCi/L (picocuries per liter):** Measurement of the natural rate of disintegration of radioactive contaminants in water (also beta particles).
- **ppm (parts per million):** One part substance per million parts water, or milligrams per liter.
- **ppb (parts per billion):** One part substance per billion parts water, or micrograms per liter.

Water Quality Statement

We are pleased to report that during the past year, the water delivered to your home or business complied with all state and federal drinking water requirements. For your information, we have compiled a list in the table, showing what substances were detected in your drinking water during 2009. Although all of the substances listed below are under the Maximum Contaminant Level (MCL) set by the USEPA, we feel it is important that you know exactly what was detected and how much of the substance was present in the water. For additional information concerning our results, please contact our customer service department at (toll-free) 1-866-430-0820.

Monitoring was also done during 2008 and 2009 under the U.S. Environmental Protection Agency (USEPA) Unregulated Contaminant Monitoring Rule 2 (UCMR2). Data is available on the USEPA's web site (www.epa.gov/safewater/data/ucmrgetdata.html).

There are many unforeseen and unpredictable factors that may cause a source water to be contaminated. The Missouri Department of Natural Resources routinely monitors all public water supplies to ensure public health is protected. Source Water Assessments have been assembled by the Missouri Department of Natural Resources to evaluate the susceptibility of contamination to our drinking water sources. For more information about these assessments call the Missouri Department of Natural Resources at (800) 361-4827.

Water Quality Results

Regulated Substances (Measured on the Water Leaving the Treatment Facility)							
Substance (units)	Year Sampled	MCL	MCLG	Results	Range Low-High	Compliance Achieved	Typical Source
Alpha emitters (pCi/L)	2008	15	0	2.4	1.5 - 3.9	Yes	Erosion of natural deposits
Barium (ppm)	2009	2	2	0.12	0.11 - 0.13	Yes	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Chloramines (ppm)	2009	TT	NA	3.1	2.8 - 3.4	Yes	Water additive used to control microbes
Di(2-ethylhexyl)phthalate (ppb)	2009	6	0	0.4	ND - 1.1	Yes	Discharge from rubber and chemical factories
Fluoride (ppm)	2009	4	4	0.7	0.7 - 0.8	Yes	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate (as N) (ppm)	2009	10	10	0.05	0.03 - 0.07	Yes	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite (as N) (ppm)	2009	1	1	0.01	0.01 - 0.01	Yes	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Bacterial Results (from the Distribution System)							
Substance (units)	Year Sampled	MCL	MCLG	Highest Percentage Detected	Compliance Achieved	Typical Source	
Total Coliform Bacteria	2009	5% Pos. Samples	0	0	Yes	Naturally present in the environment	
Other Compounds (Measured in the Distribution System)							
Substance (units)	Year Sampled	MCL	MCLG	Results	Range Low-High	Compliance Achieved	Typical Source
Chloramines (ppm)	2009	MRDL = 4	MRDLG = 4	2.3	2.3 - 3.0	Yes	Water additive used to control microbes
THMs [Total trihalomethanes] (ppb)	2009	80	NA	4.1	2.0 - 4.9	Yes	By-product of drinking water disinfection
HAA5 [Haloacetic Acids] (ppb)	2009	60	NA	5.2	3.7 - 6.2	Yes	By-product of drinking water disinfection
Unregulated Substances (Measured on the Water Leaving the Treatment Facility)							
Substance (units)	Year Sampled	Results	Range Low-High	Typical Source			
Bromodichloromethane (ppb)	2009	1.1	ND - 1.8	By-product of disinfection			
Chloroform (ppb)	2009	3.3	1.4 - 4.8	By-product of disinfection			
Sulfate (ppm)	2009	112	94.2 - 145.7	Erosion of natural deposits			
Tap Water Samples: Lead and Copper Results							
Substance (units)	Year Sampled	Action Level	MCLG	Number of Samples	90th Percentile	Number of Samples Above Action Level	Typical Source
Copper (ppm)	2007	AL = 1.3	1.3	30	0.163	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead (ppb)	2007	AL = 15	0	30	4.0	0	Corrosion of household plumbing systems; Erosion of natural deposits

Missouri-American Water Company
 Name of Issuing Corporation

For

City of St. Joseph and Vicinity Areas Only
 Community, Town or City

CLASSIFICATION OF SERVICE
GENERAL WATER SERVICE

Availability

Available for any metered customer located on Company mains suitable for supplying the service requested.

Rate

Billing Rate as follows:

Water Usage – 1,000 Gallons – Rate per 1,000 Gallons Per Month

		Residential	Commercial	Industrial	Public Authority	Sale For Resale
For the first	100	\$ 4.2705	\$4.2794	\$6.2732	\$ 4.2794	\$ 4.2794
For the next	1,900	4.2705	3.3234	3.5141	3.3234	3.3234
For the next	3,000	4.2705	2.7691	2.1196	2.7691	2.7691
For all over	5,000	4.2705	1.8886	1.7316	1.8886	1.8886

+
+
+
+

Water Usage – CCF – Rate per CCF

For the first	134	\$ 3.2029	\$ 3.2096	\$4.7049	\$3.2096	\$3.2096
For the next	2,533	3.2029	2.4925	2.6356	2.4925	2.4925
For the next	4,000	3.2029	2.0768	1.5897	2.0768	2.0768
For all over	6,667	3.2029	1.4164	1.2987	1.4164	1.4164

+
+
+
+

Monthly Minimum Charge

Meter Size	Per Month	Meter Size	Per Month
5/8"	\$ 9.26	4"	\$ 128.45
3/4"	11.85	6"	252.50
1"	16.80	8"	401.35
1 1/2"	29.22	10"	681.79
2"	44.11	12"	1,124.62
3"	78.85		

+
+
+
+
+
+
+

These rates do not include any municipal, state or federal taxes computed on either billing or consumption basis. Any such taxes applicable shall be added as separate items in rendering each bill.

Billing

Bills for water service will be distributed on a monthly basis. The due date on the tariff shall be ten (10) days after the "date of rendition" of the bill to the customer. The customer's bill will be due and payable after this due date. The delinquent date printed on the bill will not be less than twenty-one (21) days after the date of the postmark of the bill. Any accounts remaining unpaid at the expiration of twenty-one (21) days shall be considered delinquent and the Company may take such action as specified in its filed rules and regulations.

* Indicates new rate or text
 + Indicates change

DATE OF ISSUE: June 18, 2010

DATE OF EFFECTIVE: July 1, 2010

ISSUED BY: Frank Kartmann, President
727 Craig Road, St. Louis, MO 63141

January 24, 2011

Ms. Sarah A. Stewart, P.E.
CDM, Inc.
9200 Ward Parkway, Ste. 500
Kansas City, MO 64114

Subject: Re: Request for Proposals to Supply Potable Water to Great Northwest Wholesale Water Commission

Dear Ms. Stewart:

The following are responses to your January 6th, 2011, request:

- The initial phase of construction is under design and scheduled to go on line in mid 2013. The initial phase will have a firm capacity of 2.5 million gallons per day (MGD). The site was selected to allow for future expansions to a total capacity of 10 MGD. Of this total, approximately 4 MGD is planned to be held in reserve for the Atchison County area. The remaining 6 MGD is potentially available for sale to the Great Northwest Wholesale Water Commission.
- The residual disinfectant used by the plant will be chloramines.
- The supply will come from nearby alluvial wells and the treatment process will include aerations, lime softening, pH adjustment and filtration.
- All of the initial phase capacity is slated for existing members of the Atchison County Wholesale Water Commission (ACWWC). Providing water to the Great NW Wholesale Water Commission would require additional construction in well, treatment and transmission systems.
- A copy of the 2010 Community Confidence Report cannot be included since there was no water treatment conducted in 2010.
- Financing any future improvements will be considered on a case by case basis.
- The wholesale rate would depend on agreed upon financing terms, up front contributions and the level of grants available from the federal government. Following is an estimate using the November 2008 Facility Plant rate estimates (Table 9.5) and these assumptions:
 - No grant funds.
 - Construction of wells and treatment similar to the project under design.
 - Similar financing terms as indicated in Table 9.5.
 - Similar reserve practices as indicated in Table 9.5.
 - A population served that fully uses the contracted supply. The numbers shown in the first scenario of Table 9.5 anticipates expansion in the local water district and customers in Atchison County by a factor of 5,076/2,157 or 2.35. The resulting wholesale rate for 5,000 gallons is \$64 per month or \$12.80 per thousand gallons.
 - Total project costs for supply and plant, excluding transmission is 73% ((22-6)/22) of the loan indicated in Table 9.5.

○ Maximum supply is 6 MGD.
The resulting calculation is: $\$12.80 \text{ per thousand gallons} \times 73\% / 2.35 = \$3.98 \text{ per thousand gallons}$ or approximately \$4.00 per thousand gallons. These numbers should be escalated to account for inflation since November 2008.

If you have any further questions, please contact me.

Sincerely,



Bruce Hattig, P.E.

cc: Kyra Mills, Chairperson, Atchison County Wholesale Water Commission

Drinking Water Facilities Plan

Water Treatment Plant Improvements

City of Savannah, Missouri

By



City Contact	Engineer Contact
Mike Fischer, City Administrator City Hall 402 Court Street Savannah, MO 64485 Ph 816-324-3315	Casey Patton Bartlett & West 3110 Karnes Rd, St Joseph, MO 64506 Ph 816-364-3551

Only relevant portions of this Drinking Water Facilities Plan are included for reference to the Stage 1 Pipeline PER.

Introduction

This study was commissioned by the City of Savannah, Missouri in an effort to develop a long-term plan for improving the efficient use and expansion of their water treatment plant and related facilities. Specifically the City identified three areas of concern for evaluation within the study to assist them in addressing their long-term planning needs. Those areas and their corresponding divisions within the study are as follows:

- **PART I - EXPANSION OF THE WATER TREATMENT FACILITY**

Develop a facility plan for expansion of their water treatment plant (WTP) in order to provide future service to wholesale water customers and support growth of the City.

- **PART IIA - ALTERNATE WIND ENERGY SOURCE**

Review the potential costs and related benefits for developing an alternate wind energy source.

- **PART IIB -METHODS OF ENERGY CONSERVATION**

Review methods of energy conservation within current operations that would lower their electrical costs.

- **PART III - CHLORINE VERSUS CHLORAMINE**

Address the issues related to the use of free chlorine versus chloramines as it relates to potential service to wholesale customers and the City service. Review the efficiencies of current disinfection operations and areas for improvement.

In each section of this study, a number of alternatives were considered and the benefits and costs evaluated. Upon evaluation, recommendations are made to assist the City in moving forward.

Year	Average Day Use *	Peak Day Use **	Ratio of Peak to Avg. Day Use
2004	412,816	620,000	1.50
2005	510,444	774,000	1.52
2006	556,016	881,000	1.58
2007	575,315	1,003,000	1.74
2008	533,205		
2009	530,174	800,000	1.51
2010	552,165	793,000	1.44

**Total water use and the peak to average day ratio includes both Savannah municipal water use and water sold to Public Water Supply District No.3 (PWSD No 3) of Andrew County.*


*** Peak Day in 2007 is high due to a leak in the system, no data is available for 2008.*

While the City meters water use at each household within town, this information was not readily available to compare with metered use at the water treatment plant. However the per capita-day water use is consistent with other towns the size of Savannah. As such, we would anticipate the unaccounted for water use, as a percent of the total demand to be approximately 10%.

Unaccounted for water use reflects water loss due to backwashing, fighting fires, flushing mains and hydrants, system leaks and repairs, and unmetered parks, swimming pools, or other public facilities. There are 2,061 household meters within the City and the City is currently implementing a program to replace each meter with a wireless read system to further track and reduce water loss.

Water Use Projections

The following table and graph are provided showing the current and future water use projections for the City of Savannah and Andrew County PWS District No 3. As indicated, water use projections are determined using the estimates of population growth presented earlier in this study, a water use rate of 95 gallons per capita-day and a peaking factor of 1.60. Water use projections similar to population projections are for the 30-year study period.



Population and Water Use Projections			
City of Savannah, Missouri			
Year	City Population	Avg.Day Water Use MGD	Peak Day Water Use MGD
2005	4,812	0.510	0.77
2006	5,002	0.556	0.88
2009	5,107	0.530	0.80
2010	5,150	0.563	0.90
2020	5,605	0.612	0.98
2030	6,100	0.666	1.07
2040	6,639	0.725	1.16

Wholesale Water Use and Sales

As indicated, the City currently sells water to PWSD No 3 of Andrew County and has done so since November of 2004. The interconnection is located west of town near the old treatment plant and the intersection of highway 71 and County Road 427. Sales to their system are metered at the point of connection and for the purposes of this study will be estimated at about 15% of water used or 81,000 gallons per day. The City is currently renegotiating a new purchase agreement with PWSD No 3.

Informally, the City of Savannah has also discussed the potential of interconnection and selling water to Andrew County PWSD 1. Their estimated water use, as documented in a letter in 2007 (see Appendix), indicates a current peak day of 900,000 gallons per day and a future peak day of 1.4 MGD. In the fall of 2008, the City of Savannah also voted and agreed to join the Great Northwest Wholesale Water Commission (GNWWC) and has since been active in participating in planning sessions and hosting the regional meetings.

V. Discussion of Alternatives


For this study, three different WTP expansion levels or alternatives were considered and evaluated for feasibility and planning purposes. Depending on the growth and development of other regional systems in proximity to the City of Savannah, these expansion alternatives may also be considered in phases. A brief description of each alternative is provided below along with a comparison of the additional system capacity and demand.

Alternate No. 1

This alternate considers the improvements needed within the system to maximize the use of their current treatment plant and related facilities with a minimum amount of capital expenditure. The improvements of this alternate requires increasing the system run time during peak conditions to 22 hours per day along with the following proposed capital improvements. The current treatment process, depending on water use and other system variables has a run time of 6-10 hours.

- Well Field/Raw Water Line --In an effort to increase the firm capacity at the well field and not to stress the existing wells which are all hydraulically connected, a third well in the area already test drilled is proposed along with the approximately one mile of connecting raw water line.
- WTP Improvements – Little physical expansion of the WTP is anticipated however the addition of a third high service pump (HSP) is proposed and added staff and maintenance expenses are anticipated with the added system run time.

As can be seen in the adjoining chart, the proposed improvements under Alternate No. 1 meet the current and future demand needs of the City and their current wholesale user PWSD No 3, to the year 2040 and beyond. In addition, the proposed improvements provide excess capacity of nearly 1.0 MGD and enable the City to add a large wholesale user with similar water use requirements of Andrew County PWSD #1. However, while initially meeting those demands, further expansion of the system would likely be required within a few years depending on growth and their final demand requirements.




Alternate No. 2

This expansion alternative addresses the system improvements that are needed to meet the water use of a wholesale customer equivalent to the size of PWSD No 1 of Andrew County in the year 2040. Those demands are estimated at 900,000 gpd for their current peak day use and 1.4 MGD for future peak day demand. The expansion effort in this scenario will require increasing the size and capacity of the major system components to 3.5 to 4.0 MGD. Specifically the improvements needed are as follows.

- Well Field/Raw Water Line –In addition to adding a fourth well as indicated above, a fifth well is proposed such that the peak day demand can be met with the largest well of the five wells out of service.
- WTP /Clearwell Improvements – As indicated above, this alternative would require expansion of major system components. In addition to chemical feed expansions, a two new solids contact basins and three or four additional filter cells would be required, depending on filter arrangement and design criteria. Additionally, clearwell capacity would likely need to be doubled at this stage, resulting in an overall cost of WTP & clearwell improvements of approximately \$4,060,000.

The adjoining chart compares the system capacity developed with Alternate No. 2 and Alternate No. 3 with potential water use.



Alternate No. 3

In this alternative, consideration was given to expansion of the treatment facilities and well field to meet a larger regional wholesale user such as the GNWWC. The projected system capacity for this alternate is estimated at 5.0 MGD. This is sufficient to meet projected water use needs for the City of Savannah and potential wholesale users Andrew County PWSD No. 1 and No. 3 with an additional 2.0 to 2.5 MGD dedicated to serving the regional needs of the Great Northwest Wholesale Water Commission GNWWC.

While it may be feasible to expand facilities beyond the limits of Alternate 3, additional effort beyond the scope of this study is needed to project that capacity. One constraint, without completing additional exploration and test pumping, is projecting the yield and development of new wells. For the purposes of this study, it is estimated that three new wells similar to the test well in 2004 can be developed. Other possible constraints include the availability of land at the WTP site for lime sludge lagoons and ready reconfiguration of the piping at the treatment facilities.

In addition to the three wells, the improvements of Alternate No. 3 include construction of new raw water pipeline, additional clearwell capacity, and a new 3.0 MGD treatment train; including solids contact basins, multi-media rapid rate filters, waste residuals handling and associated chemical feed equipment.

- Well Field/Raw Water Line – Approximately \$1,680,000 of improvements, including construction of three new 1,200 gpm wells and approximately 5 miles of 18” diameter raw water transmission pipeline.
- WTP Improvements – Approximately \$5,180,000 of improvements, including construction of two new 1.5 MGD treatment trains, each consisting of a solids contact basin, rapid rate filters, and chemical feed equipment. Also included are additional waste lagoons as required to handle the increased treatment residuals.

Project Criteria

Project design criteria as proposed are as per requirements for distribution systems, MoDNR Publication 417 -Design Guide for Community Water Systems and the 10 State Standards – Recommended Standards for Water Works. The project design period is 30 years with population and water use projections to the year 2040.

VI. Project Financing and Water Rates

City's Current Indebtedness and Budget

As part of the improvements in 2005 and 2006, the City issued 20-year revenue bonds for approximately 8 million in loans to construct the water system improvements. In 2009-2010, the debt service payment on the principle and interest of the bonds was \$699,000 or about 45% of the City budget of approximately 1.5 million. The debt service is slated to increase by approximately \$10,000 per year for the next 15 years before finally decreasing for eight years before the final two payments.

A summary of the current City water budget and an estimate of associated revenues from both bulk and metered sales are provided below.

VII. Project Budget with O & M Costs

Life Cycle Costs and Comparison of Alternatives

For each of the proposed alternates or level of expansion, capital costs were estimated and life cycle costs were developed. These life cycle costs are summarized below and include a comparison of the debt service, annual operating and maintenance (O & M) expenses, along with funds for long-term replacement and reserves. Annual operating costs include both the fixed and variable costs, the latter comprised of mostly chemical and electrical expenses.

Summary of Life Cycle Costs and Comparison of Alternatives		Current Budget	Alternate 1	Alternate 2	Alternate 3
Water Use and Plant Capacity					
Estimated Annual Water Use (X 1000gal)		197,465	410,692	410,692	866,942
City Annual Sales (X 1000gal)		167,845	174,572	174,572	174,572
Bulk Annual Sales (X 1000gal)		29,620	236,119	236,119	692,369
System Capacity		1.0 MGD	2.0 MGD	3.8 MGD	5.0 MGD
Capital Cost Summary					
Well Field/Raw Water Line		\$0	\$260,000	\$490,000	\$1,680,000
WTP Improvements		\$0	\$120,000	\$4,060,000	\$5,180,000
Total New Capital Costs		\$0	\$380,000	\$4,550,000	\$6,860,000
Annual Expenses & Production Costs					
Annual Debt Service					
New Improvements Debt Service		\$0	\$30,094	\$360,336	\$543,276
Current Annual Debt Service (P & I)		\$699,000	\$799,000	\$799,000	\$799,000
Total Annual Debt Service		\$699,000	\$829,094	\$1,159,336	\$1,342,276
Admin Costs					
City Annual Retail/Admin Costs		\$220,800	\$220,800	\$220,800	\$220,800
Annual Operating Costs					
Fixed Operating Costs		\$337,200	\$437,200	\$660,000	\$760,000
Variable Operating Costs, (\$0.93/kgal)		\$183,000	\$382,000	\$382,000	\$806,000
Subtotal		\$520,200	\$819,200	\$1,042,000	\$1,566,000
Rehab/Reserve, Existing Facilities		\$92,000	\$92,000	\$92,000	\$92,000
Rehab/Reserves, New Improvements		\$0	\$15,047	\$180,168	\$271,638
Annual Operating Costs		\$612,200	\$926,247	\$1,314,168	\$1,929,638
Total Annual Expenses		\$1,532,000	\$1,976,141	\$2,694,304	\$3,492,713
Unit Price Cost Comparison					
Cost of Debt Service (\$/kgal)		\$3.54	\$2.02	\$2.82	\$1.55
Cost of Operation (\$/kgal)		\$3.10	\$2.26	\$3.20	\$2.23
*Total Production Cost (\$/kgal)		\$6.64	\$4.27	\$6.02	\$3.77
* Excludes City Admin Costs					

The production costs as tabulated above include both the debt service and operating costs divided by the projected annual water sales. It does not include the City administration and billing costs. The unit price cost comparison of production costs is intended as a tool to evaluate the economic feasibility of the different alternatives.

Capacity Charge

As an alternate to charging bulk users their debt service charge in their water bill, the City may consider providing bulk users the option of a lump sum capacity charge. This capacity charge allows the bulk user, based on their projected peak demand to “purchase” treatment and source capacity from the City. This defines the maximum allowable water use in their User Agreement and allows the bulk user to seek alternate forms of financing their share of the debt service.

The advantage of this approach is it recognizes that some bulk users may have access to better loan terms or even be able to secure grants for which the City of Savannah may not be eligible or be able to access. In this approach the basis for the bulk user’s water rates are the operating costs and the perimeters for this calculation are mutually agreed upon prior to connection.

VIII. Conclusions and Recommendations

Maximize Existing Facility

As a first step in improving efficiencies, the City should consider maximizing the use of their existing treatment plant by increasing run times and securing additional bulk water sales. With rather small capital expenditures at the well field and high service pumps, the City could significantly increase production and sell the excess to a large wholesale user. This would spread the debt service and fixed operating costs over a larger number of users and resulting in lower production costs.

Important in adding a new large wholesale user will be the wording of the agreement to protect and enable the City to manage future system growth. As noted by the higher operating and debt service unit costs for Alternate No. 2, an expansion of facilities must be carefully phased with added demand to maintain these efficiencies and cost savings.

Expansion of the Treatment Plant

The efficiencies of expanding and operating a larger system will, in the long-term, have an impact on lowering the City’s production costs on a unit price basis. This is due to the efficiencies of operating a larger treatment facility as well as having a larger number of users participating in the system operating costs and repayment of debt service. The most cost efficient expansion is the larger 5.0 MGD facility that allows Savannah to serve the local wholesale users as well as the Great Northwest Wholesale Water Commission (GNWWC).

Recover Production Costs

It is important to note that the success of any future expansion of facilities is contingent on the City negotiating a rate for their bulk water sales that covers their cost of production and debt service for capital expenses as well as contributing to the equipment reserve and replacement fund. In all of the alternates outlined in this study, the average water bill in the City would be negatively impacted if these costs are not shared by all the users.

the City. As such, the change from chlorine to chloramines to reduce DBPs provides little advantage for the City users. The change already outlined is also complex, with the potential for nitrification and biofilm formation. This would be true not only for the City distribution system but also for their current wholesale user Andrew County PWSD No. 3.

While switching to chloramines would extend the residual within the distribution system, the current use of free chlorine has worked well for the City, allowing them to maintain a consistent residual within their distribution system, despite the shorter residual time of free chlorine.

Finally, because the City must continue to use free chlorine as the primary disinfectant at their treatment plant the addition of another disinfectant at the treatment facility will add costs and complexity to the operation.

Recommended Alternative

It is recommended that the City consider each potential wholesale user on a case by case basis. If a new wholesale user requires the addition of chloramines for secondary disinfection in their system, the injection point can be provided at the master meter location. The cost increase for adding a liquid chlorine and ammonia injection system at a master meter pit location is estimated at about \$70,000. This would include a 6 x 10 foot building, free and total chlorine analyzers, metering and chemical feed equipment, and a 100-200 gallon mixing tank with palletized dry chemical storage area. Depending on flows required, a gas chlorination system may prove to be more economical, though it would likely require a larger building and initial capital costs would be closer to \$125,000. However depending on the chlorine residual and output requirements, chemical costs for a liquid chlorine system would be about \$0.05 per thousand gallons while chemical costs for a gas system would be less than half that amount. The City could have the new wholesale user pay for this as part of the connection fee and also make them responsible of the operation and maintenance of the new facility.

VI. Secondary Disinfection's Point of Injection

Currently the third injection site for the chlorine gas is located between the filters and the clearwell. The purpose of this chlorine injection location is to provide both primary disinfection, 4-log virus removal/inactivation, and secondary disinfection, maintaining a residual in the distribution system. Typically, the primary disinfection is located downstream of the filters to help reduce DBP formation and the secondary disinfection would be provided as the water enters the distribution system, if needed. If a secondary disinfectant system is considered to be a benefit for the distribution system then the injection point should be located between the ground storage reservoir and the high service pumps.

VII. Conclusions

Appendix D
Cost Options

ACWWC Cost Options

Date: 7 March 2011

By: Molly Pesce

Checked: Bruce Hattig

Re: 16164.010 Great NW Phase IV, Stage I Total Cost, Atchison Co Alternative

Assumptions & Givens:

KC CCI Value for Dec. 2010 = 10410.12
KC CCI Value for March 2009 = 9667.81
KC CCI Value for Dec. 2001 = 6477.21

OPCC Pipeline without Davies 1²			
Diameter	Length (feet)	Unit Cost (per foot) ¹	Extension
6	27,300	\$ 27.00	\$ 740,000
8	12,100	\$ 39.00	\$ 480,000
12	164,800	\$ 60.00	\$ 9,890,000
16	58,300	\$ 81.00	\$ 4,730,000
20	74,000	\$ 101.00	\$ 7,480,000
24	202,500	\$ 121.00	\$ 24,510,000
30	130,400	\$ 151.00	\$ 19,700,000
Total			\$ 67,530,000

1) Notes: Unit prices include design, material, installation and land.

2) Notes: Pipe lengths were rounded to the nearest 100, unit cost per foot were rounded to nearest dollar and every subtotal was rounded up to the nearest \$10,000.

OPCC Pipeline for Davies 1²			
Diameter	Length (feet)	Unit Cost (per foot) ¹	Extension
12	105,100	\$ 60.00	\$ 6,310,000
Total			\$ 6,310,000

Date: 7 March 2011

By: Molly Pesce

Checked: Bruce Hattig

Re: 16164.010 Great NW Phase IV, Stage I Total Cost, Atchison Co Alternative

OPCC Elevated Water Storage Tanks/Stand Pipes			
Tank ID	Height (feet)	Volume (x1000 gal)	Extension ¹
1	140	400	\$ 970,000
2	63	200	\$ 550,000
Total			\$ 1,520,000

OPCC Pump Stations						
Pump Station ID	Flow (gal/min)	Flow (MGD)	Head	Total HP	Number of Pumps	Extension ¹
1	4,170	6.00	376	650	4	\$ 1,730,000
Total						\$ 1,730,000

OPCC for ACWWC Stage I Option		
	w/o Davies I	w/ Davies I
Transmission Lines	\$ 67,530,000	\$ 73,840,000
Elevated Water Storage Tanks	\$ 1,520,000	\$ 1,520,000
Pump Stations	\$ 1,730,000	\$ 1,730,000
Total	\$ 70,780,000	\$ 77,090,000

Date: 7 March 2011

By: Molly Pesce

Checked: Bruce Hattig

Re: 16164.010 Great NW Phase IV, Stage I Total Cost, Atchison Co Alternative

Total Cost Summary		
	w/o Davies I	w/ Davies I
Construction, Land & Engineering	\$ 70,780,000	\$ 77,090,000
Legal & Financial (5%)	\$ 3,540,000	\$ 3,860,000
Contingency & Inflation (20%)	\$ 14,160,000	\$ 15,420,000
Total	\$ 88,480,000	\$ 96,370,000

Missouri-American Cost Options

Date: 26 April 2011

By: Molly Pesce

Checked: Bruce Hattig

Re: 16164.010 Great NW Phase IV, Stage 1 Total Cost, MO American Alternative

Revised to add storage to the suction side of the Pump Station near Missouri American's WTP. One storage unit is assumed for Stage I.

Assumptions & Givens:

Kansas City Construction Cost Index (KC CCI) Value

for Dec. 2010 = 10410.12

KC CCI Value for March 2009 = 9667.81

KC CCI Value for Dec. 2001 = 6477.21

Opinion of Probable Construction Costs (OPCC) Pipeline without Davies 1²			
Diameter	Length (feet)	Unit Cost (per linear foot) ¹	Extension
6	27,300	\$ 27.00	\$ 740,000
8	12,100	\$ 39.00	\$ 480,000
12	225,800	\$ 60.00	\$ 13,550,000
16	53,000	\$ 81.00	\$ 4,300,000
20	73,000	\$ 101.00	\$ 7,380,000
24	87,600	\$ 121.00	\$ 10,600,000
Total			\$ 37,050,000

1) Notes: Unit prices include design, material, installation and land.

2) Notes: Pipe lengths were rounded to the nearest 100, unit cost per foot were rounded to nearest dollar and every subtotal was rounded up to the nearest \$10,000.

OPCC Pipeline for Davies 1²			
Diameter	Length (feet)	Unit Cost (per linear foot) ¹	Extension
12	105,100	\$ 60.00	\$ 6,310,000
Total			\$ 6,310,000

Date: 26 April 2011

By: Molly Pesce

Checked: Bruce Hattig

Re: 16164.010 Great NW Phase IV, Stage 1 Total Cost, MO American Alternative

OPCC Elevated Water Storage Tanks/Stand Pipes			
Tank ID	Height (feet)	Volume (x1000 gal)	Extension ¹
1	140	400	\$ 970,000
2	63	200	\$ 550,000
Clearwell	--	900	\$ 1,800,000
Total			\$ 3,320,000

OPCC Pump Stations/Flow Control						
Pump Station ID	Flow (gal/min)	Flow (MGD)	Head	Total HP	Number of Pumps	Extension ¹
1	4,170	6.00	255	450	3	\$ 1,250,000
Flow Control Structure	--	--	--	--	--	\$ 80,000
Total						\$ 1,330,000

OPCC for MO American Stage I Option		
	w/o Davies I	w/ Davies I
Transmission Lines	\$ 37,050,000	\$ 43,360,000
Elevated Water Storage Tanks	\$ 3,320,000	\$ 3,320,000
Pump Stations	\$ 1,330,000	\$ 1,330,000
Total	\$ 41,700,000	\$ 48,010,000.00

Date: 26 April 2011

By: Molly Pesce

Checked: Bruce Hattig

Re: 16164.010 Great NW Phase IV, Stage 1 Total Cost, MO American Alternative

Total Cost Summary		
	w/o Davies I	w/ Davies I
Construction, Land & Engineering	\$ 41,700,000	\$ 48,010,000
Legal & Financial (5%)	\$ 2,090,000	\$ 2,410,000
Contingency & Inflation (20%)	\$ 8,340,000	\$ 9,610,000
Total	\$ 52,130,000	\$ 60,030,000

Savannah Cost Options

Date: 7 March 2011

By: Molly Pesce

Checked: Bruce Hattig

Re: 16164.010 Great NW Phase IV, Stage I Total Cost, Savannah Alternative

Assumptions & Givens:

KC CCI Value for Dec. 2010 = 10410.12

KC CCI Value for March 2009 = 9667.81

KC CCI Value for Dec. 2001 = 6477.21

OPCC Pipeline without Davies 1²			
Diameter	Length (feet)	Unit Cost (per foot) ¹	Extension
6	27,300	\$ 27.00	\$ 740,000
8	12,100	\$ 39.00	\$ 480,000
12	254,500	\$ 60.00	\$ 15,270,000
16	53,000	\$ 81.00	\$ 4,300,000
20	73,000	\$ 101.00	\$ 7,380,000
24	30,300	\$ 121.00	\$ 3,670,000
Total			\$ 31,840,000

1) Notes: Unit prices include design, material, installation and land.

2) Notes: Pipe lengths were rounded to the nearest 100, unit cost per foot were rounded to nearest dollar and every subtotal was rounded up to the nearest \$10,000.

OPCC Pipeline for Davies 1²			
Diameter	Length (feet)	Unit Cost (per foot) ¹	Extension
12	105,100	\$ 60.00	\$ 6,310,000
Total			\$ 6,310,000

Date: 7 March 2011

By: Molly Pesce

Checked: Bruce Hattig

Re: 16164.010 Great NW Phase IV, Stage I Total Cost, Savannah Alternative

OPCC Elevated Water Storage Tanks/Stand Pipes			
Tank ID	Height (feet)	Volume (x1000 gal)	Extension ¹
1	140	400	\$ 970,000
2	63	200	\$ 550,000
Total			\$ 1,520,000

OPCC Pump Stations						
Pump Station ID	Flow (gal/min)	Flow (MGD)	Head	Total HP	Number of Pumps	Extension ¹
1	4,170	6.00	255	450	3	\$ 1,250,000
Flow Control Structure	--	--	--	--	--	\$ 80,000
Total						\$ 1,330,000

OPCC for Savannah Stage I Option		
	w/o Davies I	w/ Davies I
Transmission Lines	\$ 31,840,000	\$ 38,150,000
Elevated Water Storage Tanks	\$ 1,520,000	\$ 1,520,000
Pump Stations	\$ 1,330,000	\$ 1,330,000
Total	\$ 34,690,000	\$ 41,000,000

Date: 7 March 2011

By: Molly Pesce

Checked: Bruce Hattig

Re: 16164.010 Great NW Phase IV, Stage I Total Cost, Savannah Alternative

Total Cost Summary		
	w/o Davies I	w/ Davies I
Construction, Land & Engineering	\$ 34,690,000	\$ 41,000,000
Legal & Financial (5%)	\$ 1,740,000	\$ 2,050,000
Contingency & Inflation (20%)	\$ 6,940,000	\$ 8,200,000
Total	\$ 43,370,000	\$ 51,250,000