

Annual Equipment Check

Facility ID: ST####

Facility Name: ABC Gas Station
 Address: 100 Main, Anytown, MO

ATG Operability Check

Tank #	Reg 1	Reg 2	Prem	Diesel	Dye-diesel	
ATG manufacturer	FF	FF	FF	FF	FF	
ATG model	TS-550	TS-550	TS-550	TS-550	TS-550	
Tank probe checked	√	√	√	√	√	
Interstitial probe checked	---	---	---	---	---	
Tank top sealed	√	√	√	√	√	
Pass/Fail	Pass	Pass	Pass	Pass	Pass	

I checked the automatic tank gauging system in accordance with federal requirements and the manufacturer's operability check procedures. This included testing the alarm, verifying proper setup, testing battery (unless data is electronically remotely stored), inspecting probes/sensors for buildup, and checking that the floats move freely, cables are in good shape, product and water level readings are accurate, and equipment is properly communicating.

Technician: John Doe Manufacturer Certification: #1234 Date: 2/14/17

Line Leak Detector Operability Check

Line #	Reg 1	Reg 2	Prem	Diesel	Dye-diesel	
LLD manufacturer	Redjacket	Redjacket	Redjacket	Redjacket	Redjacket	
LLD model	FX1V	FX1V	FX1V	FX1DV	FX1DV	
Serial #	#####	#####	#####	#####	#####	
New LLD – If yes, serial #	----	----	----	----	Yes- new	
STP cycles	√	√	√	√	√	
Pump Operating Pressure (psi)	28 psi	27 psi	28 psi	29 psi	27 psi	
Holding Pressure (psi)	19 psi	17 psi	18 psi	17 psi	16 psi	
Metering Pressure (psi)	10 psi	12 psi	10 psi	11 psi	12 psi	
Opening Time (sec)	2 sec	3 sec	2 sec	2 sec	2 sec	
Resiliency (ml)	67 ml	82 ml	50 ml	76 ml	54 ml	
Pass/Fail	Pass	Pass	Pass	Pass	Pass	

I simulated a 3.0 gallon/hour leak at 10psi, or equivalent, and tested the operability of the line leak detector in accordance with the manufacturer's operability check procedures.

Technician: John Doe Manufacturer Certification: #1234 Date: 2/14/17

Annual Walkthrough Inspection

I checked all of the required containment sumps. I looked for damage, removed liquid/debris, and looked for leaks from equipment or releases to the environment.

- Repairs needed, documentation or invoice attached
- Double-walled containment sumps, interstice check (test attached, if appropriate)
- Hand-held release detection equipment present and checked if appropriate

Technician: John Doe Manufacturer Certification: #1234 Date: 2/14/17