

Proposed Underground Storage Tank Compliance Dates

July 1, 2017

July 1, 2019

Jan. 1, 2020

July 1, 2020

July 1, 2017	July 1, 2019	Jan. 1, 2020	July 1, 2020
New USTs must be double-walled/interstitial monitoring	<i>Existing</i> Airport, Field Constructed Tanks must comply with all regs but release detection	1 st Spill Bucket Test required	Vapor Monitoring sunsets as a release detection method (without chemical marker)
Replaced piping must be double-walled/interstitial monitoring	<i>Existing</i> Airport, Field Constructed Tanks must register	1 st Overfill Prevention Equipment Test required	Groundwater Monitoring sunsets as a release detection method
Dispenser replacement requires sump install		1 st Walkthrough inspection due	<i>Existing</i> Airport, Field Constructed Tanks must comply with release detection regs
Spill, Overfill and Containment Sump Test required at install		1 st operability test of release detection equipment due	
<i>New</i> Airport, Field Constructed Tanks must comply with all regs		New linings must be UL1856 'listed'	

*Anticipated Rule Effective Date April 30, 2017