

STATE OF MISSOURI

DEPARTMENT OF NATURAL RESOURCES

MISSOURI CLEAN WATER COMMISSION



MISSOURI STATE OPERATING PERMIT

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92nd Congress) as amended,

Permit No.: MO-0113191

Owner: Jefferson County Public Sewer District
Owner's Address: PO Box 632, Cedar Hill, MO 63016

Continuing Authority: Same as above
Address: Same as above

Facility Name: Sunrise Acres Subdivision
Facility Address: 7925 Graham Road, Cedar Hill, MO 63016

Legal Description: SW ¼, NE ¼, NW ¼, Sec 30, T42N, R4E, Jefferson County
UTM Coordinates: X=707767, Y=4247550

Receiving Stream: Tributary to Big River
First Classified Stream and ID: Big River (P) (2074)
USGS Basin & Sub-Watershed No.: (07140104-080009)

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

FACILITY DESCRIPTION

Outfall #001 - WWTF - SIC #6552 Subdivision
Septic Tank/ recirculating sand filter/ chlorination & dechlorination/ contract sludge hauling.
Design population equivalent is 44.
Design flow is 4,400 gallons per day.
Design sludge production is 0.308 dry tons/year

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Section 644.051.6 of the Law.

November 26, 2010
Effective Date

October 16, 2012
Revised Date

Sara Parker Pauley
Sara Parker Pauley, Director, Department of Natural Resources

November 25, 2015
Expiration Date

John Madras
John Madras, Director, Water Protection Program

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

PAGE NUMBER 2 of 4

PERMIT NUMBER MO-0113191

The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective upon issuance and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below:

OUTFALL NUMBER AND EFFLUENT PARAMETER(S)	UNITS	FINAL EFFLUENT LIMITATIONS			MONITORING REQUIREMENTS	
		DAILY MAXIMUM	WEEKLY AVERAGE	MONTHLY AVERAGE	MEASUREMENT FREQUENCY	SAMPLE TYPE
<u>Outfall #001</u>						
Flow	MGD	*		*	once/month	24 hr. Est.
Biochemical Oxygen Demand ₅	mg/L		45	30	once/quarter**	***
Total Suspended Solids	mg/L		45	30	once/quarter**	***
pH – Units	SU	****		****	once/quarter**	grab
Ammonia as N (mg/L)						
(May 1- Oct. 31)	mg/L	3.7		1.4	once/quarter**	grab
(Nov. 1- Apr. 30)	mg/L	7.5		2.9	once/quarter**	grab
Temperature	°C	*		*	once/quarter**	grab
Fecal Coliform (Notes 1)	#/100mls	1000		400	once/quarter**	grab
Total Residual Chlorine (Note 2)	mg/L	0.017 (0.13ML)		0.008 (0.13ML)	once/quarter**	grab

MONITORING REPORTS SHALL BE SUBMITTED **QUARTERLY**; THE NEXT REPORT IS DUE January 28, 2013. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.

B. STANDARD CONDITIONS

IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED Parts I & III STANDARD CONDITIONS DATED October 1, 1980 and August 15, 1994, AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN.

MO 780-0010 (8/91)

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

- * Monitoring requirement only.
- ** Sample once per quarter.
- *** A composite sample made up from a minimum of four grab samples collected within a 24-hour period with a minimum of two hours between each grab sample.
- **** pH is measured in pH units and is not to be averaged. The pH is limited to the range of 6.0-9.0 pH units.

Note 1- Final limitations and monitoring requirements for Fecal Coliform are applicable only during the recreational season from April 1 through October 31.

Note 2 - This permit contains a Total Residual Chlorine (TRC) limit.

- (a) This effluent limit is below the minimum quantification level (ML) of the most common and practical EPA approved CLTRC methods. The department has determined the current acceptable ML for total residual chlorine to be 0.13 mg/L when using the DPD Colorimetric Method #4500 – CL G. from Standard Methods for the Examination of Waters and Wastewater. The permittee will conduct analyses in accordance with this method, or equivalent, and report actual analytical values. Measured values greater than or equal to the minimum quantification level of 0.13 mg/L will be considered violations of the permit and values less than the minimum quantification level of 0.13 mg/L will be considered to be in compliance with the permit limitation. The minimum quantification level does not authorize the discharge of chlorine in excess of the effluent limits stated in the permit.

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

- (b) Disinfection is required year-round unless the permit specifically states that “Final limitations and monitoring requirements for Fecal Coliform are applicable only during the recreational season from April 1 through October 31.” If your permit does not require disinfection during the non-recreational months, do not chlorinate in those months.
- (c) Do not chemically dechlorinate **if it is not needed to meet the limits in your permit.**
- (d) If no chlorine was used in a given sampling period, an actual analysis is not necessary. Simply report as “0 mg/L” TRC.

C. SPECIAL CONDITIONS

- 1. This permit may be reopened and modified, or alternatively revoked and reissued, to:
 - a. Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a) (2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
 - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
 - (2) controls any pollutant not limited in the permit.
 - b. Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri’s Water Quality Standards.
 - c. Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri’s list of waters of the state not fully achieving the state’s water quality standards, also called the 303(d) list.

The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.
- 2. All outfalls must be clearly marked in the field.
- 3. Permittee will cease discharge by connection to areawide wastewater treatment system within 90 days of notice of its availability.
- 4. Changes in Discharges of Toxic Substances.
The permittee shall notify the Director as soon as it knows or has reason to believe:
 - a. That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:"
 - (1) One hundred micrograms per liter (100 µg/L);
 - (2) Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,5 dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
 - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;
 - (4) The level established in Part A of the permit by the Director.
 - b. That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.
 - c. That the effluent limit established in part A of the permit will be exceeded.
- 5. Report as no-discharge when a discharge does not occur during the report period.
- 6. Water Quality Standards.
 - a. Discharges to waters of the state shall not cause a violation of water quality standards rule under 10 CSR 20-7.031, including both specific and general criteria.
 - b. General Criteria. The following general water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:
 - (1) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
 - (2) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
 - (3) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
 - (4) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
 - (5) There shall be no significant human health hazard from incidental contact with the water;
 - (6) There shall be no acute toxicity to livestock or wildlife watering;
 - (7) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
 - (8) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.

C. SPECIAL CONDITIONS (continued)

7. Sludge and Biosolids Use For Domestic Wastewater Treatment Facilities
 - a. Permittee shall comply with the pollutant limitations, monitoring, reporting, and other requirements in accordance with the attached permit Standard Conditions.
 - b. If sludge is not removed by a contract hauler, permittee is authorized to land apply biosolids. Permit Standard Conditions, Part III shall apply to the land application of biosolids. Permittee shall notify the department at least 180 days prior to the planned removal of biosolids. The department may require submittal of a biosolids management plan for department review and approval as determined appropriate on a case-by-case basis.

Missouri Department of Natural Resources
Statement of Basis
#MO-0113191
Sunrise Acres Subdivision Wastewater Treatment System

This Statement of Basis (Statement) gives pertinent information regarding minor/simple modification(s) to the above listed operating permit without the need for a public comment process.

A Statement is not an enforceable part of a Missouri State Operating Permit.

Part I – Facility Information

Facility Type: Subdivision
Facility SIC Code(s): #6552

Outfall #001 - WWTF - SIC #6552 Subdivision

Septic Tank/ recirculating sand filter/ chlorination & dechlorination/ contract sludge hauling.

Design population equivalent is 44.

Design flow is 4,400 gallons per day.

Design sludge production is 0.308 dry tons/year

Part II – Modification Rationale

This operating permit is hereby modified to reflect a change in ownership.

No other changes were made at this time.

Part III – Administrative Requirements

On the basis of preliminary staff review and the application of applicable standards and regulations, the Department, as administrative agent for the Missouri Clean Water Commission, proposes to issue a permit(s) subject to certain effluent limitations, schedules, and special conditions contained herein and within the operating permit.

Date of Statement of Basis: August 17, 2012

Submitted by

Logan Cole, Environmental Specialist
Domestic Wastewater Unit
Operating Permits Section
Water Protection Program
(572)751-5827
logan.cole@dnr.mo.gov