

| A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS | | | | | PAGE NUMBER 2 of 9 | |
|--|------------|------------------------------|----------------|-----------------|-------------------------|------------------|
| | | | | | PERMIT NUMBER MO0116246 | |
| The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The interim effluent limitations shall become effective upon issuance and remain in effect for three years. Such discharges shall be controlled, limited and monitored by the permittee as specified below: | | | | | | |
| OUTFALL NUMBER AND EFFLUENT PARAMETER(S) | UNITS | INTERIM EFFLUENT LIMITATIONS | | | MONITORING REQUIREMENTS | |
| | | DAILY MAXIMUM | WEEKLY AVERAGE | MONTHLY AVERAGE | MEASUREMENT FREQUENCY | SAMPLE TYPE |
| Outfall #001 | | | | | | |
| Flow | MGD | * | | * | once/month | 24 hr. total |
| Biochemical Oxygen Demand ₅ *** | mg/L | | 45 | 30 | once/month | grab |
| Total Suspended Solids*** | mg/L | | 45 | 30 | once/month | grab |
| pH – Units | SU | ** | | ** | once/month | grab |
| Ammonia as N | mg/L | * | | * | once/month | grab |
| Temperature | °C | * | | * | once/month | grab |
| Oil & Grease | mg/L | 15 | | 10 | once/month | grab |
| Fecal Coliform (Note 1) | #/100 ml | 1000 | | 400 | once/month | grab |
| Total Residual Chlorine (Note 2) | mg/L | 1.0 | | 1.0 | once/month | grab |
| MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE <u>August 28, 2009</u> . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS. | | | | | | |
| The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective three years from the issuance of the permit and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below: | | | | | | |
| OUTFALL NUMBER AND EFFLUENT PARAMETER(S) | UNITS | FINAL EFFLUENT LIMITATIONS | | | MONITORING REQUIREMENTS | |
| | | DAILY MAXIMUM | WEEKLY AVERAGE | MONTHLY AVERAGE | MEASUREMENT FREQUENCY | SAMPLE TYPE |
| Outfall #001 | | | | | | |
| Flow | MGD | * | | * | once/month | 24 hr. total |
| Biochemical Oxygen Demand ₅ *** | mg/L | | 45 | 30 | once/month | grab |
| Total Suspended Solids*** | mg/L | | 45 | 30 | once/month | grab |
| pH – Units | SU | ** | | ** | once/month | grab |
| Ammonia as N | mg/L | | | | once/month | grab |
| Summer (May 1 – Oct 31) | | 12.6 | | 5.5 | | |
| Winter (Nov 1 – Apr 30) | | 12.6 | | 4.8 | | |
| Temperature | °C | * | | * | once/month | grab |
| Oil & Grease | mg/L | 15 | | 10 | once/month | grab |
| Fecal Coliform (Note 1) | #/100 ml | 1000 | | 400 | once/month | grab |
| Total Residual Chlorine (Note 2) | mg/L | 0.02 (.13ML) | | 0.01 (.13ML) | once/month | grab |
| MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE <u>August 28, 2012</u> . THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS. | | | | | | |
| Whole Effluent Toxicity (WET) test | % Survival | See Special Conditions #9 | | | once/5 years | 24 hr. composite |
| MONITORING REPORTS SHALL BE SUBMITTED <u>ONCE/5 YEARS</u> ; THE FIRST REPORT IS DUE <u>January 28, 2013</u> . | | | | | | |
| B. STANDARD CONDITIONS | | | | | | |
| IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED <u>Parts I, II, & III</u> STANDARD CONDITIONS DATED <u>October 1, 1980 and August 15, 1994</u> , AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN. | | | | | | |

| C. INFLUENT MONITORING REQUIREMENTS | | PAGE NUMBER 3 of 9 | |
|--|-------|-------------------------|-------------|
| | | PERMIT NUMBER MO0116246 | |
| The facility is required to meet a removal efficiency of 85% or more. The monitoring requirements shall become effective upon issuance and remain in effect until expiration of the permit. To determine removal efficiencies, the influent wastewater shall be monitored by the permittee as specified below: | | | |
| SAMPLING LOCATION AND PARAMETER(S) | UNITS | MONITORING REQUIREMENTS | |
| | | MEASUREMENT FREQUENCY | SAMPLE TYPE |
| <u>Influent</u> | | | |
| Biochemical Oxygen Demand ₅ *** | mg/L | once/month | grab |
| Total Suspended Solids*** | mg/L | once/month | grab |
| MONITORING REPORTS SHALL BE SUBMITTED <u>MONTHLY</u> ; THE FIRST REPORT IS DUE <u>August 28, 2009</u> . | | | |

MO 780-0010 (8/91)

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

* Monitoring requirement only.

** pH is measured in pH units and is not to be averaged. The pH is limited to the range of 6.0-9.0 pH units.

*** This facility is required to meet a removal efficiency of 85% or more. Influent and effluent samples used to determine percent removal shall be taken the same day.

Note 1 - Final limitations and monitoring requirements for Fecal Coliform are applicable only during the recreational season from April 1 through October 31. The Monthly Average Limit for Fecal Coliform is expressed as a geometric mean.

Note 2 - This permit contains a Total Residual Chlorine (TRC) limit.

- (a) This effluent limit is below the minimum quantification level (ML) of the most common and practical EPA approved CLTRC methods. The department has determined the current acceptable ML for total residual chlorine to be 0.13 mg/L when using the DPD Colorimetric Method #4500 – CL G. from Standard Methods for the Examination of Waters and Wastewater. The permittee will conduct analyses in accordance with this method, or equivalent, and report actual analytical values. Measured values greater than or equal to the minimum quantification level of 0.13 mg/L will be considered violations of the permit and values less than the minimum quantification level of 0.13 mg/L will be considered to be in compliance with the permit limitation. The minimum quantification level does not authorize the discharge of chlorine in excess of the effluent limits stated in the permit.
- (b) Disinfection is required year-round unless the permit specifically states that “Final limitations and monitoring requirements for Fecal Coliform are applicable only during the recreational season from April 1 through October 31.” If your permit does not require disinfection during the non-recreational months, do not chlorinate in those months.
- (c) Do not chemically dechlorinate **if it is not needed to meet the limits in your permit**.
- (d) If no chlorine was used in a given sampling period, an actual analysis is not necessary. Simply report as “0 mg/L” TRC.

D. SPECIAL CONDITIONS

- 1. This permit may be reopened and modified, or alternatively revoked and reissued, to:
 - (a) Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a) (2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
 - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
 - (2) controls any pollutant not limited in the permit.
 - (b) Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri’s Water Quality Standards.
 - (c) Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri’s list of waters of the state not fully achieving the state’s water quality standards, also called the 303(d) list.

The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.

D. SPECIAL CONDITIONS (continued)

2. All outfalls must be clearly marked in the field.
3. Permittee will cease discharge by connection to area-wide wastewater treatment system within 90 days of notice of its availability.
4. Changes in Discharges of Toxic Substances

The permittee shall notify the Director as soon as it knows or has reason to believe:

- (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:"
 - (1) One hundred micrograms per liter (100 µg/L);
 - (2) Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,5 dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
 - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;
 - (4) The level established in Part A of the permit by the Director.
 - (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.
5. Report as no-discharge when a discharge does not occur during the report period.
 6. Water Quality Standards
 - (a) Discharges to waters of the state shall not cause a violation of water quality standards rule under 10 CSR 20-7.031, including both specific and general criteria.
 - (b) General Criteria. The following general water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:
 - (1) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
 - (2) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
 - (3) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
 - (4) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
 - (5) There shall be no significant human health hazard from incidental contact with the water;
 - (6) There shall be no acute toxicity to livestock or wildlife watering;
 - (7) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
 - (8) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.
 7. The permittee shall comply with any applicable requirements listed in 10 CSR 20-8 and 10 CSR 20-9, unless the facility has received written notification that the Department has approved a modification to the requirements. The monitoring frequencies contained in this permit shall not be construed by the permittee as a modification of the monitoring frequencies listed in 10 CSR 20-9. If a modification of the monitoring frequencies listed in 10 CSR 20-9 is needed, the permittee shall submit a written request to the department for review and, if deemed necessary, approval.
 8. The permittee should develop and implement a program for maintenance and repair of the collection system. The recommended guidance is the US EPA's Guide For Evaluating Capacity, Management, Operation, And Maintenance (CMOM) Programs At Sanitary Sewer Collection Systems (Document number EPA 305-B-05-002).

D. SPECIAL CONDITIONS (continued)

9. Whole Effluent Toxicity (WET) Test shall be conducted as follows:

| SUMMARY OF ACUTE WET TESTING FOR THIS PERMIT | | | | | |
|--|-----|--------|---------------|-------------------|---------------------------------|
| OUTFALL | AEC | LC50%* | FREQUENCY | SAMPLE TYPE | MONTH |
| 001 | 68% | >100% | Once/ 5 Years | 24 hour composite | Any, but report in January 2013 |

* LC50 = AEC / 0.3.

| Dilution Series | | | | | | |
|-----------------|-----|-----|-------|-------|---------------------------------------|---|
| 100% | 50% | 25% | 12.5% | 6.25% | (Control) 100% upstream, if available | (Control) 100% Lab Water, also called synthetic water |

$$\text{AEC\%} = \text{outfall design flow cfs} / (\text{ZID cfs} + \text{outfall design flow cfs})$$

(a) Test Schedule and Follow-Up Requirements

- (1) Perform a MULTIPLE-dilution acute WET test in the months and at the frequency specified above. For tests which are successfully passed, submit test results using the Department's WET test report form #MO-780-1899 along with complete copies of the test reports as received from the laboratory, including copies of chain-of-custody forms within 30 calendar days of availability to the WATER PROTECTION PROGRAM, P.O. Box 176, Jefferson City, MO 65102. If the effluent passes the test, do not repeat the test until the next test period.
 - (a) For discharges of stormwater, samples shall be collected within three hours from when discharge first occurs.
 - (b) Samples submitted for analysis of stormwater discharges shall be collected as a grab.
 - (c) For discharges of non-stormwater, samples shall be collected only when precipitation has not occurred for a period of forty-eight hours prior to sample collection. In no event shall sample collection occur simultaneously with the occurrence of precipitation excepting for stormwater samples.
 - (d) A twenty-four hour composite sample shall be submitted for analysis of non-stormwater discharges.
 - (e) Upstream receiving water samples, where required, shall be collected upstream from any influence of the effluent where downstream flow is clearly evident.
 - (f) Samples submitted for analysis of upstream receiving water may be collected as either a grab or twenty-four-hour composite as appropriate to the nature of the discharge.
 - (g) Chemical and physical analysis of the upstream control and effluent sample shall occur immediately upon being received by the laboratory, prior to any manipulation of the effluent sample beyond preservation methods consistent with federal guidelines for WET testing that are required to stabilize the sample during shipping.
 - (h) Any and all chemical or physical analysis of the effluent sample performed in conjunction with the WET test shall be performed at the 100% Effluent concentration in addition to analyses performed upon any other effluent concentration.
 - (i) All chemical analyses included in the Missouri Department of Natural Resources WET test report form #MO-780-1899 shall be performed and results shall be recorded in the appropriate field of the report form.
 - (j) Where flow-weighted composite sample is required for analysis, the samples shall be composited at the laboratory where the test is to be performed.
 - (k) Where in stream testing is required downstream from the discharge, sample collection shall occur

D. SPECIAL CONDITIONS (continued)

immediately below the established Zone of Initial Dilution in conjunction with or immediately following a release or discharge.

- (l) Samples submitted for analysis of downstream receiving water may be collected as either a grab or twenty-four-hour composite as appropriate to the nature of the discharge.
 - (m) All instream samples, including downstream samples, shall be tested for toxicity at the 100% concentration in addition to any other assigned AEC for in-stream samples.
- (2) All failing test results along with complete copies of the test reports as received from the laboratory, INCLUDING THOSE TESTS CONDUCTED UNDER CONDITION (3) BELOW, shall be reported to the WATER PROTECTION PROGRAM, P.O. Box 176, Jefferson City, MO 65102 within 14 calendar days of the availability of the results.
 - (3) If the effluent fails the test, a multiple dilution test shall be performed for BOTH test species within 30 calendar days and biweekly thereafter (for storm water, tests shall be performed on the next and subsequent storm water discharges as they occur, but not less than 7 days apart) until one of the following conditions are met:
 - (a) THREE CONSECUTIVE MULTIPLE-DILUTION TESTS PASS. No further tests need to be performed until next regularly scheduled test period.
 - (b) A TOTAL OF THREE MULTIPLE-DILUTION TESTS FAIL.
 - (4) Failure of at least two multiple-dilution tests during any period of accelerated monitoring violates the permit narrative requirement for aquatic life protection.
 - (5) The permittee shall submit a summary of all test results for the test series along with complete copies of the test reports as received from the laboratory to the WATER PROTECTION PROGRAM, P.O. Box 176, Jefferson City, MO 65102 within 14 calendar days of the third failed test.
 - (6) Additionally, the following shall apply upon failure of the third MULTIPLE DILUTION test: A toxicity identification evaluation (TIE) or toxicity reduction evaluation (TRE) is automatically triggered. The permittee shall contact THE WATER PROTECTION PROGRAM within 14 calendar days from availability of the test results to ascertain as to whether a TIE or TRE is appropriate. The permittee shall submit a plan for conducting a TIE or TRE to the WATER PROTECTION PROGRAM within 60 calendar days of the date of DNR's direction to perform either a TIE or TRE. This plan must be approved by DNR before the TIE or TRE is begun. A schedule for completing the TIE or TRE shall be established in the plan approval.
 - (7) Upon DNR's approval, the TIE/TRE schedule may be modified if toxicity is intermittent during the TIE/TRE investigations. A revised WET test schedule may be established by DNR for this period.
 - (8) If a previously completed TIE has clearly identified the cause of toxicity, additional TIEs will not be required as long as effluent characteristics remain essentially unchanged and the permittee is proceeding according to a DNR approved schedule to complete a TRE and reduce toxicity. Regularly scheduled WET testing as required in the permit, without the follow-up requirements, will be required during this period.
 - (9) When WET test sampling is required to run over one DMR period, each DMR report shall contain a copy of the Department's WET test report form that was generated during the reporting period.
 - (10) Submit a concise summary in tabular format of all WET test results with the annual report.
- (b) PASS/FAIL procedure and effluent limitations:
- (1) To pass a multiple-dilution test:
 - (a) For facilities with a computed percent effluent at the edge of the zone of initial dilution, Allowable Effluent Concentration (AEC) OF 30% OR LESS, the AEC must be less than three-tenths (0.3) of the LC₅₀ concentration for the most sensitive of the test organisms; **OR**,
 - (b) For facilities with an AEC greater than 30%, the LC₅₀ concentration must be greater than 100%; **AND**,
 - (c) all effluent concentrations equal to or less than the AEC must be nontoxic. Mortality observed in all effluent concentrations equal to or less than the AEC shall not be significantly different (at the 95% confidence level; p = 0.05) than that observed in the upstream receiving-water control sample. Where upstream receiving water is not available mortality observed in the AEC test concentration shall not be significantly different (at the 95% confidence level; p = 0.05) than that observed in the laboratory control. The appropriate statistical tests of significance shall be consistent with the most current edition of METHODS FOR MEASURING THE ACUTE TOXICITY OF EFFLUENTS AND RECEIVING WATERS TO FRESHWATER AND MARINE ORGANISMS or other federal guidelines as appropriate or required. Failure of one multiple-dilution test may be considered an effluent limit violation.

D. SPECIAL CONDITIONS (continued)

- (c) Test Conditions
 - (1) Test Type: Acute Static non-renewal
 - (2) All tests, including repeat tests for previous failures, shall include both test species listed below.
 - (3) Test species: *Ceriodaphnia dubia* and *Pimephales promelas* (fathead minnow). Organisms used in WET testing shall come from cultures reared for the purpose of conducting toxicity tests and cultured in a manner consistent with the most current USEPA guidelines. All test animals shall be cultured as described in the most current edition of Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms.
 - (4) Test period: 48 hours at the "Acceptable Effluent Concentration" (AEC) specified above.
 - (5) Upstream receiving stream water shall be used as dilution water. If upstream water is unavailable or if mortality in the upstream water exceeds 10%, "reconstituted" water will be used as dilution water. Procedures for generating reconstituted water will be supplied by the MDNR upon request.
 - (6) Multiple-dilution tests will be run with:
 - (a) 100%, 50%, 25%, 12.5%, and 6.25% effluent, unless the AEC is less than 25% effluent, in which case dilutions will be 4 times the AEC, two times the AEC, AEC, 1/2 AEC and 1/4 AEC;
 - (b) 100% receiving-stream water (if available), collected upstream of the outfall at a point beyond any influence of the effluent; and
 - (c) reconstituted water.
 - (7) If reconstituted-water control mortality for a test species exceeds 10%, the entire test will be rerun.
 - (8) If upstream control mortality exceeds 10%, the entire test will be rerun using reconstituted water as the dilutant.

SUMMARY OF TEST METHODOLOGY FOR ACUTE WHOLE-EFFLUENT TOXICITY TESTS

Whole-effluent-toxicity test required in NPDES permits shall use the following test conditions when performing single or multiple dilution methods. Any future changes in methodology will be supplied to the permittee by the Missouri Department of Natural Resources (MDNR). Unless more stringent methods are specified by the DNR, the procedures shall be consistent with the most current edition of Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms,

Test conditions for Ceriodaphnia dubia:

| | |
|----------------------------------|--|
| Test duration: | 48 h |
| Temperature: | 25 ± 1°C Temperatures shall not deviate by more than 3°C during the test. |
| Light Quality: | Ambient laboratory illumination |
| Photoperiod: | 16 h light, 8 h dark |
| Size of test vessel: | 30 mL (minimum) |
| Volume of test solution: | 15 mL (minimum) |
| Age of test organisms: | <24 h old |
| No. of animals/test vessel: | 5 |
| No. of replicates/concentration: | 4 |
| No. of organisms/concentration: | 20 (minimum) |
| Feeding regime: | None (feed prior to test) |
| Aeration: | None |
| Dilution water: | Upstream receiving water; if no upstream flow, synthetic water modified to reflect effluent hardness. |
| Endpoint: | Pass/Fail (Statistically significant Mortality when compared to upstream receiving water control or synthetic control if upstream water was not available at $p \leq 0.05$) |
| Test acceptability criterion: | 90% or greater survival in controls |

Test conditions for Pimephales promelas:

| | |
|----------------------------------|--|
| Test duration: | 48 h |
| Temperature: | 25 ± 1°C Temperatures shall not deviate by more than 3°C during the test. |
| Light Quality: | Ambient laboratory illumination |
| Photoperiod: | 16 h light/ 8 h dark |
| Size of test vessel: | 250 mL (minimum) |
| Volume of test solution: | 200 mL (minimum) |
| Age of test organisms: | 1-14 days (all same age) |
| No. of animals/test vessel: | 10 |
| No. of replicates/concentration: | 4 (minimum) single dilution method 2 (minimum) multiple dilution method |
| No. of organisms/concentration: | 40 (minimum) single dilution method 20 (minimum) multiple dilution method |
| Feeding regime: | None (feed prior to test) |
| Aeration: | None, unless DO concentration falls below 4.0 mg/L; rate should not exceed 100 bubbles/min. |
| Dilution water: | Upstream receiving water; if no upstream flow, synthetic water modified to reflect effluent hardness. |
| Endpoint: | Pass/Fail (Statistically significant Mortality when compared to upstream receiving water control or synthetic control if upstream water was not available at $p \leq 0.05$) |
| Test Acceptability criterion: | 90% or greater survival in controls |

E. SCHEDULE OF COMPLIANCE

The Department of Natural Resources has implemented policy to address the discharge of ammonia, therefore the permit contains an effluent limits for ammonia. The treatment system may or may not be capable of consistently meeting the calculated ammonia and chlorine limits. An interim effluent table that contains ammonia and temperature monitoring for three years is in the permit. The Effluent Regulation, 10 CSR 20 – 7.031 (10) allows the permittee up to three years from the issuance date of this permit to comply with the final limits for ammonia and chlorine. Timeline to comply with new limits:

- (1.) **Within one year from the issuance of this permit**, the permittee shall submit a preliminary engineering report prepared by a registered professional engineer in the State of Missouri. The preliminary engineering report shall address the ability of the existing facility to meet new ammonia and chlorine limits. If it appears the facility will not meet those limits without upgrades, then the report shall make recommendations to upgrade the wastewater treatment facility. If upgrades are necessary then item 2 below should be addressed.
- (2.) **Within one year and six months from the issuance of this permit**, the permittee shall submit a construction permit application if upgrades are necessary to meet new ammonia and chlorine limits. The application shall include applicable fees, plans, and specifications in accordance with the approved preliminary engineering report.
- (3.) **Within two years from the issuance of this permit**, the permittee shall submit an interim progress report concerning the status of upgrades to the wastewater treatment facility.
- (4.) **Within three years from the issuance of this permit**, the permittee shall submit a letter of authorization or statement of work complete signed by the owner and a licensed professional engineer in the State of Missouri after construction is complete for upgrades necessary to meet new ammonia and chlorine limits.

Missouri Department of Natural Resources
FACT SHEET
FOR THE PURPOSE OF RENEWAL
OF
MO0116246
MARQUAND WWTF

The Federal Water Pollution Control Act ("Clean Water Act" Section 402 Public Law 92-500 as amended) established the National Pollution Discharge Elimination System (NPDES) permit program. This program regulates the discharge of pollutants from point sources into the waters of the United States, and the release of storm water from certain point sources. All such discharges are unlawful without a permit (Section 301 of the "Clean Water Act"). After a permit is obtained, a discharge not in compliance with all permit terms and conditions is unlawful. Missouri State Operating Permits (MSOPs) are issued by the Director of the Missouri Department of Natural Resources (department) under an approved program, operating in accordance with federal and state laws (Federal "Clean Water Act" and "Missouri Clean Water Law" Section 644 as amended). MSOPs are issued for a period of five (5) years unless otherwise specified.

As per [40 CFR Part 124.8(a)] and [10 CSR 20-6.020(1)2.] a Factsheet shall be prepared to give pertinent information regarding the applicable regulations, rationale for the development of effluent limitations and conditions, and the public participation process for the Missouri State Operating Permit (operating permit) listed below.

A Factsheet is not an enforceable part of an operating permit.

This Factsheet is for:

Minor

Part I – Facility Information

Facility Type: POTW
 Facility SIC Code(s): 4952

Facility Description:

Septic Tank/recirculating filter/chlorination/sludge disposal is by contract hauler.
 Design population equivalent is 351.
 Design flow is 35,000 gallons per day.
 Actual flow is 31,050 gallons per day.
 Design sludge production is 2.5 dry tons/year.
 Actual sludge production is 2.1 dry tons/year.

Have any changes occurred at this facility or in the receiving water body that effects effluent limit derivation?

No

Application Date: 1/29/2009
 Expiration Date: 9/8/2008

Last Inspection: 8/25/2006 In Compliance Non Compliance

OUTFALL(S) TABLE:

| OUTFALL | DESIGN FLOW (CFS) | TREATMENT LEVEL | EFFLUENT TYPE | DISTANCE TO CLASSIFIED SEGMENT (MI) |
|---------|-------------------|-----------------|---------------|-------------------------------------|
| 001 | 0.054 | Secondary | Domestic | 0.0 |

Outfall #001

Legal Description: SE ¼, SE ¼, SE ¼, Sec. 28, T32N, R8E, Madison County
 Latitude/Longitude: +3725184/-09009522

Receiving Stream: Castor River (P)

First Classified Stream and ID: Castor River (P)(02297)
 USGS Basin & Sub-watershed No.: (7140107-010003)

Receiving Water Body's Water Quality & Facility Performance History:
 EFFL.GRAY,HS ODOR(6-06)FC=15000(9/06), IMPROVE O/M (6-06)

Comments:

Facility is required to add dechlorination facilities.

Part II – Operator Certification Requirements

As per [10 CSR 20-6.010(8) Terms and Conditions of a Permit], permittees shall operate and maintain facilities to comply with the Missouri Clean Water Law and applicable permit conditions and regulations. Operators or supervisors of operations at regulated wastewater treatment facilities shall be certified in accordance with [10 CSR 20-9.020(2)] and any other applicable state law or regulation. As per [10 CSR 20-9.010(2)(A)], requirements for operation by certified personnel shall apply to all wastewater treatment systems, if applicable, as listed below:

Check boxes below that are applicable to the facility;

- Owned or operated by or for:
 - Municipalities
 - Public Sewer District
 - County
 - Public Water Supply Districts
 - Private sewer company regulated by the Public Service Commission
 - State or Federal agencies

Each of the above entities are only applicable if they have a Population Equivalent greater than two hundred (200) and/or fifty (50) or more service connections.

This facility currently requires an operator with a C Certification Level. Modifications made to the wastewater treatment facility may cause the classification to be modified.

<http://www.dnr.mo.gov/operator/index.do>

Part III – Receiving Stream Information

APPLICABLE DESIGNATIONS OF WATERS OF THE STATE:

As per Missouri's Effluent Regulations [10 CSR 20-7.015], the waters of the state are divided into the below listed seven (7) categories. Each category lists effluent limitations for specific parameters, which are presented in each outfall's Effluent Limitation Table and further discussed in the Derivation & Discussion of Limits section.

- All Other Waters [10 CSR 20-7.015(8)]

10 CSR 20-7.031 Missouri Water Quality Standards, the department defines the Clean Water Commission water quality objectives in terms of "water uses to be maintained and the criteria to protect those uses." The receiving stream and/or 1st classified receiving stream's beneficial water uses to be maintained are located in the Receiving Stream Table located below in accordance with [10 CSR 20-7.031(3)].

RECEIVING STREAM(S) TABLE:

| WATERBODY NAME | CLASS | WBID | DESIGNATED USES* | 8-DIGIT HUC | EDU** |
|----------------|-------|------|-------------------------------|-------------|-------|
| Castor River | P | 2297 | LWW, AQL, CLF, SCR, WBC(A)*** | 07140107 | OUSFC |

* - Irrigation (IRR), Livestock & Wildlife Watering (LWW), Protection of Warm Water Aquatic Life and Human Health-Fish Consumption (AQL), Cool Water Fishery(CLF), Cold Water Fishery (CDF), Whole Body Contact Recreation (WBC), Secondary Contact Recreation (SCR), Drinking Water Supply (DWS), Industrial (IND), Groundwater (GRW).

** - Ecological Drainage Unit
 *** - UAA has not been conducted.

RECEIVING STREAM(S) LOW-FLOW VALUES TABLE:

| RECEIVING STREAM (U, C, P) | LOW-FLOW VALUES (CFS) | | |
|--|-----------------------|------|-------|
| | 1Q10 | 7Q10 | 30Q10 |
| Castor River (P) (<i>Default Values</i>) | 0.1 | 0.1 | 1.0 |

MIXING CONSIDERATIONS TABLE:

| MIXING ZONE (CFS) [10 CSR 20-7.031(4)(A)...] | | ZONE OF INITIAL DILUTION (CFS) [10 CSR 20-7.031(4)(A)...] | |
|---|-------|--|-------|
| 7Q10 | 30Q10 | 1Q10 | 7Q10 |
| 0.025 | 0.25 | 0.0025 | 0.025 |

RECEIVING STREAM MONITORING REQUIREMENTS:

No receiving water monitoring requirements recommended at this time.

Part IV – Rationale and Derivation of Effluent Limitations & Permit Conditions

ALTERNATIVE EVALUATIONS FOR NEW FACILITIES:

As per [10 CSR 20-7.015(4)(A)], discharges to losing streams shall be permitted only after other alternatives including land application, discharges to a gaining stream and connection to a regional wastewater treatment facility have been evaluated and determined to be unacceptable for environmental and/or economic reasons.

Not Applicable

The facility does not discharge to a Losing Stream as defined by [10 CSR 20-2.010(36)] & [10 CSR 20-7.031(1)(N)], or is an existing facility.

ANTI-BACKSLIDING:

A provision in the Federal Regulations [CWA §303(d)(4); CWA §402(c); 40 CFR Part 122.44(I)] that requires a reissued permit to be as stringent as the previous permit with some exceptions.

All limits in this Factsheet are at least as protective as those previously established; therefore, backsliding does not apply.

ANTIDEGRADATION:

In accordance with Missouri’s Water Quality Standard [10 CSR 20-7.031(2)], the department is to document by means of Antidegradation Review that the use of a water body’s available assimilative capacity is justified. Degradation is justified by documenting the socio-economic importance of a discharging activity after determining the necessity of the discharge.

Renewal no degradation proposed and no further review necessary.

AREA-WIDE WASTE TREATMENT MANAGEMENT & CONTINUING AUTHORITY:

As per [10 CSR 20-6.010(3)(B)], ...An applicant may utilize a lower preference continuing authority by submitting, as part of the application, a statement waiving preferential status from each existing higher preference authority, providing the waiver does not conflict with any area-wide management plan approved under section 208 of the Federal Clean Water Act or any other regional sewage service and treatment plan approved for higher preference authority by the department.

BIO-SOLIDS, SLUDGE, & SEWAGE SLUDGE:

Bio-solids are solid materials resulting from wastewater treatment that meet federal and state criteria for beneficial uses (i.e. fertilizer). Sludge is any solid, semi-solid, or liquid waste generated from a municipal, commercial, or industrial wastewater treatment plant, water supply treatment plant, or air pollution control facility or any other such waste having similar characteristics and effect. Sewage sludge is solids, semi-solids, or liquid residue generated during the treatment of domestic sewage in a treatment works; including but not limited to, domestic septage; scum or solids removed in primary, secondary, or advanced wastewater treatment process; and a material derived from sewage sludge. Sewage sludge does not include ash generated during the firing of sewage sludge in a sewage sludge incinerator or grit and screening generated during preliminary treatment of domestic sewage in a treatment works.

Applicable

This facility has been approved to land apply as per Permit Standard Conditions III and a department approved bio-solids management plan.

COMPLIANCE AND ENFORCEMENT:

Enforcement is the action taken by the Water Protection Program (WPP) to bring an entity into compliance with the Missouri Clean Water Law, its implementing regulations, and/or any terms and conditions of an operating permit. The primary purpose of the enforcement activity in the WPP is to resolve violations and return the entity to compliance.

Not Applicable

The permittee/facility is not currently under Water Protection Program enforcement action.

PRETREATMENT PROGRAM:

The reduction of the amount of pollutants, the elimination of pollutants, or the alteration of the nature of pollutant properties in wastewater prior to or in lieu of discharging or otherwise introducing such pollutants into a Publicly Owned Treatment Works [40 CFR Part 403.3(q)].

Pretreatment programs are required at any POTW (or combination of POTW operated by the same authority) and/or municipality with a total design flow greater than 5.0 MGD and receiving industrial wastes that interfere with or pass through the treatment works or are otherwise subject to the pretreatment standards. Pretreatment programs can also be required at POTWs/municipals with a design flow less than 5.0 MGD if needed to prevent interference with operations or pass through.

Several special conditions pertaining to the permittee's pretreatment program may be included in the permit, and are as follows:

- Implementation and enforcement of the program,
- Annual pretreatment report submittal,
- Submittal of list of industrial users,
- Technical evaluation of need to establish local limitations, and
- Submittal of the results of the evaluation

Not Applicable

The permittee, at this time, is not required to have a Pretreatment Program or does not have an approved pretreatment program.

REASONABLE POTENTIAL ANALYSIS (RPA):

Federal regulation [40 CFR Part 122.44(d)(1)(i)] requires effluent limitations for all pollutants that are or may be discharged at a level that will cause or have the reasonable potential to cause or contribute to an in-stream excursion above narrative or numeric water quality standard.

In accordance with [40 CFR Part 122.44(d)(iii)] if the permit writer determines that any give pollutant has the reasonable potential to cause, or contribute to an in-stream excursion above the WQS, the permit must contain effluent limits for that pollutant.

Not Applicable

A RPA was not conducted for this facility.

REMOVAL EFFICIENCY:

Removal efficiency is a method by which the Federal Regulations define Secondary Treatment and Equivalent to Secondary Treatment, which applies to Biochemical Oxygen Demand 5-day (BOD₅) and Total Suspended Solids (TSS) for Publicly Owned Treatment Works (POTWs)/municipals. Please see the United States Environmental Protection Agency's (EPA) website for interpretation of percent removal requirements for National Pollutant Discharge Elimination System Permit Application Requirements for Publicly Owned Treatment Works and Other Treatment Works Treating Domestic Sewage @ www.epa.gov/fedrgstr/EPA-WATER/1999/August/Day-04/w18866.htm.

Applicable

Secondary Treatment is 85% removal [40 CFR Part 133.102(a)(3) & (b)(3)].

SANITARY SEWER OVERFLOWS (SSOs), BYPASSES, INFLOW & INFILTRATION (I&I) – PREVENTION/REDUCTION:

Sanitary Sewer Systems (SSSs) are municipal wastewater collection system that convey domestic, commercial, and industrial wastewater, and limited amounts of infiltrated groundwater and storm water (i.e. I&I), to a POTW. SSSs are not designed to collect large amounts of storm water runoff from precipitation events.

Untreated or partially treated discharges from SSSs are commonly referred to as SSOs. SSOs have a variety of causes including blockages, line breaks, sewer defects that allow excess storm water and ground water to overload the system, lapses in sewer system operation and maintenance, inadequate sewer design and construction, power failures, and vandalism. A SSOs is defined as an untreated or partially treated sewage release from a SSS. SSOs can occur at any point in an SSS, during dry weather or wet weather. SSOs include overflows that reach waters of the state. SSOs also include overflows out of manholes and onto city streets, sidewalks, and other terrestrial locations. SSSs can back up into buildings, including private residences. When sewage backups are caused by problems in the publicly-owned portion of an SSS, they are considered SSOs.

Applicable

The permittee is required to develop or implement a program for maintenance and repair of the collection system and should be required in this operating permit by either means of a Special Condition or Schedule of Compliance. In addition, the department considers the development of this program as an implementation of this condition.

At this time, the department recommends the US EPA's Guide for Evaluating Capacity, Management, Operation and Maintenance (CMOM) Programs At Sanitary Sewer Collection Systems (Document # EPA 305-B-05-002). The CMOM identifies some of the criteria used by the EPA to evaluate a collection system's management, operation, and maintenance and was intended for use by the EPA, state, regulated community, and/or third party entities. The CMOM is applicable to small, medium, and large systems; both public and privately owned; and both regional and satellite collection systems. The CMOM does not substitute for the Clean Water Act, the Missouri Clean Water Law, and both federal and state regulations, as it is not a regulation.

SCHEDULE OF COMPLIANCE (SOC):

A schedule of remedial measures included in a permit, including an enforceable sequence of interim requirements (actions, operations, or milestone events) leading to compliance with the Missouri Clean Water Law, its implementing regulations, and/or the terms and conditions of an operating permit.

Applicable

The time given for effluent limitations of this permit listed under Interim Effluent Limitation and Final Effluent Limitations were established in accordance with [10 CSR 20-7.031(10)].

STORM WATER POLLUTION PREVENTION PLAN (SWPPP):

In accordance with 40 CFR 122.44(k) *Best Management Practices (BMPs)* to control or abate the discharge of pollutants when: (1) Authorized under section 304(e) of the Clean Water Act (CWA) for the control of toxic pollutants and hazardous substances from ancillary industrial activities; (2) Authorized under section 402(p) of the CWA for the control of storm water discharges; (3) Numeric effluent limitations are infeasible; or (4) the practices are reasonably necessary to achieve effluent limitations and standards or to carry out the purposes and intent of the CWA.

In accordance with the EPA's *Storm Water Management for Industrial Activities: Developing Pollution Prevention Plans and Best Management Practices* [EPA 832-R-92-006] (Storm Water Management), BMPs are measures or practices used to reduce the amount of pollution entering (regarding this operating permit) waters of the state. BMPs may take the form of a process, activity, or physical structure.

Additionally in accordance with the Storm Water Management, a SWPPP is a series of steps and activities to (1) identify sources of pollution or contamination, and (2) select and carry out actions which prevent or control the pollution of storm water discharges.

Not Applicable

At this time, the permittee is not required to develop and implement a SWPPP.

VARIANCE:

As per the Missouri Clean Water Law § 644.061.4, variances shall be granted for such period of time and under such terms and conditions as shall be specified by the commission in its order. The variance may be extended by affirmative action of the commission. In no event shall the variance be granted for a period of time greater than is reasonably necessary for complying with the Missouri Clean Water Law §§644.006 to 644.141 or any standard, rule or regulation promulgated pursuant to Missouri Clean Water Law §§644.006 to 644.141.

Not Applicable

This operating permit is not drafted under premises of a petition for variance.

WASTELOAD ALLOCATIONS (WLA) FOR LIMITS:

As per [10 CSR 20-2.010(78)], the amount of pollutant each discharger is allowed by the department to release into a given stream after the department has determined total amount of pollutant that may be discharged into that stream without endangering its water quality.

Applicable

Wasteload allocations were calculated where applicable using water quality criteria or water quality model results and the dilution equation below:

$$C = \frac{(Cs \times Qs) + (Ce \times Qe)}{(Qe + Qs)} \quad (\text{EPA/505/2-90-001, Section 4.5.5})$$

Where C = downstream concentration
 Cs = upstream concentration
 Qs = upstream flow
 Ce = effluent concentration
 Qe = effluent flow

Chronic wasteload allocations were determined using applicable chronic water quality criteria (CCC: criteria continuous concentration) and stream volume of flow at the edge of the mixing zone (MZ). Acute wasteload allocations were determined using applicable water quality criteria (CMC: criteria maximum concentration) and stream volume of flow at the edge of the zone of initial dilution (ZID).

Water quality based maximum daily and average monthly effluent limitations were calculated using methods and procedures outlined in USEPA's "Technical Support Document For Water Quality-based Toxics Control" (EPA/505/2-90-001).

WLA MODELING:

There are two general types of effluent limitations, technology-based effluent limits (TBELs) and water quality based effluent limits (WQBELs). If TBELs do not provide adequate protection for the receiving waters, then WQBEL must be used.

Not Applicable

A WLA study was either not submitted or determined not applicable by department staff.

WATER QUALITY STANDARDS:

Per [10 CSR 20-7.031(3)], General Criteria shall be applicable to all waters of the state at all times including mixing zones. Additionally, [40 CFR 122.44(d)(1)] directs the department to establish in each NPDES permit to include conditions to achieve water quality established under Section 303 of the Clean Water Act, including State narrative criteria for water quality.

WHOLE EFFLUENT TOXICITY (WET) TEST:

A WET test is a quantifiable method of determining if a discharge from a facility may be causing toxicity to aquatic life by itself, in combination with or through synergistic responses when mixed with receiving stream water.

Applicable

In accordance with the Clean Water Act (CWA) §101(a)(3), requiring WET testing is reasonably appropriate for site-specific Missouri State Operating Permits for discharges to waters of the state issued under the National Pollutant Discharge Elimination System. Furthermore, WET testing is a means by which the department determines that [10 CSR 20-7.031(3)(D, F, & G)] are being met by the permitted facility. In addition to justification for the WET testing, WET tests are required under [10 CSR 20-6.010(8)(A)4] to be performed by specialists who are properly trained in conducting the test according to the methods prescribed by the Federal Government as referenced in [40 CFR Part 136]. WET test will be required by all facilities meeting the following criteria:

- Facility is a designated Major.
- Facility continuously or routinely exceeds its design flow.
- Facility (industrial) that alters its production process throughout the year.

Facility handles large quantities of toxic substances, or substances that are toxic in large amounts.

Facility has Water Quality-based Effluent Limitations for toxic substances (other than NH3)

Facility is a municipality or domestic discharger with a Design Flow > 22,500 gpd.

Other - Please justify

303(d) LIST & TOTAL MAXIMUM DAILY LOAD (TMDL):

Section 303(d) of the federal Clean Water Act requires that each state identify waters that are not meeting water quality standards and for which adequate water pollution controls have not been required. Water quality standards protect such beneficial uses of water as whole body contact (such as swimming), maintaining fish and other aquatic life, and providing drinking water for people, livestock and wildlife. The 303(d) list helps state and federal agencies keep track of waters that are impaired but not addressed by normal water pollution control programs.

A TMDL is a calculation of the maximum amount of a given pollutant that a body of water can absorb before its water quality is affected. If a water body is determined to be impaired as listed on the 303(d) list, then a watershed management plan will be developed that shall include the TMDL calculation

Not Applicable

This facility does not discharge to a 303(d) listed stream.

Part V – Effluent Limits Determination

Outfall #001 – Main Facility Outfall

EFFLUENT LIMITATIONS TABLE:

| PARAMETER | UNIT | BASIS FOR LIMITS | DAILY MAXIMUM | WEEKLY AVERAGE | MONTHLY AVERAGE | MODIFIED | PREVIOUS PERMIT LIMITATIONS |
|---------------------------------------|--|------------------|---|----------------|-----------------|----------|-----------------------------|
| FLOW | GPD | | | | | | |
| BOD ₅ | MG/L | 1 | 45 | | 30 | No | |
| TSS | MG/L | 1 | 45 | | 30 | No | |
| PH | SU | 2 | 6-9 | | 6-9 | No | |
| TEMPERATURE | °C | 5 | * | | * | YES | **** |
| AMMONIA AS N (MAY 1 – OCT 31) | MG/L | 5 | 12.6 | | 5.5 | YES | **** |
| AMMONIA AS N (NOV 1 – APR 30) | MG/L | 5 | 12.6 | | 4.8 | YES | **** |
| ESCHERICHIA COLI | ** | 1 | Please see Escherichia Coli (E. coli) in the Derivation and Discussion Section below. | | | | |
| FECAL COLIFORM | ** | 2 | 1000 | | 400** | No | |
| CHLORINE, TOTAL RESIDUAL | MG/L | 2 | 0.02 (.13ML) | | 0.01 (.13ML) | YES | 1.0 |
| OIL & GREASE (MG/L) | MG/L | 1 | 15 | | 10 | Y | **** |
| WHOLE EFFLUENT TOXICITY (WET) TEST | % Survival | 11 | Please see WET Test in the Derivation and Discussion Section below. | | | | |
| MONITORING FREQUENCY | Please see Minimum Sampling and Reporting Frequency Requirements in the Derivation and Discussion Section below. | | | | | | |

* - Monitoring requirement only.

** - For DO the Daily Maximum is a Daily Minimum and the Monthly Average is a Monthly Average Minimum.

*** - # of colonies/100mL; the Monthly Average for Fecal Coliform is a geometric mean.

**** - Parameter not previously established in previous state operating permit.

Basis for Limitations Codes:

1. State or Federal Regulation/Law
2. Water Quality Standard (includes RPA)
3. Water Quality Based Effluent Limits
4. Lagoon Policy
5. Ammonia Policy
6. Dissolved Oxygen Policy
7. Antidegradation Policy
8. Water Quality Model
9. Best Professional Judgment
10. TMDL or Permit in lieu of TMDL
11. WET Test Policy
12. Antidegradation Review

OUTFALL #001 – DERIVATION AND DISCUSSION OF LIMITS:

- **Flow.** In accordance with [40 CFR Part 122.44(i)(1)(ii)] the volume of effluent discharged from each outfall is needed to assure compliance with permitted effluent limitations. If the permittee is unable to obtain effluent flow, then it is the responsibility of the permittee to inform the department, which may require the submittal of an operating permit modification.
- **Biochemical Oxygen Demand (BOD₅).** 45 mg/L as a Weekly Average and 30 mg/L as a Monthly Average. Please see the **APPLICABLE DESIGNATION OF WATERS OF THE STATE** sub-section of the **Receiving Stream Information.**
- **Total Suspended Solids (TSS).** Effluent limitations from the previous state operating permit have been reassessed and verified that they are still protective of the receiving stream's Water Quality. Therefore, effluent limitations have been retained from previous state operating permit, please see the **APPLICABLE DESIGNATION OF WATERS OF THE STATE** sub-section of the **Receiving Stream Information.**
- **pH.** Effluent limitations have been retained from previous state operating permit, please see the **APPLICABLE DESIGNATION OF WATERS OF THE STATE** sub-section of the **Receiving Stream Information.**
- **Temperature.** Monitoring requirement due to the toxicity of Ammonia varies by temperature.
- **Total Ammonia Nitrogen.** Early Life Stages Present Total Ammonia Nitrogen criteria apply [10 CSR 20-7.031(4)(B)7.C. & Table B3] default pH 7.8 SU Background total ammonia nitrogen = 0.01 mg/L (Default).

| Season | Temp (°C) | pH (SU) | Total Ammonia Nitrogen CCC (mg/L) | Total Ammonia Nitrogen CMC (mg/L) |
|--------|-----------|---------|-----------------------------------|-----------------------------------|
| Summer | 26 | 7.8 | 1.5 | 12.1 |
| Winter | 6 | 7.8 | 3.1 | 12.1 |

Summer: May 1 – October 31

Chronic WLA: $C_e = ((0.054 + 0.25)1.5 - (0.25 * 0.01))/0.054$
 $C_e = 8.4 \text{ mg/L}$

Acute WLA: $C_e = ((0.054 + 0.0025)12.1 - (0.0025 * 0.01))/0.054$
 $C_e = 12.7 \text{ mg/L}$

$LTA_c = 8.4 \text{ mg/L} (0.780) = 6.6 \text{ mg/L}$ [CV = 0.6, 99th Percentile, 30 day avg.]
 $LTA_a = 12.7 \text{ mg/L} (0.321) = \mathbf{4.8 \text{ mg/L}}$ [CV = 0.6, 99th Percentile]

Use most protective number of LTA_c or LTA_a .

MDL = 4.1 mg/L (3.11) = 12.6 mg/L [CV = 0.6, 99th Percentile]
 AML = 4.1 mg/L (1.19) = 5.5 mg/L [CV = 0.6, 95th Percentile, n=30]

Winter: November 1 – April 30

Chronic WLA: $C_e = ((0.054 + 0.25)3.1 - (0.25 * 0.01))/0.054$
 $C_e = 17.4 \text{ mg/L}$

Acute WLA: $C_e = ((0.054 + 0.0025)12.1 - (0.0025 * 0.01))/0.054$
 $C_e = 12.6 \text{ mg/L}$

$LTA_c = 12.6 \text{ mg/L} (0.780) = 9.8 \text{ mg/L}$ [CV = 0.6, 99th Percentile, 30 day avg.]
 $LTA_a = 12.6 \text{ mg/L} (0.321) = \mathbf{4.0 \text{ mg/L}}$ [CV = 0.6, 99th Percentile]

Use most protective number of LTA_c or LTA_a .

MDL = 4.0 mg/L (3.11) = 12.6 mg/L [CV = 0.6, 99th Percentile]
 AML = 4.0 mg/L (1.19) = 4.8 mg/L [CV = 0.6, 95th Percentile, n=30]

- ***Escherichia coli (E. coli)***. This facility may be required to have *E. coli* effluent limitations when Missouri adopts the implementation of the *E. coli* standards, as per [10 CSR 20-7.031(4)(C)]. (This will be updated upon promulgation of the regulation).
- **Fecal Coliform**. Discharge shall not contain more than a monthly geometric mean of 400 colonies/100 mL and a daily maximum of 1000 colonies/100 mL during the recreational season (April 1 – October 31), please see the **APPLICABLE DESIGNATION OF WATERS OF THE STATE** sub-section of the **Receiving Stream Information**. Future renewals of the facility operating permit will contain effluent limitations for *E. coli*, which will replace fecal coliform as the applicable bacteria criteria in Missouri’s water quality standards.
- **Total Residual Chlorine (TRC)**. Warm-water Protection of Aquatic Life CCC = 10 µg/L, CMC = 19 µg/L [10 CSR 20-7.031, Table A]. Background TRC = 0.0 µg/L.

Chronic WLA: $C_e = ((0.054 + 0.25)10 - (0.25 * 0.0))/0.054$
 $C_e = 56.3 \text{ µg/L}$

Acute WLA: $C_e = ((0.054 + 0.0025)19 - (0.0025 * 0.0))/0.054$
 $C_e = 19.9 \text{ µg/L}$

$LTA_c = 56.3 (0.527) = 29.7 \text{ µg/L}$ [CV = 0.6, 99th Percentile]
 $LTA_a = 19.9 (0.321) = 6.4 \text{ µg/L}$ [CV = 0.6, 99th Percentile]

Use most protective number of LTA_c or LTA_a .

$MDL = 6.4 (3.11) = 19.9 \text{ µg/L}$ [CV = 0.6, 99th Percentile]
 $AML = 6.4 (1.55) = 9.9 \text{ µg/L}$ [CV = 0.6, 95th Percentile, n = 4]

Total Residual Chlorine effluent limits of 0.02 mg/L daily maximum, 0.01 mg/L monthly average are recommended if chlorine is used as a disinfectant. Standard compliance language for TRC, including the minimum level (ML), should be included in the permit.

- **Oil & Grease**. Conventional pollutant, effluent limitation for protection of aquatic life; 10 mg/L monthly average, 15 mg/L daily maximum.

WET Test. WET Testing schedules and intervals are established in accordance with the department’s Permit Manual; Section 5.2 *Effluent Limits / WET Testing for Compliance Bio-monitoring*. It is recommended that WET testing be conducted during the period of lowest stream flow.

Acute (default)

No less than ONCE/PERMIT CYCLE

Municipality or domestic facility with a design flow > 22,500 gpd, but less than 1.0 MGD.

Other, please justify.

Acute and/or Chronic Allowable Effluent Concentrations (AECs) for facilities that discharge to unclassified, Class C, Class P (with default Mixing Considerations), or Lakes [10 CSR 20-7.031(4)(A)4.B.(IV)(b)] are 100%, 50%, 25%, 12.5%, & 6.25%.

Classified P with other than default Mixing Considerations, the AEC% is determined as follows:.

$Acute \text{ AEC\%} = ((design \text{ flow}_{cfs} + ZID_{7Q10}) / design \text{ flow}_{cfs})^{-1} \times 100 = \#\\#\%$

- **Minimum Sampling and Reporting Frequency Requirements**. Sampling and reporting frequency requirements have been retained from previous state operating permit.

| PARAMETER | SAMPLING FREQUENCY | REPORTING FREQUENCY |
|-----------|--------------------|---------------------|
| FLOW | ONCE/DAY | ONCE/MONTH |

| | | |
|----------------------------------|------------|------------|
| BOD ₅ | ONCE/MONTH | ONCE/MONTH |
| TSS | ONCE/MONTH | ONCE/MONTH |
| PH | ONCE/MONTH | ONCE/MONTH |
| TEMPERATURE | ONCE/MONTH | ONCE/MONTH |
| AMMONIA AS N (MAY 1 – OCT 31) | ONCE/MONTH | ONCE/MONTH |
| AMMONIA AS N (NOV 1 – APR 30) | ONCE/MONTH | ONCE/MONTH |
| FECAL COLIFORM | ONCE/MONTH | ONCE/MONTH |
| CHLORINE, TOTAL RESIDUAL | ONCE/MONTH | ONCE/MONTH |
| OIL & GREASE | ONCE/MONTH | ONCE/MONTH |

Part VI – Administrative Requirements

On the basis of preliminary staff review and the application of applicable standards and regulations, the Department, as administrative agent for the Missouri Clean Water Commission, proposes to issue a permit(s) subject to certain effluent limitations, schedules, and special conditions contained herein and within the operating permit. The proposed determinations are tentative pending public comment.

PUBLIC NOTICE:

The department shall give public notice that a draft permit has been prepared and its issuance is pending. Additionally, public notice will be issued if a public hearing is to be held because of a significant degree of interest in and water quality concerns related to a draft permit. No public notice is required when a request for a permit modification or termination is denied; however, the requester and permittee must be notified of the denial in writing.

The department must issue public notice of a pending operating permit or of a new or reissued statewide general permit. The public comment period is the length of time not less than 30 days following the date of the public notice which interested persons may submit written comments about the proposed permit.

For persons wanting to submit comments regarding this proposed operating permit, then please refer to the Public Notice page located at the front of this draft operating permit. The Public Notice page gives direction on how and where to submit appropriate comments.

DATE OF FACT SHEET: APRIL 14, 2009

COMPLETED BY:

**TIM SOUTHARDS
ENVIRONMENTAL ENGINEER III
MISSOURI DEPARTMENT OF NATURAL RESOURCES
SOUTHEAST REGIONAL OFFICE
(573)840-9750**