

STATE OF MISSOURI
DEPARTMENT OF NATURAL RESOURCES
MISSOURI CLEAN WATER COMMISSION



CONSTRUCTION PERMIT

The Missouri Department of Natural Resources hereby issues a permit to:

City of Liberty
101 E. Kansas
Liberty, MO 60468

for the construction of (described facilities):

See attached.

Permit Conditions:

See attached.

Construction of such proposed facilities shall be in accordance with the provisions of the Missouri Clean Water Law, Chapter 644, RSMo, and regulation promulgated thereunder, or this permit may be revoked by the Department of Natural Resources (Department).

As the Department does not examine structural features of design or the efficiency of mechanical equipment, the issuance of this permit does not include approval of these features.

A representative of the Department may inspect the work covered by this permit during construction. Issuance of a permit to operate by the Department will be contingent on the work substantially adhering to the approved plans and specifications.

This permit applies only to the construction of water pollution control components; it does not apply to other environmentally regulated areas.

December 17, 2014
Effective Date

December 16, 2016
Expiration Date

Sara Parker Pauley
Sara Parker Pauley, Director, Department of Natural Resources

John Madros
Director, Water Protection Program

CONSTRUCTION PERMIT

COLLECTION SYSTEM:

This project consists of the installation and construction of approximately 1080 linear feet (lf) of 21-inch polyvinyl chloride (PVC) Standard Dimension Ratio (SDR)-35 and SDR-26 gravity sewer lines, and approximately 219 linear feet (lf) of 8-inch PVC, SDR-26 gravity sewer lines with approximately 9 manholes and all the necessary appurtenances to make a complete and usable wastewater collection system to replace an existing sewer system. There will be no additional sewage flow due to this project. The project will also include general site work appropriate to the scope and purpose of the project.

These activities will be in the vicinity of Forest Ave. and Circle Dr. in the City of Liberty, Clay County and will continue to discharge to an existing sewer system to be treated at the Birmingham Wastewater Treatment Facility, Missouri State Operating Permit No. MO-0049531.

PERMIT CONDITIONS:

1. All construction shall be in accordance with the plans and specifications submitted by AGC Engineers, Inc. as follows:
 - Specifications received on November 17, 2014, and signed and sealed by Ronald L. Cowger, P.E. on November 10, 2014.
 - Plans received on November 17, 2014, and signed and sealed by Ronald L. Cowger, P.E. on November 3, 2014.
2. The Department must be contacted in writing prior to making any changes to the approved plans and specifications that would directly or indirectly have an impact on the capacity, flow, system layout, or reliability of the proposed wastewater treatment facilities or any design parameter that is addressed by 10 CSR 20-8, in accordance with 10 CSR 20-8.110(8).
3. State and Federal Law does not permit bypassing of raw wastewater, therefore steps must be taken to ensure that raw wastewater does not discharge during construction. If a sanitary sewer overflow or bypass occurs, report the appropriate information to the Department's Kansas City Regional Office per 10 CSR 20-7.015(9)(E)2.
4. This Construction Permit is invalid for projects required to comply with the requirements contained in 10 CSR 20-4, "Grants and Loans".
5. Protection of drinking water supplies shall be in accordance with 10 CSR 20-8.120(10). "There shall be no physical connections between a public or private potable water supply system and a sewer, or appurtenance thereto which would permit the passage of any wastewater or polluted water into the potable supply. No water pipe shall pass through or come in contact with any part of a sewer manhole."

- A. Sewers in relation to water works structures shall meet the requirements of 10 CSR 23-3.010 with respect to minimum distances from public water supply wells or other water supply sources and structures.
 - B. Sewer mains shall be laid at least ten feet (10') horizontally from any existing or proposed water main. The distances shall be measured edge-to-edge. In cases where it is not practical to maintain a ten foot (10') separation, the Department may allow a deviation on a case-by-case basis, if supported by data from the design engineer. Such a deviation may allow installation of the sewer closer to a water main, provided that the water main is in a separate trench or on an undisturbed earth shelf located on either side of the sewer and at an elevation so the bottom of the water main is at least 18 inches above the top of the sewer. If it is impossible to obtain proper horizontal and vertical separation as described above for sewers, the sewer must be constructed of slip-on or mechanical joint pipe or continuously encased and be pressure tested to 150 pounds per square inch to assure water tightness.
 - C. Manholes should be located at least ten feet (10') horizontally from any existing or proposed water main.
 - D. Sewers crossing water mains shall be laid to provide a minimum vertical distance of 18 inches between the outside of the water main and the outside of the sewer. This shall be the case where the water main is either above or below the sewer. The crossing shall be arranged so that the sewer joints will be equidistant and as far as possible from the water main joints. Where a water main crosses under a sewer, adequate structural support shall be provided for the sewer to maintain line and grade. When it is impossible to obtain proper vertical separation as stipulated above, one (1) of the following methods must be specified:
 - 1) The sewer shall be designed and constructed equal to the water pipe and shall be pressure tested to assure water tightness prior to backfilling; or
 - 2) Either the water main or sewer line may be continuously encased or enclosed in a watertight carrier pipe which extends ten feet (10') on both sides of the crossing, measured perpendicular to the water main. The carrier pipe shall be of materials approved by the Department for use in water main construction.
6. In addition to the requirements for a construction permit, 10 CSR 20-6.200 requires land disturbance activities of one (1) acre or more to obtain a Missouri State Operating Permit to discharge stormwater. The permit requires Best Management Practices sufficient to control runoff and sedimentation to protect waters of the state. Land disturbance permits may only be obtained by means of the Department's ePermitting system available online at www.dnr.mo.gov/env/wpp/epermit/help.htm. See www.dnr.mo.gov/env/wpp/stormwater/sw-land-disturb-permits.htm for more information.


7. A United States (U.S.) Army Corps of Engineers (COE) permit (404) and a Water Quality Certification (401) issued by the Department or permit waiver may be required for the activities described in this permit. This permit is not valid until these requirements are satisfied. If construction activity will disturb any land below the ordinary high water mark of Jurisdictional Waters of the U.S. then a 404/401 will be required. Since the COE makes determinations on what is jurisdictional, you must contact the COE to determine permitting requirements. You may call the Department's Water Protection Program at 573-751-1300 for more information. See www.dnr.mo.gov/env/wpp/401/ for more information.
8. In accordance with 10 CSR 20-6.010(6)(B), submit the enclosed form Application for Letter of Authorization – Sewer Extension to the Department following completion of construction. Submit an electronic copy of the as-built drawings with this form if the project was not constructed in accordance with previously submitted plans and specifications.
9. Upon completion of construction, the City of Liberty will become the continuing authority for operation, maintenance, and modernization of these facilities.

Andrew G. Appelbaum P.E.
Engineering Section
Andy.Appelbaum@dnr.mo.gov

AM19997
 QSE00998
 C14074

RECEIVED

NOV 17 2014



MISSOURI DEPARTMENT OF NATURAL RESOURCES
 WATER PROTECTION PROGRAM
APPLICATION FOR CONSTRUCTION PERMIT -
SEWER EXTENSION

FOR DEPARTMENT USE ONLY	
APP NO.	CP NO.
FEE RECEIVED \$300	CHECK NO. 11166
DATE RECEIVED 11/17/14	

NOTE ► PLEASE READ THE ACCOMPANYING INSTRUCTIONS BEFORE COMPLETING THIS FORM

1.0 APPLICATION INFORMATION (Note – If any of the questions in this section are answered NO, this application may be considered incomplete and returned.)

- 1.1 Is this a Federal/State funded project? YES N/A Funding Agency: _____ Project #: _____
- 1.2 Has the Department of Natural Resources approved the proposed project's engineering report*? YES Date of Approval: _____ NO N/A
- 1.3 Is a copy of the appropriate plans* and specifications* included with this application? YES NO
- 1.4 Is a summary of design* included with this application? YES NO
- 1.5 Is the appropriate fee included with this application? (See instructions for appropriate fee.) YES NO
- * Must be affixed with a Missouri registered professional engineer's seal, signature and date.

2.0 PROJECT INFORMATION

2.1 NAME OF PROJECT
 City of Liberty Brookview Garden Sanitary Sewer (City Project No. 13-020)

ADDRESS	CITY	STATE	ZIP CODE	COUNTY
Forest Ave & Circle Drive	Liberty	Missouri	64068	Clay

2.2 Legal Description: SW ¼, SE ¼, ¼, Sec. 12, T 51 N, R 32 W

- 2.3 Project Components (check all that apply):
 Gravity sewers Pumping stations Force mains Alternative sewer system Other (Describe below.)

2.4 PROJECT DESCRIPTION
 Re-construction of 219 L.F. of 8" PVC (SDR 26), 607 L.F. of 21" PVC PS 46 (SDR 35), 473 L.F. of 21" PVC PS 115 (SDR 26), four (4) 4-foot diameter manholes, two (2) 4-foot diameter doghouse manholes, two (2) 5-foot diameter manholes, one (1) 5-foot diameter drop manhole, 120 L.F. of steel casing, and associated wyes and service lines to rehabilitate/ replace existing sanitary sewer.

- 2.5 DESIGN INFORMATION
- A. Population or number of lots to be served by this extension: 750 acres
- B. Estimated flow to be contributed by this extension: Design Average Flow: _____ gpd Design Peak Hourly Flow: 200,000gph
- C. Industrial Wastes: Type: N/A Flow: N/A gpd
- D. Receiving Sewer: Size: 21 inches Capacity: * _____ gpm *replacement of Ex 21" Sanitary*

3.0 PROJECT OWNER

NAME	TELEPHONE NUMBER WITH AREA CODE	E-MAIL ADDRESS	
City of Liberty, Brian Hess, PE (Utilities Director)	(816) 439-4502	bhess@ci.liberty.mo.us	
ADDRESS	CITY	STATE	ZIP CODE
101 E Kansas	Liberty	Missouri	60468

4.0 CONTINUING AUTHORITY: Permanent organization that will serve as the continuing authority for the operation, maintenance and modernization of the wastewater collection system.

NAME	TELEPHONE NUMBER WITH AREA CODE	E-MAIL ADDRESS	
same as project owner			
ADDRESS	CITY	STATE	ZIP CODE

4.1 A letter from the continuing authority, if different than the owner, is included with this application. YES NO N/A

5.0 ENGINEER

ENGINEER NAME / COMPANY NAME	TELEPHONE NUMBER WITH AREA CODE	E-MAIL ADDRESS	
Ronald L. Cowger, PE / AGC Engineers, Inc.	(816) 781-4200	rcowger@agcengineers.com	
ADDRESS	CITY	STATE	ZIP CODE
405 S Leonard, Ste D	Liberty	Missouri	64068

6.0 RECEIVING WASTEWATER TREATMENT FACILITY

NAME	TELEPHONE NUMBER WITH AREA CODE	E-MAIL ADDRESS
KCMO Birmingham WWTP	(816) 513-0303	N/A

MISSOURI STATE OPERATING PERMIT # MO-0049531		REMAINING CAPACITY (GPD) 7 MGD (7,000,000 gpd)	
6.1 Has the receiving treatment facility agreed to accept the additional wastewater flow? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO			
6.2 A letter from the receiving wastewater treatment facility, if different than the continuing authority, is included with this application. <input type="checkbox"/> YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> N/A <i>replacement of Ex 21" Sanitary and Ex 8" sanitary</i>			
7.0 PROJECT OWNER: I hereby certify that I am familiar with the information contained in this application and to the best of my knowledge and belief such information is true, complete, and accurate, and if granted this permit, I agree to abide by the Missouri Clean Water Law and all rules, regulations, orders, and decisions, subject to any legitimate appeal available to applicant under Missouri Clean Water Law.			
PROJECT OWNER SIGNATURE 			
PRINTED NAME Brian Hess, PE		DATE 11/06/2014	
TITLE OR CORPORATE POSITION Utilities Director	TELEPHONE NUMBER WITH AREA CODE (816) 439-4502	E-MAIL ADDRESS bhess@ci.liberty.mo.us	
Mail completed copy to:		MISSOURI DEPARTMENT OF NATURAL RESOURCES WATER PROTECTION PROGRAM P.O. BOX 176 JEFFERSON CITY, MO 65102-0176	